

TRANSMITTAL SHEET

TO: All Bidders

DATE: March 25, 2021

TOTAL NUMBER OF PAGES (INCLUDING COVER PAGE): 3

FROM: Kevin O'Brien, P. Eng. TEL. #: (506) 658-2894
Utilities & Infrastructure Services

IF YOU DID NOT RECEIVE ALL PAGES, OR FURTHER INFORMATION IS REQUIRED,
PLEASE CONTACT THE SENDER

MESSAGE:

TENDER NO: 2020-01

**WATERLOO STREET (HAYMARKET SQUARE TO CASTLE STREET) -
WATER, SANITARY AND STORM SEWER RENEWAL AND STREET
RECONSTRUCTION**

Please find attached a copy of Addendum #1 for the above tender.

As of March 2021, please be advised that an *Acknowledgement Form* (historically sent as part of the City's addendum packages) confirming receipt of an Addendum is **no longer** included in the addendum package.

However, in accordance with Section 2.5.03 of the City's General Specifications, it remains a requirement that **each Addendum** will contain a signature page(s) which each Tenderer is **required to sign and include with its Tender submission.**



UTILITIES & INFRASTRUCTURE SERVICES
Engineering Services

175 Rothesay Avenue
Saint John, NB, E2J 2B4

A D D E N D U M

PROJECT TITLE:

ADDENDUM NO: 1

WATERLOO STREET (HAYMARKET SQUARE TO

DATE: March 25, 2021

CASTLE STREET) – WATER, SANITARY AND STORM

PAGE: 1 OF 2

SEWER RENEWAL AND STREET RECONSTRUCTION

TENDER NO: 2020-01

MAKE THE FOLLOWING MODIFICATIONS TO THE ABOVE PROJECT. INCLUDE IN THE AMOUNT OF THE TENDER ANY ADDITIONS TO OR DEDUCTIONS FROM THE COST OF THE WORK BY REASON OF THESE INSTRUCTIONS. THE DATE FOR RECEIVING TENDERS REMAINS AT: **2:30PM, TUESDAY, MARCH 30TH, 2021.**

TO THE SPECIFICATIONS:

Division 2 – Submission of Tender

As a result of the COVID-19 pandemic, the City of Saint John is implementing adjustments to the tender submission procedure as follows:

2.6.01 Location of Tender Box for the Submission of Tender

175 Rothesay Avenue, Saint John, New Brunswick

The tender box will be available at the main building entrance for submission of tenders by the Tenderer between the hours of 9:30am and 2:30pm only on the above tender closing date. Tenderers shall maintain physical distancing from others when depositing their tender in the tender box.

There will not be a public tender opening. The Tender Opening Committee will conduct the evaluation of the Tenders and Compliant tenders will be included in the summary of bids on the City's Tenders & Procurements website within 1 business day following the tender closing.

COVID-19 Pandemic: Considerations for Construction Contracts

In addition to the requirements of Section 7.11 (Notification of Official Agencies), the Contractor shall be responsible for carrying out the Works in strict accordance with all Federal, Provincial and Municipal Laws, Acts, Regulations, by-laws, codes, etc., including any orders, policies, directives, standards and guidelines issued by any governmental authority, governing all or any part of the work under this Contract. The Contractor shall be responsible for fully complying with the requirements of all agencies governing COVID-19. All costs associated with meeting the requirements as it relates to COVID-19 are the responsibility of the Contractor and should be included in their bid.

Bionax Watermain

Bionax PVCO watermain will be considered as an equivalent to PVC watermain for the 300mm and 200mm diameters of watermain on Waterloo Street between GV-7 and GV-20. It shall not be permitted for use on the 300mm and 400mm diameter watermain in the Haymarket Square intersection. Should the Contractor use PVCO watermain conforming to the latest AWWA C 909 Standard, they must provide documentation that all appurtenances have been tested and approved for use on this class of pipe.

Note: Signed copy of the addendum **must** be enclosed in the tender documents, according to the Instructions to Tenderers and Tendering Procedures in Division 2 of the Contract Specifications.

BY:



CHIEF CITY ENGINEER

CONTRACTOR'S SIGNATURE

TO BE SIGNED AND ATTACHED TO TENDER DOCUMENTS