



## ADDENDUM

PROJECT TITLE: Refrigeration System Upgrades – City Arenas	ADD. NO: 1
TENDER NO: 2021-085302T	DATE: April 22, 2021
PAGE 1 of 2 (Including Confirmation Sheet)	

Make the following modifications to the above project. Include in the amount of the Tender, any additions to or deductions from the cost of the work by reason of these instructions.

**Sign and attach this Addendum to the Tender documents and submit with your Tender. Failure to do so may result in the rejection of your Tender.**

Add to specifications:

For each new evaporative condenser, contractor is to include an auxiliary circuit for compressor glycol cooling.

**SIGN AND RETURN THIS ADDENDUM WITH YOUR TENDER**

\_\_\_\_\_  
Chris Roberts, SCMP, CPPB  
Procurement Manager  
Supply Chain Management

\_\_\_\_\_  
Contractor's Signature



## ADDENDUM

PROJECT TITLE: Refrigeration System Upgrades – City Arenas	ADD. NO: 1
TENDER NO: 2021-085302T	DATE: April 22, 2021
PAGE 2 of 2 (Including Confirmation Sheet)	

## CONFIRMATION - RECEIPT OF ADDENDUM

**Upon receipt of this document, fax this page to  
(506) 658-4742 to confirm receipt of this addendum.**

CONTRACTOR'S NAME: \_\_\_\_\_

ADDRESS: \_\_\_\_\_  
\_\_\_\_\_

PHONE: \_\_\_\_\_ FAX: \_\_\_\_\_

RECEIVER NAME (PRINT) \_\_\_\_\_

RECEIVER SIGNATURE: \_\_\_\_\_