

TRANSMITTAL SHEET

TO: All Bidders

DATE: April 15, 2021

TOTAL NUMBER OF PAGES (INCLUDING COVER PAGE): 3

FROM: Gerry Mattsson, P.Eng. TEL. #: 506 649 7998
Utilities & Infrastructure Services

IF YOU DID NOT RECEIVE ALL PAGES, OR FURTHER INFORMATION IS REQUIRED,
PLEASE CONTACT THE SENDER

MESSAGE:

TENDER NO: 2021-12

Westmorland Rd. & Bayside Dr. Flow Meters/Chamber #33 Flow Limiting Valves

Please find attached a copy of Addendum #1 for the above tender.

As of March 2021, please be advised that an *Acknowledgement Form* (historically sent as part of the City's addendum packages) confirming receipt of an Addendum is **no longer** included in the addendum package.

However, in accordance with Section 2.5.03 of the City's General Specifications, it remains a requirement that **each Addendum** will contain a signature page(s) which each Tenderer is **required to sign and include with its Tender submission.**



UTILITIES & INFRASTRUCTURE SERVICES
Engineering Services
175 Rothesay Avenue
Saint John, NB, E2J 2B4

ADDENDUM

PROJECT TITLE:

Westmorland Rd. & Bayside Dr. Flow Meters/Chamber #33
Flow Limiting Valves

ADDENDUM NO: 1

DATE: April 15, 2021

PAGE: 1 OF 2

TENDER NO: 2021-12

MAKE THE FOLLOWING MODIFICATIONS TO THE ABOVE PROJECT. INCLUDE IN THE AMOUNT OF THE TENDER ANY ADDITIONS TO OR DEDUCTIONS FROM THE COST OF THE WORK BY REASON OF THESE INSTRUCTIONS. THE DATE FOR RECEIVING TENDERS REMAINS AT: **2:30PM, WEDNESDAY, April 21, 2021.**

ADDITION TO THE SPECIFICATIONS

Division 2 – Submission of Tender

As a result of the COVID-19 pandemic, the City of Saint John is implementing adjustments to the tender submission procedure as follows:

Section 2.6.01 Location of Tender Box for the Submission of Tender

175 Rothesay Avenue, Saint John, New Brunswick

The tender box will be available at the main building entrance for submission of tenders by the Tenderer between the hours of 9:30 am and 2:30 pm only on the above tender closing date. Tenderers shall maintain physical distancing from others when depositing their tender in the tender box.

There will not be a public tender opening. Registered Bidders will receive an email invitation to view the Tender Opening using Microsoft Teams software. Email invitations will be sent to the address provided on the Official Bidder's List. The Tender Opening Committee will conduct the evaluation of the tenders and Compliant tenders will be included in the summary of bids on the City's Tenders & Proposals website within 1 business day following the tender closing.

Questions from Bidders:

Question #1: Can COSJ provide a control narrative for the control valves in chamber 33 for our control contractor?

Response #1: The flow limiting valves are controlled by the Group 2 relay outputs on the PLC system. When the pump station is running, both flow limiting valves will be closed sending no water to the clear well. When the pump station is not running, both flow limiting valves will be open discharging water to the clear well at a flow rate of 6.1 million litres/day.

The flow limiting valve solenoids are powered via the 24VDC power supply in the SCADA panel.

The flow limiting valves limit switch assemblies are connected to the DC inputs on the PLC system to give indication status that the valves are open.

Note: Signed copy of the addendum **must** be enclosed in the tender documents, according to the Instructions to Tenderers and Tendering Procedures in Division 2 of the Contract Specifications.

BY:



CHIEF CITY ENGINEER

CONTRACTOR'S SIGNATURE

TO BE SIGNED AND ATTACHED TO TENDER DOCUMENTS