



ADDENDUM

| | |
|-----------------------------------------------------------|---------------------|
| PROJECT TITLE: ENGINEERING SERVICES: “WWPS Woodlawn Park” | ADD. NO: 1 |
| TENDER NO: 2021-091006P | DATE: June 22, 2021 |
| PAGE 1 of 2 (Including Confirmation Sheet) | |

Make the following modifications to the above project. Include in the amount of the Tender, any additions to or deductions from the cost of the work by reason of these instructions.

Sign and attach this Addendum to the Tender documents and submit with your Tender. Failure to do so may result in the rejection of your Tender.

Please find below questions and responses.

(REVISED – SEE ANSWER FOR QUESTION 2.)

Q1. Under Section 2 Project Description, Item 3: Can the City please clarify whether the consultant is issuing the RFP or is the consultant supplying the documentation for the City to issue the preselection RFP for the supply of wastewater pumps?

A1. *The consultant will be responsible for evaluating pumping requirements, providing technical performance specifications and participate in the evaluation of submittals. The City will administer the preselection RFP.*

Q2. Under Section 2 Project Description, Item 4: Can the City please clarify if the design of a mechanical screen system is indeed part of this project as this would be significantly different than the reference station at Tilley Avenue and has a significant impact on scope?

A2. *The current Woodlawn station utilizes a bar screen which is manually cleaned bi-monthly. The consultant shall investigate the requirement for screening at this location and design the new station accordingly. Should the consultant determine that screening is required, include specific reasoning for including screening in the details of the proposal.*

Q3. In the interest of environmental sustainability, would the City consider accepting proposals submitted through email?

A3. *No. Please follow “Submissions of Proposal” instructions as specified on page 24 and 25 of the RFP document.*

SIGN AND RETURN THIS ADDENDUM WITH YOUR PROPOSAL

Monic MacVicar, CCLP, CPPB
Procurement Specialist
Supply Chain Management

Contractor’s Signature



ADDENDUM

| | |
|-----------------------------------------------------------|---------------------|
| PROJECT TITLE: ENGINEERING SERVICES: "WWPS Woodlawn Park" | ADD. NO: 1 |
| TENDER NO: 2021-091006P | DATE: June 22, 2021 |
| PAGE 2 of 2 (Including Confirmation Sheet) | |

CONFIRMATION - RECEIPT OF ADDENDUM

Upon receipt of this document, fax this page to (506) 658-4742 to confirm receipt of this addendum.

CONTRACTOR'S NAME: _____

ADDRESS: _____

PHONE: _____ FAX: _____

RECEIVER NAME (PRINT) _____

RECEIVER SIGNATURE: _____