

**TRANSMITTAL SHEET**

**TO:** All Bidders  
**DATE:** Aug 6, 2021  
**TOTAL NUMBER OF PAGES (INCLUDING COVER PAGE):** 6  
**FROM:** Dean Price, P. Eng. **TEL. #:** (506) 658-4770  
*Utilities & Infrastructure Services*

IF YOU DID NOT RECEIVE ALL PAGES, OR FURTHER INFORMATION IS REQUIRED,  
PLEASE CONTACT THE SENDER

**MESSAGE:**

**TENDER NO: 2021-20**

**Visart Street Combined Sewer Emergency Repair**

Please find attached a copy of **Addendum #1** for the above tender.

As of March 2021, please be advised that an ***Acknowledgement Form*** (historically sent as part of the City's addendum packages) confirming receipt of an Addendum is **no longer** included in the addendum package.

However, in accordance with Section 2.5.03 of the City's General Specifications, it remains a requirement that **each Addendum** will contain a signature page(s) which each Tenderer is **required to sign and include with its Tender submission.**



**UTILITIES & INFRASTRUCTURE SERVICES**  
Engineering Services  
175 Rothesay Avenue  
Saint John, NB, E2J 2B4

## **ADDENDUM**

**PROJECT TITLE:**

Visart Street Combined Sewer Emergency Repair

**ADDENDUM NO:** 1

**DATE:** August 6, 2021

**PAGE:** 1 OF 5

**TENDER NO:** 2021-20

MAKE THE FOLLOWING MODIFICATIONS TO THE ABOVE PROJECT. INCLUDE IN THE AMOUNT OF THE TENDER ANY ADDITIONS TO OR DEDUCTIONS FROM THE COST OF THE WORK BY REASON OF THESE INSTRUCTIONS. THE DATE FOR RECEIVING TENDERS REMAINS AT: **2:30PM, TUESDAY, AUGUST 10, 2021.**

### **REVISIONS TO THE SPECIFICATIONS**

#### **Division 2 – Submission of Tender**

##### **2.2.10 Timetable for Completion of the Work**

**Remove:**

The Substantial Completion of the Work is **September 30, 2021.**

**Add:**

The Substantial Completion of the Work is **October 15, 2021.**

As this work is an emergency repair and in close proximity to a school the City requires the work to be completed as soon as possible, but no later than **October 15, 2021.**

##### **2.6.01 Location of Tender Box for the Submission of Tender**

**Replace this section with the following:**

175 Rothesay Avenue, Saint John, New Brunswick

The tender box will be available at the main building entrance for submission of tenders by the Tenderer between the hours of 9:30 am and 2:30 pm only on the above tender closing date. Tenderers shall maintain physical distancing from others when depositing their tender in the tender box.

There will not be a public tender opening. Registered Bidders will receive an email invitation to view the Tender Opening using Microsoft Teams software. Email invitations will be sent to the address provided on the Official Bidder's List. The Tender Opening Committee will conduct the evaluation of the tenders and Compliant tenders will be included in the summary of bids on the City's Tenders & Proposals website within 1 business day following the tender closing.

## **Division 3 – Particular Specification**

### **3.1.02 SITE RESTRICTIONS**

**Replace this section with the following:**

The following shall be strictly observed:

Following the start of the school year, rock breaking shall not be permitted during school hours unless otherwise approved by the Centennial School. School hours shall be considered anytime between 8:00am and 4:00pm Monday through Friday after August 31<sup>st</sup>, 2021.

During school hours the contractor shall organize their work to have the least impact possible on the school.

It is the Contractor's responsibility to examine the site(s) and determine any other restrictions which may affect the work, as no claim will be entertained for any additional costs caused by site conditions or restrictions.

All permits required shall be in place before any work can begin. Claims will not be considered for any delays related to property acquisitions. Nevertheless, material shall be ordered immediately upon award.

Concrete pipe shall not be accepted as a material for the combined sewer or storm sewer piping, excluding the connection to the existing concrete storm sewer at approximate Sta. 0+058.

### **3.1.06 SAFETY**

**Add the following paragraph to the section:**

The contractor is responsible for the installation of temporary metal safety fence around the excavation at all times when they are not on site.

### **Section 3.1.08 SCHEDULE OF WORK**

**Remove:**

The specified Substantial Completion date for this contract is on or before **September 30, 2021**.

**Add:**

The specified Substantial Completion date for this contract is on or before **October 15, 2021**.

As this work is an emergency repair and in close proximity to a school the City requires the work to be completed as soon as possible, but no later than **October 15, 2021**.

### **3.1.10 TRAFFIC DIRECTION AND CONTROL**

**Add the following paragraph to the section:**

Access to the Centennial School driveway via Visart Street shall be maintained at all times during school hours. If access to vehicular traffic cannot be maintained (i.e. Piping between CSMH-4 and CSMH-5) this work shall be completed after 4:00pm on weekdays or on weekends, or as agreed with the school.

### **Section 3.1.11 ITEMS TO BE SUPPLIED BY THE CONTRACTOR**

**Replace this section with the following:**

The Contractor shall supply everything necessary to complete the work shown on the drawings and detailed in these Specifications. This includes minor details, work, materials, equipment, labour and/or services not specifically indicated on the Drawings or in the Specifications but required for the proper completion of the work.

Combined sewer and storm sewer manholes shall be provided by the Owner. These manholes have not yet been manufactured but are to be ordered as soon as possible by the Owner.

The Contractor shall be responsible to coordinate delivery of the manholes to the project site with the supplier. Once the project is awarded and agreements are signed the City will inform the Contractor of the manhole supplier so delivery arrangements can be made. The Contractor shall be responsible to unload the structures at the site.

## **Division 4 – Form of Tender**

### **4.2 Tenderer's Responsibilities and Agreement**

**Remove:**

In the event the City accepts its Tender, the undersigned Tenderer hereby agrees to Substantially Complete asphalt paving, pipe installation and site works no later than **September 30, 2021**.

**Add:**

In the event the City accepts its Tender, the undersigned Tenderer hereby agrees to Substantially Complete asphalt paving, pipe installation and site works no later than **October 15, 2021**.

As this work is an emergency repair and in close proximity to a school the City requires the work to be completed as soon as possible, but no later than **October 15, 2021**.

### **4.5 Schedule of Quantities and unit Prices**

#### **Section E Landscaping - Supply & Place - Topsoil – 100mm Thickness**

The quantity of topsoil shall be 9 cubic meters and not 90 cubic meters.

The adjusted Schedule of Quantities and Unit Prices is attached.

Replace page 8 of 10 for tender submission.

**Division 5 – Form of Agreement**

**5.1 Agreement Between Owner and Contractor**

**Remove:**

(c) The Contractor shall Substantially Complete the asphalt paving, pipe installation and site works no later than **September 30<sup>th</sup>, 2021**.

**Add:**

(c) The Contractor shall Substantially Complete the asphalt paving, pipe installation and site works no later than **October 15<sup>th</sup>, 2021**.

As this work is an emergency repair and in close proximity to a school the City requires the work to be completed as soon as possible, but no later than **October 15, 2021**.

**Note:** Signed copy of the addendum **must** be enclosed in the tender documents, according to the Instructions to Tenderers and Tendering Procedures in Division 2 of the Contract Specifications.

BY:



CHIEF CITY ENGINEER

CONTRACTOR'S SIGNATURE

**TO BE SIGNED AND ATTACHED TO TENDER DOCUMENTS**

DIVISION 4  
SCHEDULE OF QUANTITIES AND UNIT PRICES

CONTRACT NUMBER: 2021-20

TITLE: Visart Street Combined Sewer Emergency Repair

UNIT PRICE TO BE  
EITHER TYPEWRITTEN  
OR PRINTED IN INK IN  
WORDS AND PRINTED  
NUMERICALLY

ITEM NO.	DESCRIPTION	DIV. NO.	UNIT	EST. QTY.	UNIT BID PRICE		TOTAL (\$)
					WRITTEN	NUMERICAL	
E	LANDSCAPING	5.11					
	<u>Landscaping - Supply &amp; Place</u>						
	Topsoil - 100mm thickness		m <sup>3</sup>	9			
	Nursery Sod (minimum thickness 40mm)		m <sup>2</sup>	90			
	<u>Contingency</u>	2.6.03	LS	1	One Thousand Dollars and Zero Cents	1,000.00	1,000.00
	<b>AMOUNT "E" (LANDSCAPING)</b>						