



## ADDENDUM

PROJECT TITLE: Public Space at Market Slip & Harbour Passage Extension – Pedestrian Level Light Fixtures	ADD. NO: 1
RFP NO: 2022-621001P	DATE: March 21, 2022
PAGE 1 of 2 (Including Confirmation Sheet)	

Make the following modifications to the above project. Include in the amount of the Proposal, any additions to or deductions from the cost of the work by reason of these instructions.

**Sign and attach this Addendum to the Proposal documents and submit with your Proposal. Failure to do so may result in the rejection of your Proposal.**

**Item No. 1**

Please note that the closing date and time for this RFP has been changed to Thursday, March 31, 2022, 4:00 pm, ADT.

**Item No. 2 – Questions and Answers**

Q1. Please advise if there are GFI sockets on the poles and if yes, please let us know on which poles.

*A1. All shuffles will require GFI.*

Q2. The strobe needs to be connected to an intercom which is not specified on the technical description. The strobe is a security component and needs to be activated manually.

*A2. Please remove option "Strobe" from light Item # 12 as indicated on bid price form.*

**SIGN AND RETURN THIS ADDENDUM WITH YOUR PROPOSAL**

---

Chris Roberts, SCMP, CPPB  
Procurement Manager  
Supply Chain Management

---

Proponent's Signature



## ADDENDUM

PROJECT TITLE: Public Space at Market Slip & Harbour Passage Extension – Pedestrian Level Light Fixtures	ADD. NO: 1
RFP NO: 2022-621001P	DATE: March 21, 2022
PAGE 2 of 2 (Including Confirmation Sheet)	

## CONFIRMATION - RECEIPT OF ADDENDUM

**Upon receipt of this document, fax this page to  
(506) 658-4742 to confirm receipt of this addendum.**

CONSULTANT'S NAME: \_\_\_\_\_

ADDRESS: \_\_\_\_\_

\_\_\_\_\_

PHONE: \_\_\_\_\_ FAX: \_\_\_\_\_

RECEIVER NAME (PRINT) \_\_\_\_\_

RECEIVER SIGNATURE: \_\_\_\_\_