

New Brunswick Clean Water Results Latimer Lake Raw Water (Source 4)			
Organic Parameters:	Units	Health Advisory Limit	January 17 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		< 0.29
Bromodichloromethane	µg/L		< 0.26
Dibromochloromethane	µg/L		< 0.37
Bromoform	µg/L		< 0.34
Total Trihalomethanes	µg/L	100	< 0.37
Trichloroacetic acid	µg/L		< 5.3
Dichloroacetic acid	µg/L		< 2.6
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	< 5.3

Inorganic Parameters:	Units	Health Advisory Limit	January 17 2022
Alkalinity (as CaCO3)	mg/L		8
Total Hardness (as CaCO3)	mg/L		13
Aluminum	µg/L		43
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	<10
Boron	µg/L	5000	< 10
Cadmium	µg/L	7	<0.02
Calcium	mg/L		4.2
Chloride	mg/L		7.9
Chromium	µg/L	50	<1
Copper	µg/L	2000	<1
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		71
Lead	µg/L	5	<1
Magnesium	mg/L		0.6
Manganese	µg/L	120	10
Mercury	µg/L	1	<0.02
Nitrate (as NO3)	mg/L	45	<0.2
pH			6.78
Potassium	mg/L		0.1
Selenium	µg/L	50	<2
Sodium	mg/L		3.4
Sulphate	mg/L		2
Thallium	µg/L		<1
Turbidity	NTU		0.79
Uranium	µg/L	20	<0.5
Zinc	µg/L		<2

**New Brunswick Clean Water Results
Operations Complex (Zone 4)**

Organic Parameters:	Units	Health Advisory Limit	January 17 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		20.0
Bromodichloromethane	µg/L		3.5
Dibromochloromethane	µg/L		< 0.37
Bromoform	µg/L		< 0.34
Total Trihalomethanes	µg/L	100	23
Trichloroacetic acid	µg/L		23.2
Dichloroacetic acid	µg/L		15.0
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	38.1

Inorganic Parameters:	Units	Health Advisory Limit	January 17 2022
Alkalinity (as CaCO3)	mg/L		29
Total Hardness (as CaCO3)	mg/L		18
Aluminum	µg/L		12
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	<10
Boron	µg/L	5000	<10
Cadmium	µg/L	7	<0.02
Calcium	mg/L		6.2
Chloride	mg/L		10.5
Chromium	µg/L	50	<1
Copper	µg/L	2000	18
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		4
Lead	µg/L	5	<1
Magnesium	mg/L		0.6
Manganese	µg/L	120	<2
Mercury	µg/L	1	<0.02
Nitrate (as NO3)	mg/L	45	<0.2
pH			7.48
Potassium	mg/L		0.2
Selenium	µg/L	50	<2
Sodium	mg/L		10.9
Sulphate	mg/L		2
Thallium	µg/L		<1
Turbidity	NTU		0.25
Uranium	µg/L	20	<0.5
Zinc	µg/L		80

**New Brunswick Clean Water Results
36 Park Drive (Zone 24)**

Organic Parameters:	Units	Health Advisory Limit	January 17 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		44.0
Bromodichloromethane	µg/L		5.9
Dibromochloromethane	µg/L		< 0.37
Bromoform	µg/L		< 0.34
Total Trihalomethanes	µg/L	100	50.0
Trichloroacetic acid	µg/L		37.5
Dichloroacetic acid	µg/L		21.4
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	58.9

Inorganic Parameters:	Units	Health Advisory Limit	January 17 2022
Alkalinity (as CaCO3)	mg/L		29
Total Hardness (as CaCO3)	mg/L		18
Aluminum	µg/L		22
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	<10
Boron	µg/L	5000	<10
Cadmium	µg/L	7	<0.02
Calcium	mg/L		6.2
Chloride	mg/L		10.3
Chromium	µg/L	50	<1
Copper	µg/L	2000	<1
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		30
Lead	µg/L	5	<1
Magnesium	mg/L		0.6
Manganese	µg/L	120	<2
Mercury	µg/L	1	<0.02
Nitrate (as NO3)	mg/L	45	<0.2
pH			7.41
Potassium	mg/L		0.3
Selenium	µg/L	50	<2
Sodium	mg/L		10.7
Sulphate	mg/L		2
Thallium	µg/L		<1
Turbidity	NTU		0.20
Uranium	µg/L	20	<0.5
Zinc	µg/L		93

**New Brunswick Clean Water Results
Lakewood Pump Station, Line #2 (Zone 18)**

Organic Parameters:	Units	Health Advisory Limit	January 17 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		15.0
Bromodichloromethane	µg/L		2.9
Dibromochloromethane	µg/L		< 0.37
Bromoform	µg/L		< 0.34
Total Trihalomethanes	µg/L	100	18.0
Trichloroacetic acid	µg/L		17.5
Dichloroacetic acid	µg/L		11.3
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	28.8

Inorganic Parameters:	Units	Health Advisory Limit	January 17 2022
Alkalinity (as CaCO3)	mg/L		29
Total Hardness (as CaCO3)	mg/L		17
Aluminum	µg/L		36
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	<10
Boron	µg/L	5000	<10
Cadmium	µg/L	7	<0.02
Calcium	mg/L		5.9
Chloride	mg/L		10.4
Chromium	µg/L	50	<1
Copper	µg/L	2000	<1
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		41
Lead	µg/L	5	<1
Magnesium	mg/L		0.6
Manganese	µg/L	120	<2
Mercury	µg/L	1	<0.02
Nitrate (as NO3)	mg/L	45	<0.2
pH			7.44
Potassium	mg/L		0.3
Selenium	µg/L	50	<2
Sodium	mg/L		11.1
Sulphate	mg/L		2
Thallium	µg/L		<1
Turbidity	NTU		0.17
Uranium	µg/L	20	<0.5
Zinc	µg/L		85

**New Brunswick Clean Water Results
Ryerson Metals (Zone 7)**

Organic Parameters:	Units	Health Advisory Limit	January 17 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		26.0
Bromodichloromethane	µg/L		4.2
Dibromochloromethane	µg/L		< 0.37
Bromoform	µg/L		< 0.34
Total Trihalomethanes	µg/L	100	30.0
Trichloroacetic acid	µg/L		29.4
Dichloroacetic acid	µg/L		16.9
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	46.3

Inorganic Parameters:	Units	Health Advisory Limit	January 17 2022
Alkalinity (as CaCO3)	mg/L		29
Total Hardness (as CaCO3)	mg/L		17
Aluminum	µg/L		10
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	<10
Boron	µg/L	5000	<10
Cadmium	µg/L	7	<0.02
Calcium	mg/L		5.9
Chloride	mg/L		10.5
Chromium	µg/L	50	<1
Copper	µg/L	2000	<1
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		75
Lead	µg/L	5	<1
Magnesium	mg/L		0.6
Manganese	µg/L	120	<2
Mercury	µg/L	1	<0.02
Nitrate (as NO3)	mg/L	45	<0.2
pH			7.40
Potassium	mg/L		0.2
Selenium	µg/L	50	<2
Sodium	mg/L		10.9
Sulphate	mg/L		2
Thallium	µg/L		<1
Turbidity	NTU		0.35
Uranium	µg/L	20	<0.5
Zinc	µg/L		75

**New Brunswick Clean Water Results
University Avenue Pumping Station (Zone 15)**

Organic Parameters:	Units	Health Advisory Limit	January 17 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		20.0
Bromodichloromethane	µg/L		3.6
Dibromochloromethane	µg/L		< 0.37
Bromoform	µg/L		< 0.34
Total Trihalomethanes	µg/L	100	24.0
Trichloroacetic acid	µg/L		22.3
Dichloroacetic acid	µg/L		14.4
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	36.7

Inorganic Parameters:	Units	Health Advisory Limit	January 17 2022
Alkalinity (as CaCO3)	mg/L		29
Total Hardness (as CaCO3)	mg/L		16
Aluminum	µg/L		90
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	<10
Boron	µg/L	5000	<10
Cadmium	µg/L	7	<0.02
Calcium	mg/L		5.6
Chloride	mg/L		11.1
Chromium	µg/L	50	<1
Copper	µg/L	2000	14
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		166
Lead	µg/L	5	<1
Magnesium	mg/L		0.6
Manganese	µg/L	120	<2
Mercury	µg/L	1	<0.02
Nitrate (as NO3)	mg/L	45	<0.2
pH			7.28
Potassium	mg/L		0.3
Selenium	µg/L	50	<2
Sodium	mg/L		11.7
Sulphate	mg/L		2
Thallium	µg/L		<1
Turbidity	NTU		0.21
Uranium	µg/L	20	<0.5
Zinc	µg/L		79

**New Brunswick Clean Water Results
Kennebecasis Drive (Zone 10)**

Organic Parameters:	Units	Health Advisory Limit	January 17 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		27.0
Bromodichloromethane	µg/L		4.3
Dibromochloromethane	µg/L		< 0.37
Bromoform	µg/L		< 0.34
Total Trihalomethanes	µg/L	100	31.0
Trichloroacetic acid	µg/L		21.1
Dichloroacetic acid	µg/L		13.8
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	34.9

Inorganic Parameters:	Units	Health Advisory Limit	January 17 2022
Alkalinity (as CaCO3)	mg/L		26
Total Hardness (as CaCO3)	mg/L		17
Aluminum	µg/L		10
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	<10
Boron	µg/L	5000	<10
Cadmium	µg/L	7	<0.02
Calcium	mg/L		5.8
Chloride	mg/L		11.1
Chromium	µg/L	50	<1
Copper	µg/L	2000	<1
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		<2
Lead	µg/L	5	<1
Magnesium	mg/L		0.6
Manganese	µg/L	120	<2
Mercury	µg/L	1	<0.02
Nitrate (as NO3)	mg/L	45	<0.2
pH			7.38
Potassium	mg/L		0.3
Selenium	µg/L	50	<2
Sodium	mg/L		10.9
Sulphate	mg/L		2
Thallium	µg/L		<1
Turbidity	NTU		0.16
Uranium	µg/L	20	<0.5
Zinc	µg/L		66

**New Brunswick Clean Water Results
Millidgeville WWTP (Zone 25)**

Organic Parameters:	Units	Health Advisory Limit	January 17 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		24.0
Bromodichloromethane	µg/L		4.0
Dibromochloromethane	µg/L		< 0.37
Bromoform	µg/L		< 0.34
Total Trihalomethanes	µg/L	100	28.0
Trichloroacetic acid	µg/L		21.1
Dichloroacetic acid	µg/L		13.9
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	35.1

Inorganic Parameters:	Units	Health Advisory Limit	January 17 2022
Alkalinity (as CaCO3)	mg/L		27
Total Hardness (as CaCO3)	mg/L		17
Aluminum	µg/L		53
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	<10
Boron	µg/L	5000	<10
Cadmium	µg/L	7	<0.02
Calcium	mg/L		5.9
Chloride	mg/L		11.2
Chromium	µg/L	50	<1
Copper	µg/L	2000	44
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		83
Lead	µg/L	5	<1
Magnesium	mg/L		0.6
Manganese	µg/L	120	<2
Mercury	µg/L	1	<0.02
Nitrate (as NO3)	mg/L	45	<0.2
pH			7.13
Potassium	mg/L		0.3
Selenium	µg/L	50	<2
Sodium	mg/L		11.4
Sulphate	mg/L		2
Thallium	µg/L		<1
Turbidity	NTU		0.16
Uranium	µg/L	20	<0.5
Zinc	µg/L		67

New Brunswick Clean Water Results Harris & Roome (Zone 22)			
Organic Parameters:	Units	Health Advisory Limit	January 17 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		23.0
Bromodichloromethane	µg/L		3.9
Dibromochloromethane	µg/L		< 0.37
Bromoform	µg/L		< 0.34
Total Trihalomethanes	µg/L	100	27.0
Trichloroacetic acid	µg/L		23.6
Dichloroacetic acid	µg/L		14.7
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	38.3

Inorganic Parameters:	Units	Health Advisory Limit	January 17 2022
Alkalinity (as CaCO3)	mg/L		29
Total Hardness (as CaCO3)	mg/L		16
Aluminum	µg/L		26
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	<10
Boron	µg/L	5000	<10
Cadmium	µg/L	7	<0.02
Calcium	mg/L		5.3
Chloride	mg/L		8.9
Chromium	µg/L	50	<1
Copper	µg/L	2000	<1
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		36
Lead	µg/L	5	<1
Magnesium	mg/L		0.6
Manganese	µg/L	120	<2
Mercury	µg/L	1	<0.02
Nitrate (as NO3)	mg/L	45	<0.2
pH			7.29
Potassium	mg/L		0.4
Selenium	µg/L	50	<2
Sodium	mg/L		11.5
Sulphate	mg/L		2
Thallium	µg/L		<1
Turbidity	NTU		0.23
Uranium	µg/L	20	<0.5
Zinc	µg/L		81

**New Brunswick Clean Water Results
Champlain Heights Pump Station (Zone 13)**

Organic Parameters:	Units	Health Advisory Limit	January 17 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		15.0
Bromodichloromethane	µg/L		2.9
Dibromochloromethane	µg/L		< 0.37
Bromoform	µg/L		< 0.34
Total Trihalomethanes	µg/L	100	18.0
Trichloroacetic acid	µg/L		18.4
Dichloroacetic acid	µg/L		11.5
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	30.0

Inorganic Parameters:	Units	Health Advisory Limit	January 17 2022
Alkalinity (as CaCO3)	mg/L		29
Total Hardness (as CaCO3)	mg/L		17
Aluminum	µg/L		<5
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	<10
Boron	µg/L	5000	<10
Cadmium	µg/L	7	<0.02
Calcium	mg/L		5.6
Chloride	mg/L		10.1
Chromium	µg/L	50	<1
Copper	µg/L	2000	<1
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		<2
Lead	µg/L	5	<1
Magnesium	mg/L		0.7
Manganese	µg/L	120	<2
Mercury	µg/L	1	<0.02
Nitrate (as NO3)	mg/L	45	<0.2
pH			7.28
Potassium	mg/L		0.5
Selenium	µg/L	50	<2
Sodium	mg/L		12
Sulphate	mg/L		2
Thallium	µg/L		<1
Turbidity	NTU		0.22
Uranium	µg/L	20	<0.5
Zinc	µg/L		95

**New Brunswick Clean Water Results
Somerset Street Pump Station (Zone 16)**

Organic Parameters:	Units	Health Advisory Limit	January 17 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		19.0
Bromodichloromethane	µg/L		3.4
Dibromochloromethane	µg/L		< 0.37
Bromoform	µg/L		< 0.34
Total Trihalomethanes	µg/L	100	22.0
Trichloroacetic acid	µg/L		20.7
Dichloroacetic acid	µg/L		13.3
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	34.0

Inorganic Parameters:	Units	Health Advisory Limit	January 17 2022
Alkalinity (as CaCO3)	mg/L		31
Total Hardness (as CaCO3)	mg/L		17
Aluminum	µg/L		98
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	<10
Boron	µg/L	5000	<10
Cadmium	µg/L	7	<0.02
Calcium	mg/L		5.8
Chloride	mg/L		11.3
Chromium	µg/L	50	<1
Copper	µg/L	2000	<1
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		140
Lead	µg/L	5	<1
Magnesium	mg/L		0.6
Manganese	µg/L	120	<2
Mercury	µg/L	1	<0.02
Nitrate (as NO3)	mg/L	45	<0.2
pH			7.35
Potassium	mg/L		0.3
Selenium	µg/L	50	<2
Sodium	mg/L		12.1
Sulphate	mg/L		2
Thallium	µg/L		<1
Turbidity	NTU		0.16
Uranium	µg/L	20	<0.5
Zinc	µg/L		79

**New Brunswick Clean Water Results
Fairville Boulevard Subway (Zone 34)**

Organic Parameters:	Units	Health Advisory Limit	January 17 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		25.0
Bromodichloromethane	µg/L		4.2
Dibromochloromethane	µg/L		< 0.37
Bromoform	µg/L		< 0.34
Total Trihalomethanes	µg/L	100	29.0
Trichloroacetic acid	µg/L		24.0
Dichloroacetic acid	µg/L		15.1
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	39.1

Inorganic Parameters:	Units	Health Advisory Limit	January 17 2022
Alkalinity (as CaCO3)	mg/L		30
Total Hardness (as CaCO3)	mg/L		17
Aluminum	µg/L		28
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	<10
Boron	µg/L	5000	<10
Cadmium	µg/L	7	<0.02
Calcium	mg/L		6
Chloride	mg/L		9
Chromium	µg/L	50	<1
Copper	µg/L	2000	<1
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		27
Lead	µg/L	5	<1
Magnesium	mg/L		0.6
Manganese	µg/L	120	25
Mercury	µg/L	1	<0.02
Nitrate (as NO3)	mg/L	45	<0.2
pH			7.38
Potassium	mg/L		0.4
Selenium	µg/L	50	<2
Sodium	mg/L		11.9
Sulphate	mg/L		2
Thallium	µg/L		<1
Turbidity	NTU		0.58
Uranium	µg/L	20	<0.5
Zinc	µg/L		79

**New Brunswick Clean Water Results
Saint John Laboratory Services (Zone 35)**

Organic Parameters:	Units	Health Advisory Limit	January 17 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		29.0
Bromodichloromethane	µg/L		4.5
Dibromochloromethane	µg/L		< 0.37
Bromoform	µg/L		< 0.34
Total Trihalomethanes	µg/L	100	34.0
Trichloroacetic acid	µg/L		24.0
Dichloroacetic acid	µg/L		14.0
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	38.0

Inorganic Parameters:	Units	Health Advisory Limit	January 17 2022
Alkalinity (as CaCO3)	mg/L		30
Total Hardness (as CaCO3)	mg/L		17
Aluminum	µg/L		5
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	<10
Boron	µg/L	5000	<10
Cadmium	µg/L	7	<0.02
Calcium	mg/L		5.7
Chloride	mg/L		10.6
Chromium	µg/L	50	<1
Copper	µg/L	2000	10
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		14
Lead	µg/L	5	<1
Magnesium	mg/L		0.6
Manganese	µg/L	120	<2
Mercury	µg/L	1	<0.02
Nitrate (as NO3)	mg/L	45	<0.2
pH			7.36
Potassium	mg/L		0.3
Selenium	µg/L	50	<2
Sodium	mg/L		12.0
Sulphate	mg/L		2
Thallium	µg/L		<1
Turbidity	NTU		0.19
Uranium	µg/L	20	<0.5
Zinc	µg/L		76

New Brunswick Clean Water Results Doiron's (Zone 9)			
Organic Parameters:	Units	Health Advisory Limit	January 17 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		24.0
Bromodichloromethane	µg/L		4.1
Dibromochloromethane	µg/L		< 0.37
Bromoform	µg/L		< 0.34
Total Trihalomethanes	µg/L	100	28.0
Trichloroacetic acid	µg/L		22.7
Dichloroacetic acid	µg/L		15.1
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	37.8

Inorganic Parameters:	Units	Health Advisory Limit	January 17 2022
Alkalinity (as CaCO3)	mg/L		29
Total Hardness (as CaCO3)	mg/L		18
Aluminum	µg/L		17
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	<10
Boron	µg/L	5000	<10
Cadmium	µg/L	7	<0.02
Calcium	mg/L		6.4
Chloride	mg/L		10.9
Chromium	µg/L	50	<1
Copper	µg/L	2000	<1
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		23
Lead	µg/L	5	<1
Magnesium	mg/L		0.6
Manganese	µg/L	120	21
Mercury	µg/L	1	<0.02
Nitrate (as NO3)	mg/L	45	<0.2
pH			7.36
Potassium	mg/L		0.5
Selenium	µg/L	50	<2
Sodium	mg/L		11.7
Sulphate	mg/L		2
Thallium	µg/L		<1
Turbidity	NTU		0.41
Uranium	µg/L	20	<0.5
Zinc	µg/L		83

New Brunswick Clean Water Results Carleton Community Centre (Zone 2)			
Organic Parameters:	Units	Health Advisory Limit	January 17 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		23.0
Bromodichloromethane	µg/L		4.0
Dibromochloromethane	µg/L		< 0.37
Bromoform	µg/L		< 0.34
Total Trihalomethanes	µg/L	100	27.0
Trichloroacetic acid	µg/L		23.7
Dichloroacetic acid	µg/L		15.4
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	39.1

Inorganic Parameters:	Units	Health Advisory Limit	January 17 2022
Alkalinity (as CaCO3)	mg/L		29
Total Hardness (as CaCO3)	mg/L		17
Aluminum	µg/L		12
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	<10
Boron	µg/L	5000	<10
Cadmium	µg/L	7	<0.02
Calcium	mg/L		5.7
Chloride	mg/L		11
Chromium	µg/L	50	<1
Copper	µg/L	2000	<1
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		2
Lead	µg/L	5	<1
Magnesium	mg/L		0.6
Manganese	µg/L	120	<2
Mercury	µg/L	1	<0.02
Nitrate (as NO3)	mg/L	45	<0.2
pH			7.32
Potassium	mg/L		0.3
Selenium	µg/L	50	<2
Sodium	mg/L		11.2
Sulphate	mg/L		2
Thallium	µg/L		<1
Turbidity	NTU		0.24
Uranium	µg/L	20	<0.5
Zinc	µg/L		71

New Brunswick Clean Water Results Bridge Road (Zone 8)			
Organic Parameters:	Units	Health Advisory Limit	January 17 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		19.0
Bromodichloromethane	µg/L		3.5
Dibromochloromethane	µg/L		< 0.37
Bromoform	µg/L		< 0.34
Total Trihalomethanes	µg/L	100	22.0
Trichloroacetic acid	µg/L		17.8
Dichloroacetic acid	µg/L		11.1
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	28.9

Inorganic Parameters:	Units	Health Advisory Limit	January 17 2022
Alkalinity (as CaCO3)	mg/L		28
Total Hardness (as CaCO3)	mg/L		14
Aluminum	µg/L		9
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	<10
Boron	µg/L	5000	<10
Cadmium	µg/L	7	<0.02
Calcium	mg/L		5.4
Chloride	mg/L		10.8
Chromium	µg/L	50	<1
Copper	µg/L	2000	<1
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		<2
Lead	µg/L	5	<1
Magnesium	mg/L		0.6
Manganese	µg/L	120	<2
Mercury	µg/L	1	<0.02
Nitrate (as NO3)	mg/L	45	<0.2
pH			7.35
Potassium	mg/L		0.3
Selenium	µg/L	50	<2
Sodium	mg/L		11.1
Sulphate	mg/L		2
Thallium	µg/L		<1
Turbidity	NTU		0.20
Uranium	µg/L	20	<0.5
Zinc	µg/L		77

New Brunswick Clean Water Results Dunn Avenue (Zone 14)			
Organic Parameters:	Units	Health Advisory Limit	January 17 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		20.0
Bromodichloromethane	µg/L		3.7
Dibromochloromethane	µg/L		< 0.37
Bromoform	µg/L		< 0.34
Total Trihalomethanes	µg/L	100	23.0
Trichloroacetic acid	µg/L		19.7
Dichloroacetic acid	µg/L		14.9
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	34.6

Inorganic Parameters:	Units	Health Advisory Limit	January 17 2022
Alkalinity (as CaCO3)	mg/L		29
Total Hardness (as CaCO3)	mg/L		17
Aluminum	µg/L		10
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	<10
Boron	µg/L	5000	<10
Cadmium	µg/L	7	<0.02
Calcium	mg/L		5.9
Chloride	mg/L		10.9
Chromium	µg/L	50	<1
Copper	µg/L	2000	16
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		5
Lead	µg/L	5	<1
Magnesium	mg/L		0.6
Manganese	µg/L	120	<2
Mercury	µg/L	1	<0.02
Nitrate (as NO3)	mg/L	45	<0.2
pH			7.24
Potassium	mg/L		0.4
Selenium	µg/L	50	<2
Sodium	mg/L		11.2
Sulphate	mg/L		2
Thallium	µg/L		<1
Turbidity	NTU		0.21
Uranium	µg/L	20	<0.5
Zinc	µg/L		75

New Brunswick Clean Water Results Ocean Drive Well (Source 2)			
Organic Parameters:	Units	Health Advisory Limit	January 17 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		< 0.29
Bromodichloromethane	µg/L		< 0.26
Dibromochloromethane	µg/L		< 0.37
Bromoform	µg/L		< 0.34
Total Trihalomethanes	µg/L	100	< 0.37
Trichloroacetic acid	µg/L		< 5.3
Dichloroacetic acid	µg/L		< 2.6
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	< 5.3

Inorganic Parameters:	Units	Health Advisory Limit	January 17 2022
Alkalinity (as CaCO3)	mg/L		90
Total Hardness (as CaCO3)	mg/L		91
Aluminum	µg/L		25
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	189
Boron	µg/L	5000	<10
Cadmium	µg/L	7	<0.02
Calcium	mg/L		26.8
Chloride	mg/L		31.4
Chromium	µg/L	50	<1
Copper	µg/L	2000	<1
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		42
Lead	µg/L	5	<1
Magnesium	mg/L		5.8
Manganese	µg/L	120	<2
Mercury	µg/L	1	<0.02
Nitrate (as NO3)	mg/L	45	1.2
pH			8.06
Potassium	mg/L		0.7
Selenium	µg/L	50	<2
Sodium	mg/L		11.2
Sulphate	mg/L		8
Thallium	µg/L		<1
Turbidity	NTU		0.20
Uranium	µg/L	20	<0.5
Zinc	µg/L		<2

New Brunswick Clean Water Results Seaward Crescent Well (Source 3)			
Organic Parameters:	Units	Health Advisory Limit	January 17 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		< 0.29
Bromodichloromethane	µg/L		< 0.26
Dibromochloromethane	µg/L		< 0.37
Bromoform	µg/L		< 0.34
Total Trihalomethanes	µg/L	100	< 0.37
Trichloroacetic acid	µg/L		< 5.3
Dichloroacetic acid	µg/L		< 2.6
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	< 5.3

Inorganic Parameters:	Units	Health Advisory Limit	January 17 2022
Alkalinity (as CaCO3)	mg/L		96
Total Hardness (as CaCO3)	mg/L		86
Aluminum	µg/L		16
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	258
Boron	µg/L	5000	<10
Cadmium	µg/L	7	<0.02
Calcium	mg/L		27.3
Chloride	mg/L		14.7
Chromium	µg/L	50	<1
Copper	µg/L	2000	<1
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		18
Lead	µg/L	5	<1
Magnesium	mg/L		4.4
Manganese	µg/L	120	<2
Mercury	µg/L	1	<0.02
Nitrate (as NO3)	mg/L	45	1.2
pH			8.08
Potassium	mg/L		0.7
Selenium	µg/L	50	<2
Sodium	mg/L		7.2
Sulphate	mg/L		6
Thallium	µg/L		<1
Turbidity	NTU		0.26
Uranium	µg/L	20	<0.5
Zinc	µg/L		<2

New Brunswick Clean Water Results Aberdeen Street (Zone 29)			
Organic Parameters:	Units	Health Advisory Limit	January 17 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		< 0.29
Bromodichloromethane	µg/L		0.37
Dibromochloromethane	µg/L		0.54
Bromoform	µg/L		< 0.34
Total Trihalomethanes	µg/L	100	0.91
Trichloroacetic acid	µg/L		< 5.3
Dichloroacetic acid	µg/L		< 2.6
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	< 5.3

Inorganic Parameters:	Units	Health Advisory Limit	January 17 2022
Alkalinity (as CaCO3)	mg/L		92
Total Hardness (as CaCO3)	mg/L		90
Aluminum	µg/L		<5
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	187
Boron	µg/L	5000	<10
Cadmium	µg/L	7	<0.02
Calcium	mg/L		26.5
Chloride	mg/L		33.1
Chromium	µg/L	50	<1
Copper	µg/L	2000	<1
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		5
Lead	µg/L	5	<1
Magnesium	mg/L		5.8
Manganese	µg/L	120	<2
Mercury	µg/L	1	<0.02
Nitrate (as NO3)	mg/L	45	1.2
pH			8.06
Potassium	mg/L		0.6
Selenium	µg/L	50	<2
Sodium	mg/L		12.3
Sulphate	mg/L		8
Thallium	µg/L		<1
Turbidity	NTU		0.36
Uranium	µg/L	20	<0.5
Zinc	µg/L		<2

New Brunswick Clean Water Results Eden Street (Zone 28)			
Organic Parameters:	Units	Health Advisory Limit	January 17 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		< 0.29
Bromodichloromethane	µg/L		0.35
Dibromochloromethane	µg/L		0.55
Bromoform	µg/L		< 0.34
Total Trihalomethanes	µg/L	100	0.90
Trichloroacetic acid	µg/L		< 5.3
Dichloroacetic acid	µg/L		< 2.6
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	< 5.3

Inorganic Parameters:	Units	Health Advisory Limit	January 17 2022
Alkalinity (as CaCO3)	mg/L		91
Total Hardness (as CaCO3)	mg/L		89
Aluminum	µg/L		52
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	190
Boron	µg/L	5000	<10
Cadmium	µg/L	7	<0.02
Calcium	mg/L		26.0
Chloride	mg/L		32.9
Chromium	µg/L	50	<1
Copper	µg/L	2000	<1
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		141
Lead	µg/L	5	<1
Magnesium	mg/L		5.9
Manganese	µg/L	120	<2
Mercury	µg/L	1	<0.02
Nitrate (as NO3)	mg/L	45	1.2
pH			8.05
Potassium	mg/L		0.5
Selenium	µg/L	50	<2
Sodium	mg/L		12.6
Sulphate	mg/L		8
Thallium	µg/L		<1
Turbidity	NTU		1.14
Uranium	µg/L	20	<0.5
Zinc	µg/L		<2

New Brunswick Clean Water Results Spruce Lake Raw Water (Source 1)			
Organic Parameters:	Units	Health Advisory Limit	January 17 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		< 0.29
Bromodichloromethane	µg/L		< 0.26
Dibromochloromethane	µg/L		< 0.37
Bromoform	µg/L		< 0.34
Total Trihalomethanes	µg/L	100	< 0.37
Trichloroacetic acid	µg/L		< 5.3
Dichloroacetic acid	µg/L		< 2.6
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	< 5.3

Inorganic Parameters:	Units	Health Advisory Limit	January 17 2022
Alkalinity (as CaCO3)	mg/L		4
Total Hardness (as CaCO3)	mg/L		7
Aluminum	µg/L		61
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	<10
Boron	µg/L	5000	<10
Cadmium	µg/L	7	<0.02
Calcium	mg/L		2
Chloride	mg/L		5.3
Chromium	µg/L	50	<1
Copper	µg/L	2000	<1
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		115
Lead	µg/L	5	<1
Magnesium	mg/L		0.4
Manganese	µg/L	120	22
Mercury	µg/L	1	<0.02
Nitrate (as NO3)	mg/L	45	<0.2
pH			6.23
Potassium	mg/L		0.3
Selenium	µg/L	50	<2
Sodium	mg/L		3
Sulphate	mg/L		<2
Thallium	µg/L		<1
Turbidity	NTU		0.73
Uranium	µg/L	20	<0.5
Zinc	µg/L		<2

New Brunswick Clean Water Results Fundy Linen, Spruce Lake Industrial Park (Zone 6)			
Organic Parameters:	Units	Health Advisory Limit	January 17 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		0.49
Bromodichloromethane	µg/L		0.55
Dibromochloromethane	µg/L		1.5
Bromoform	µg/L		1.2
Total Trihalomethanes	µg/L	100	3.7
Trichloroacetic acid	µg/L		< 5.3
Dichloroacetic acid	µg/L		< 2.6
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	< 5.3

Inorganic Parameters:	Units	Health Advisory Limit	January 17 2022
Alkalinity (as CaCO3)	mg/L		166
Total Hardness (as CaCO3)	mg/L		224
Aluminum	µg/L		<5
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	104
Boron	µg/L	5000	65
Cadmium	µg/L	7	<0.02
Calcium	mg/L		68.4
Chloride	mg/L		73.3
Chromium	µg/L	50	<1
Copper	µg/L	2000	<1
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		<2
Lead	µg/L	5	<1
Magnesium	mg/L		12.8
Manganese	µg/L	120	<2
Mercury	µg/L	1	<0.02
Nitrate (as NO3)	mg/L	45	0.5
pH			7.83
Potassium	mg/L		2.8
Selenium	µg/L	50	<2
Sodium	mg/L		24.7
Sulphate	mg/L		46
Thallium	µg/L		<1
Turbidity	NTU		0.33
Uranium	µg/L	20	3.0
Zinc	µg/L		73

New Brunswick Clean Water Results Ridgewood Lift Station (Zone 3)			
Organic Parameters:	Units	Health Advisory Limit	January 17 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		0.65
Bromodichloromethane	µg/L		1.4
Dibromochloromethane	µg/L		3.3
Bromoform	µg/L		2.8
Total Trihalomethanes	µg/L	100	8.1
Trichloroacetic acid	µg/L		< 5.3
Dichloroacetic acid	µg/L		< 2.6
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	< 5.3

Inorganic Parameters:	Units	Health Advisory Limit	January 17 2022
Alkalinity (as CaCO3)	mg/L		168
Total Hardness (as CaCO3)	mg/L		227
Aluminum	µg/L		<5
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	100
Boron	µg/L	5000	65
Cadmium	µg/L	7	<0.02
Calcium	mg/L		69.7
Chloride	mg/L		76.3
Chromium	µg/L	50	<1
Copper	µg/L	2000	258
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		<2
Lead	µg/L	5	<1
Magnesium	mg/L		12.9
Manganese	µg/L	120	<2
Mercury	µg/L	1	<0.02
Nitrate (as NO3)	mg/L	45	0.3
pH			8.28
Potassium	mg/L		2.8
Selenium	µg/L	50	<2
Sodium	mg/L		24.9
Sulphate	mg/L		46
Thallium	µg/L		<1
Turbidity	NTU		0.17
Uranium	µg/L	20	3.0
Zinc	µg/L		63

New Brunswick Clean Water Results Travelodge Suites (Zone 20)			
Organic Parameters:	Units	Health Advisory Limit	January 17 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		0.57
Bromodichloromethane	µg/L		0.96
Dibromochloromethane	µg/L		2.4
Bromoform	µg/L		1.7
Total Trihalomethanes	µg/L	100	5.6
Trichloroacetic acid	µg/L		< 5.3
Dichloroacetic acid	µg/L		< 2.6
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	< 5.3

Inorganic Parameters:	Units	Health Advisory Limit	January 17 2022
Alkalinity (as CaCO3)	mg/L		167
Total Hardness (as CaCO3)	mg/L		219
Aluminum	µg/L		18
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	101
Boron	µg/L	5000	60
Cadmium	µg/L	7	<0.02
Calcium	mg/L		68.3
Chloride	mg/L		70.9
Chromium	µg/L	50	<1
Copper	µg/L	2000	<1
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		28
Lead	µg/L	5	<1
Magnesium	mg/L		11.8
Manganese	µg/L	120	<2
Mercury	µg/L	1	<0.02
Nitrate (as NO3)	mg/L	45	0.7
pH			7.93
Potassium	mg/L		2.8
Selenium	µg/L	50	<2
Sodium	mg/L		26.8
Sulphate	mg/L		42
Thallium	µg/L		<1
Turbidity	NTU		0.22
Uranium	µg/L	20	3.1
Zinc	µg/L		68

**New Brunswick Clean Water Results
Churchill Heights Tank (Zone 21)**

Organic Parameters:	Units	Health Advisory Limit	January 17 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		0.56
Bromodichloromethane	µg/L		1.1
Dibromochloromethane	µg/L		2.7
Bromoform	µg/L		2.0
Total Trihalomethanes	µg/L	100	6.3
Trichloroacetic acid	µg/L		< 5.3
Dichloroacetic acid	µg/L		< 2.6
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	< 5.3

Inorganic Parameters:	Units	Health Advisory Limit	January 17 2022
Alkalinity (as CaCO3)	mg/L		168
Total Hardness (as CaCO3)	mg/L		224
Aluminum	µg/L		51
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	105
Boron	µg/L	5000	66
Cadmium	µg/L	7	<0.02
Calcium	mg/L		68.5
Chloride	mg/L		72.9
Chromium	µg/L	50	<1
Copper	µg/L	2000	<1
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		88
Lead	µg/L	5	<1
Magnesium	mg/L		12.8
Manganese	µg/L	120	12
Mercury	µg/L	1	<0.02
Nitrate (as NO3)	mg/L	45	0.5
pH			7.94
Potassium	mg/L		2.9
Selenium	µg/L	50	<2
Sodium	mg/L		24.8
Sulphate	mg/L		46
Thallium	µg/L		<1
Turbidity	NTU		0.30
Uranium	µg/L	20	3.0
Zinc	µg/L		71

**New Brunswick Clean Water Results
Southbay Well #1 (Source 5)**

Organic Parameters:	Units	Health Advisory Limit	January 17 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		0.56
Bromodichloromethane	µg/L		< 0.26
Dibromochloromethane	µg/L		< 0.37
Bromoform	µg/L		< 0.34
Total Trihalomethanes	µg/L	100	0.56
Trichloroacetic acid	µg/L		< 5.3
Dichloroacetic acid	µg/L		< 2.6
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	< 5.3

Inorganic Parameters:	Units	Health Advisory Limit	January 17 2022
Alkalinity (as CaCO3)	mg/L		139
Total Hardness (as CaCO3)	mg/L		190
Aluminum	µg/L		<5
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	54
Boron	µg/L	5000	15
Cadmium	µg/L	7	<0.02
Calcium	mg/L		58.5
Chloride	mg/L		87.7
Chromium	µg/L	50	<1
Copper	µg/L	2000	<1
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		49
Lead	µg/L	5	<1
Magnesium	mg/L		10.7
Manganese	µg/L	120	<2
Mercury	µg/L	1	<0.02
Nitrate (as NO3)	mg/L	45	0.9
pH			8.04
Potassium	mg/L		2.0
Selenium	µg/L	50	<2
Sodium	mg/L		23.6
Sulphate	mg/L		34
Thallium	µg/L		<1
Turbidity	NTU		0.77
Uranium	µg/L	20	2.1
Zinc	µg/L		<2

**New Brunswick Clean Water Results
Southbay Well #2 (Source 6)**

Organic Parameters:	Units	Health Advisory Limit	January 17 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		0.73
Bromodichloromethane	µg/L		< 0.26
Dibromochloromethane	µg/L		< 0.37
Bromoform	µg/L		< 0.34
Total Trihalomethanes	µg/L	100	0.73
Trichloroacetic acid	µg/L		< 5.3
Dichloroacetic acid	µg/L		< 2.6
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	< 5.3

Inorganic Parameters:	Units	Health Advisory Limit	January 17 2022
Alkalinity (as CaCO3)	mg/L		134
Total Hardness (as CaCO3)	mg/L		182
Aluminum	µg/L		<5
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	68
Boron	µg/L	5000	20
Cadmium	µg/L	7	<0.02
Calcium	mg/L		55.7
Chloride	mg/L		63.8
Chromium	µg/L	50	<1
Copper	µg/L	2000	<1
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		10
Lead	µg/L	5	<1
Magnesium	mg/L		10.4
Manganese	µg/L	120	<2
Mercury	µg/L	1	<0.02
Nitrate (as NO3)	mg/L	45	0.6
pH			8.13
Potassium	mg/L		2.7
Selenium	µg/L	50	<2
Sodium	mg/L		22.8
Sulphate	mg/L		30
Thallium	µg/L		<1
Turbidity	NTU		0.29
Uranium	µg/L	20	2.1
Zinc	µg/L		<2

**New Brunswick Clean Water Results
Southbay Well #3 (Source 7)**

Organic Parameters:	Units	Health Advisory Limit	January 17 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		< 0.29
Bromodichloromethane	µg/L		< 0.26
Dibromochloromethane	µg/L		< 0.37
Bromoform	µg/L		< 0.34
Total Trihalomethanes	µg/L	100	< 0.37
Trichloroacetic acid	µg/L		< 5.3
Dichloroacetic acid	µg/L		< 2.6
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	< 5.3

Inorganic Parameters:	Units	Health Advisory Limit	January 17 2022
Alkalinity (as CaCO3)	mg/L		202
Total Hardness (as CaCO3)	mg/L		248
Aluminum	µg/L		<5
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	150
Boron	µg/L	5000	114
Cadmium	µg/L	7	<0.02
Calcium	mg/L		71.4
Chloride	mg/L		74.4
Chromium	µg/L	50	<1
Copper	µg/L	2000	<1
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		21
Lead	µg/L	5	<1
Magnesium	mg/L		16.9
Manganese	µg/L	120	14
Mercury	µg/L	1	<0.02
Nitrate (as NO3)	mg/L	45	<0.2
pH			8.07
Potassium	mg/L		3.5
Selenium	µg/L	50	<2
Sodium	mg/L		27.9
Sulphate	mg/L		62
Thallium	µg/L		<1
Turbidity	NTU		0.18
Uranium	µg/L	20	4.0
Zinc	µg/L		<2