



## ADDENDUM

PROJECT TITLE: SJFPL – LBR Ice Rink Defogger Installation	ADD. NO: 1
TENDER NO: 2022-085301T	DATE: May 10 <sup>th</sup> , 2022
PAGE 1 of 2 (Including Confirmation Sheet)	

Make the following modifications to the above project. Include in the amount of the Tender, any additions to or deductions from the cost of the work by reason of these instructions.

**Sign and attach this Addendum to the Tender documents and submit with your Tender. Failure to do so may result in the rejection of your Tender.**

### **Please find below questions and answers.**

Q1. We require structural(stands) and electrical drawing package.

**A1. Additional 3 drawings have been sent and posted on the City's website.**

Q2. In the event that dasher, glass and netting needs to be removed, is this the responsibility of the contractor or owner?

**A2. This will be the responsibility of City staff, if required.**

Q3. R404A was specified. As of 2019 an essential use permit is required. Has this been considered? Is there any approved alternates?

**A3. Unfortunately, this unit only ships with R404A. Alternates will be considered, subject to consultant approval.**

Q4. Is there a tentative project completion date, if so, can it be specified?

**A4. There is no completion date on this project.**

### **SIGN AND RETURN THIS ADDENDUM WITH YOUR PROPOSAL**

BY: Monic MacVicar  
Monic MacVicar, CCLP, CPPB  
Procurement Specialist, Supply Chain Management

\_\_\_\_\_  
Contractor's Signature



## ADDENDUM

PROJECT TITLE: SJFPL – LBR Ice Rink Defogger Installation	ADD. NO: 1
TENDER NO: 2022-085301T	DATE: May 10 <sup>th</sup> , 2022
PAGE 2 of 2 (Including Confirmation Sheet)	

## CONFIRMATION - RECEIPT OF ADDENDUM

**Upon receipt of this document, fax this page to  
(506) 658-4742 to confirm receipt of this addendum.**

CONTRACTOR'S NAME: \_\_\_\_\_

ADDRESS: \_\_\_\_\_  
\_\_\_\_\_

PHONE: \_\_\_\_\_ FAX: \_\_\_\_\_

RECEIVER NAME (PRINT) \_\_\_\_\_

RECEIVER SIGNATURE: \_\_\_\_\_