



ADDENDUM

PROJECT TITLE: CANADA GAMES AQUATIC CENTER (CGAC) – Solar Photovoltaic (PV)	ADD. NO: 1
TENDER NO: 2022-082301T	DATE: June 21 st , 2022
PAGE 1 of 2 (Including Confirmation Sheet)	

Make the following modifications to the above project. Include in the amount of the Tender, any additions to or deductions from the cost of the work by reason of these instructions.

Sign and attach this Addendum to the Tender documents and submit with your Tender. Failure to do so may result in the rejection of your Tender.

Please find below questions and attached addendum responses.

- Q1. Could you please offer clarification response on the following two items:
- a) Rapid Shut Down - The Fire Raptor is not capable of what they are stating is needed. They max out at 80 VDC as an input, so putting (2) of the 545-Watt modules would smoke it. Might be OK with (1) per panel, we're checking now, but it should be made clear that (1) for every (2) panels will not work.
 - b) Mounting and Racking – Its stated that the mounting system shall secure the panels with machine screws or bolts, but the image shows top clamping, is top clamping acceptable?
- Q2. Drawing E1 Specific Note # 11 indicates "Provide Data Connection" – There is no mention of data cabling on any details nor shown on any of the drawings. Is this required? If yes, please provide information on cable type, and where cable is to be run.

Please find attached the responses to the questions above.

SIGN AND RETURN THIS ADDENDUM WITH YOUR PROPOSAL

BY: Monic MacVicar
 Monic MacVicar, CCLP, CPPB
 Procurement Specialist, Supply Chain Management

 Contractor's Signature



ADDENDUM

PROJECT TITLE: CANADA GAMES AQUATIC CENTER (CGAC) – Solar Photovoltaic (PV)	ADD. NO: 1
TENDER NO: 2022-082301T	DATE: June 21 st , 2022
PAGE 2 of 2 (Including Confirmation Sheet)	

CONFIRMATION - RECEIPT OF ADDENDUM

**Upon receipt of this document, fax this page to
(506) 658-4742 to confirm receipt of this addendum.**

CONTRACTOR'S NAME: _____

ADDRESS: _____

PHONE: _____ FAX: _____

RECEIVER NAME (PRINT) _____

RECEIVER SIGNATURE: _____



Addendum

77 Vaughan Harvey Boulevard, Suite 200
Moncton, New Brunswick E1C 0K2
Phone (506) 857-8880 Fax (506) 859-8393
www.mcw.com

Date: 2022-06-21

Project Name: Solar PV Canada Games Aquatic Center
Client: City of Saint John
To: City of Saint John
Attention: Monic MacVicar
Email Address: monic.macvicar@saintjohn.ca
Distribution: [Sigourney Stott](mailto:Sstott@mcw.com)
[Samir Yammine](mailto:Samir.Yammine@mcw.com)

Project #: 12-19-082 Pkg F1
ADD #: 01
Page #: 1 of 1
From: Ryan Rix, E.I.T.

Sstott@mcw.com
Samir.yammine@saintjohn.ca

In accordance with the drawings and specifications, provide in the tender all costs required to complete the work including items as listed below.

Title:	MCW Electrical Addendum #01
Reason for Change:	Contractor Questions during Tender

Electrical Drawings:

Drawing #	Revisions
E1	<ul style="list-style-type: none">.1 Clarification: Data Drop for inverter to be supplied by the City of Saint John. Contractor is responsible for data cabling from the provided data drop to the inverter..2 Clarification: Panel Mounting as per detail 4/E1, mounting to existing frame as per structural section C/S1..3 Rapid shutdown device will be connected to only 1 panel instead of 2. Update quantity of rapid shutdown devices to 16 for new wiring method.
E2	<ul style="list-style-type: none">.4 Delete paragraph section 13.2 from the specifications.

End of Addendum #01