



ADDENDUM

PROJECT TITLE: PUBLIC SPACE AT MARKET SLIP & HARBOUR PASSAGE EXTENSION	ADD. NO: 4
TENDER NO: 2022-081201T	DATE: July 15 th , 2022
PAGE 1 of 2 (Including Confirmation Sheet)	

Make the following modifications to the above project. Include in the amount of the Tender, any additions to or deductions from the cost of the work by reason of these instructions.

Sign and attach this Addendum to the Tender documents and submit with your Tender. Failure to do so may result in the rejection of your Tender.

Please find attached Addendum #3.

The date for receiving tenders is extended to: Tuesday, July 19th, 2022 at 2:30:00PM Atlantic Time.

Please note that in light of the current Covid-19 pandemic, there will be no public opening. Tenders will be opened by the Tender Opening Committee, in the second-floor boardroom, 175 Rothesay Avenue, Municipal Operations Complex, immediately following the tender closing time. **Registered bidders may attend remotely via Teams invitation.**

Missing Drawing from Addendum #3.

I noticed on addendum (3 3) on line #2 the drawing ASK10 was referenced. Was it supposed to be attached to this addendum?

The following are additional questions that were not answered in Addendum #3.

- Q1. Please specify Asphalt Type for:
Item E1 Upper Course **Answer: Superpave 4.75 mm**
Item E2 Lower Course **Answer: Superpave 9.5 mm**
- Q2. Will Tack Coat be required between Asphalt Lifts?
Answer: Tack coat not specified at this time. If tack coat deemed to be required after contract award then it will be paid for under Contingency item.
- Q3. Will Liquid AC Adjustment be applicable to this contract?
Answer: Yes, in accordance with 27.6.02 Basis of Payment.

SIGN AND RETURN THIS ADDENDUM WITH YOUR PROPOSAL

BY: Monic MacVicar
Monic MacVicar, CCLP, CPPB
Procurement Specialist, Supply Chain Management

Contractor's Signature



ADDENDUM

PROJECT TITLE: PUBLIC SPACE AT MARKET SLIP & HARBOUR PASSAGE EXTENSION	ADD. NO: 4
TENDER NO: 2022-081201T	DATE: July 15 th , 2022
PAGE 2 of 2 (Including Confirmation Sheet)	

CONFIRMATION - RECEIPT OF ADDENDUM

**Upon receipt of this document, fax this page to
(506) 658-4742 to confirm receipt of this addendum.**

CONTRACTOR'S NAME: _____

ADDRESS: _____

PHONE: _____ FAX: _____

RECEIVER NAME (PRINT) _____

RECEIVER SIGNATURE: _____

