



## ADDENDUM

PROJECT TITLE: Sprinkler System Inspection, Testing, And Maintenance Services	ADD. NO: 2
RFP NO: 2022-085401P	DATE: July 5 <sup>th</sup> , 2022
PAGE 1 of 2 (Including Confirmation Sheet)	

Make the following modifications to the above project. Include in the amount of the Proposal, any additions to or deductions from the cost of the work by reason of these instructions.

**Sign and attach this Addendum to the Proposal documents and submit with your Proposal. Failure to do so may result in the rejection of your Proposal.**

**Please find below a list of questions and answers.**

Q1. Question Q6 from Addendum #1 refers to the requirements of performing a full flood trip testing of dry sprinkler systems every 3 years, and also the requirements for performing an internal pipe investigation every 5 years as per NFPA 25 requirements. Being that some of the buildings would require a scissor lift be rented to perform this work, and some would not, it will be difficult to price these as included items in the inspection amount. Also to include for replacing pressure gauges every 5 years, which we don't have an exact count on, wouldn't this work make more sense to be quoted during the duration of the contract when each item is due in each different building?

***A1. Scissor lift as well as pressure gauge replacement pricing to be quoted at time of inspection/ replacement.***

**SIGN AND RETURN THIS ADDENDUM WITH YOUR PROPOSAL**

*Monic MacVicar*

BY: \_\_\_\_\_  
Monic MacVicar, CCLP, CPPB  
Procurement Specialist, Supply Chain Management

\_\_\_\_\_  
Contractor's Signature



## ADDENDUM

PROJECT TITLE: Sprinkler System Inspection, Testing, And Maintenance Services	ADD. NO: 2
RFP NO: 2022-085401P	DATE: July 5 <sup>th</sup> , 2022
PAGE 2 of 2 (Including Confirmation Sheet)	

## CONFIRMATION - RECEIPT OF ADDENDUM

**Upon receipt of this document, fax this page to (506) 658-4742 to confirm receipt of this addendum.**

CONSULTANT'S NAME: \_\_\_\_\_

ADDRESS: \_\_\_\_\_

\_\_\_\_\_

PHONE: \_\_\_\_\_ FAX: \_\_\_\_\_

RECEIVER NAME (PRINT) \_\_\_\_\_

RECEIVER SIGNATURE: \_\_\_\_\_