

TRANSMITTAL SHEET

TO: All Bidders

DATE: July 21, 2022

TOTAL NUMBER OF PAGES (INCLUDING COVER PAGE): 3

FROM: Gerry Mattsson, P. Eng. TEL. #: (506) 649-7998
Utilities & Infrastructure Services

IF YOU DID NOT RECEIVE ALL PAGES, OR FURTHER INFORMATION IS REQUIRED,
PLEASE CONTACT THE SENDER

MESSAGE:

TENDER NO: 2022-12

Woodlawn Park Lift Station

Please find attached a copy of **Addendum #2** for the above tender.

As of March 2021, please be advised that an ***Acknowledgement Form*** (historically sent as part of the City's addendum packages) confirming receipt of an Addendum is **no longer** included in the addendum package.

However, in accordance with Section 2.5.03 of the City's General Specifications, it remains a requirement that **each Addendum** will contain a signature page(s) which each Tenderer is **required to sign and include with its Tender submission.**



UTILITIES & INFRASTRUCTURE SERVICES
Engineering Services
175 Rothesay Avenue
Saint John, NB, E2J 2B4

ADDENDUM

PROJECT TITLE:

Woodlawn Park Lift Station

ADDENDUM NO: 2

DATE: July 21, 2022

PAGE: 1 **OF** 2

TENDER NO: 2022-12

MAKE THE FOLLOWING MODIFICATIONS TO THE ABOVE PROJECT. INCLUDE IN THE AMOUNT OF THE TENDER ANY ADDITIONS TO OR DEDUCTIONS FROM THE COST OF THE WORK BY REASON OF THESE INSTRUCTIONS. THE DATE FOR RECEIVING TENDERS REMAINS AT: **2:30PM, WEDNESDAY, JULY 27, 2022.**

ADJUSTMENTS IN GENERAL

Item 1: Response to Queries:

Q1. Do you know what pitch you would like on the roof?

A1. The roof pitch is 7/12.

Q2. What is the desired roof overhang distance from the exterior edge of the wall stud?

A2. Dwg S3 indicates an overhang distance of 350mm. This measurement is from the outer face of the external Pre-finished Wood Siding to the inner face of the Prefinished Aluminum Fascia.

Q3. Re: Section 10 10 20 INSTRUMENTATION Part 2.5 WET WELL LEVEL CONTROLLER

The drawing illustrates an Ultrasonic unit. However, the city operations have been having trouble with these units and are now using submersible pressure level transmitters. Will this be an acceptable alternative?

A3. No, a submersible pressure transmitter is not an acceptable alternative.

Note: Signed copy of the addendum **must** be enclosed in the tender documents, according to the Instructions to Tenderers and Tendering Procedures in Division 2 of the Contract Specifications.

BY:


Susan Silver
for

CHIEF CITY ENGINEER

CONTRACTOR'S SIGNATURE

TO BE SIGNED AND ATTACHED TO TENDER DOCUMENTS