

**New Brunswick Clean Water Results
Spruce Lake Raw Water (Source 1)**

2524 Ocean Westway

Organic Parameters:	Units	Health Advisory	July 11 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		< 0.29
Bromodichloromethane	µg/L		< 0.26
Dibromochloromethane	µg/L		< 0.37
Bromoform	µg/L		< 0.34
Total Trihalomethanes	µg/L	100	< 0.37
Trichloroacetic acid	µg/L		< 5.3
Dichloroacetic acid	µg/L		< 2.6
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	< 5.3

Inorganic Parameters:	Units	Health Advisory	July 11 2022
Alkalinity (as CaCO3)	mg/L		4
Total Hardness (as CaCO3)	mg/L		8
Aluminum	µg/L	2900	26
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	<10
Boron	µg/L	5000	<10
Cadmium	µg/L	7	<0.02
Calcium	mg/L		2.4
Chloride	mg/L		7.2
Chromium	µg/L	50	<1
Copper	µg/L	2000	<1
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		37
Lead	µg/L	5	<1
Magnesium	mg/L		0.5
Manganese	µg/L	120	18
Mercury	µg/L	1	<0.02
Nitrate (as NO3)	mg/L	45	<0.2
pH			6.34
Potassium	mg/L		0.2
Selenium	µg/L	50	<2
Sodium	mg/L		3.9
Sulphate	mg/L		<2
Thallium	µg/L		<1
Turbidity	NTU		0.68
Uranium	µg/L	20	<0.5
Zinc	µg/L		<2

New Brunswick Clean Water Results Ocean Drive Well Raw Water (Source 2)			
103 Ocean Drive			
Organic Parameters:	Units	Health Advisory	July 11 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		< 0.29
Bromodichloromethane	µg/L		< 0.26
Dibromochloromethane	µg/L		< 0.37
Bromoform	µg/L		< 0.34
Total Trihalomethanes	µg/L	100	< 0.37
Trichloroacetic acid	µg/L		< 5.3
Dichloroacetic acid	µg/L		< 2.6
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	< 5.3

Inorganic Parameters:	Units	Health Advisory	July 11 2022
Alkalinity (as CaCO3)	mg/L		90
Total Hardness (as CaCO3)	mg/L		117
Aluminum	µg/L	2900	<5
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	167
Boron	µg/L	5000	<10
Cadmium	µg/L	7	<0.02
Calcium	mg/L		35.8
Chloride	mg/L		28.2
Chromium	µg/L	50	<1
Copper	µg/L	2000	<1
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		<2
Lead	µg/L	5	<1
Magnesium	mg/L		6.6
Manganese	µg/L	120	<2
Mercury	µg/L	1	<0.02
Nitrate (as NO3)	mg/L	45	1.2
pH			8.02
Potassium	mg/L		1.1
Selenium	µg/L	50	<2
Sodium	mg/L		13.5
Sulphate	mg/L		7
Thallium	µg/L		<1
Turbidity	NTU		0.18
Uranium	µg/L	20	<0.5
Zinc	µg/L		<2

**New Brunswick Clean Water Results
Seaward Crescent Well Raw Water (Source 3)**

14 Seaward Crescent

Organic Parameters:	Units	Health Advisory	July 11 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		< 0.29
Bromodichloromethane	µg/L		< 0.26
Dibromochloromethane	µg/L		< 0.37
Bromoform	µg/L		< 0.34
Total Trihalomethanes	µg/L	100	< 0.37
Trichloroacetic acid	µg/L		< 5.3
Dichloroacetic acid	µg/L		< 2.6
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	< 5.3

Inorganic Parameters:	Units	Health Advisory	July 11 2022
Alkalinity (as CaCO3)	mg/L		94
Total Hardness (as CaCO3)	mg/L		110
Aluminum	µg/L	2900	<5
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	233
Boron	µg/L	5000	<10
Cadmium	µg/L	7	<0.02
Calcium	mg/L		36.4
Chloride	mg/L		12.9
Chromium	µg/L	50	<1
Copper	µg/L	2000	<1
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		<2
Lead	µg/L	5	<1
Magnesium	mg/L		4.7
Manganese	µg/L	120	<2
Mercury	µg/L	1	<0.02
Nitrate (as NO3)	mg/L	45	1.1
pH			7.98
Potassium	mg/L		0.6
Selenium	µg/L	50	<2
Sodium	mg/L		8.1
Sulphate	mg/L		6
Thallium	µg/L		<1
Turbidity	NTU		0.29
Uranium	µg/L	20	<0.5
Zinc	µg/L		<2

**New Brunswick Clean Water Results
Latimer Lake Raw Water (Source 4)**

1200 Pipeline Road

Organic Parameters:	Units	Health Advisory	July 11 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		< 0.29
Bromodichloromethane	µg/L		< 0.26
Dibromochloromethane	µg/L		< 0.37
Bromoform	µg/L		< 0.34
Total Trihalomethanes	µg/L	100	< 0.37
Trichloroacetic acid	µg/L		< 5.3
Dichloroacetic acid	µg/L		< 2.6
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	< 5.3

Inorganic Parameters:	Units	Health Advisory	July 11 2022
Alkalinity (as CaCO3)	mg/L		8
Total Hardness (as CaCO3)	mg/L		12
Aluminum	µg/L	2900	<5
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	<10
Boron	µg/L	5000	< 10
Cadmium	µg/L	7	<0.02
Calcium	mg/L		3.9
Chloride	mg/L		6.9
Chromium	µg/L	50	<1
Copper	µg/L	2000	<1
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		13
Lead	µg/L	5	<1
Magnesium	mg/L		0.6
Manganese	µg/L	120	7
Mercury	µg/L	1	<0.02
Nitrate (as NO3)	mg/L	45	<0.2
pH			6.80
Potassium	mg/L		0.3
Selenium	µg/L	50	<2
Sodium	mg/L		4.1
Sulphate	mg/L		2
Thallium	µg/L		<1
Turbidity	NTU		0.53
Uranium	µg/L	20	<0.5
Zinc	µg/L		<2

**New Brunswick Clean Water Results
Southbay Well #1 Raw Water (Source 5)**

66 Gaelic Drive

Organic Parameters:	Units	Health Advisory	July 11 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		0.38
Bromodichloromethane	µg/L		< 0.26
Dibromochloromethane	µg/L		< 0.37
Bromoform	µg/L		< 0.34
Total Trihalomethanes	µg/L	100	0.38
Trichloroacetic acid	µg/L		< 5.3
Dichloroacetic acid	µg/L		< 2.6
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	< 5.3

Inorganic Parameters:	Units	Health Advisory	July 11 2022
Alkalinity (as CaCO3)	mg/L		141
Total Hardness (as CaCO3)	mg/L		227
Aluminum	µg/L	2900	<5
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	54
Boron	µg/L	5000	15
Cadmium	µg/L	7	<0.02
Calcium	mg/L		70.6
Chloride	mg/L		85.4
Chromium	µg/L	50	<1
Copper	µg/L	2000	<1
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		<2
Lead	µg/L	5	<1
Magnesium	mg/L		12.4
Manganese	µg/L	120	2
Mercury	µg/L	1	<0.02
Nitrate (as NO3)	mg/L	45	1.1
pH			8.23
Potassium	mg/L		3.2
Selenium	µg/L	50	<2
Sodium	mg/L		27.4
Sulphate	mg/L		31
Thallium	µg/L		<1
Turbidity	NTU		0.18
Uranium	µg/L	20	2.1
Zinc	µg/L		<2

**New Brunswick Clean Water Results
Southbay Well #2 Raw Water (Source 6)**

66 Gaelic Drive

Organic Parameters:	Units	Health Advisory	July 11 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		0.67
Bromodichloromethane	µg/L		< 0.26
Dibromochloromethane	µg/L		< 0.37
Bromoform	µg/L		< 0.34
Total Trihalomethanes	µg/L	100	0.67
Trichloroacetic acid	µg/L		< 5.3
Dichloroacetic acid	µg/L		< 2.6
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	< 5.3

Inorganic Parameters:	Units	Health Advisory	July 11 2022
Alkalinity (as CaCO3)	mg/L		130
Total Hardness (as CaCO3)	mg/L		237
Aluminum	µg/L	2900	<5
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	57
Boron	µg/L	5000	15
Cadmium	µg/L	7	<0.02
Calcium	mg/L		76.9
Chloride	mg/L		71.0
Chromium	µg/L	50	<1
Copper	µg/L	2000	<1
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		<2
Lead	µg/L	5	<1
Magnesium	mg/L		10.8
Manganese	µg/L	120	<2
Mercury	µg/L	1	<0.02
Nitrate (as NO3)	mg/L	45	0.9
pH			8.13
Potassium	mg/L		3.0
Selenium	µg/L	50	<2
Sodium	mg/L		23.8
Sulphate	mg/L		29
Thallium	µg/L		<1
Turbidity	NTU		0.21
Uranium	µg/L	20	1.8
Zinc	µg/L		<2

**New Brunswick Clean Water Results
Southbay Well #3 Raw Water (Source 7)**

66 Gaelic Drive

Organic Parameters:	Units	Health Advisory	July 11 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		< 0.29
Bromodichloromethane	µg/L		< 0.26
Dibromochloromethane	µg/L		< 0.37
Bromoform	µg/L		< 0.34
Total Trihalomethanes	µg/L	100	< 0.37
Trichloroacetic acid	µg/L		< 5.3
Dichloroacetic acid	µg/L		< 2.6
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	< 5.3

Inorganic Parameters:	Units	Health Advisory	July 11 2022
Alkalinity (as CaCO3)	mg/L		200
Total Hardness (as CaCO3)	mg/L		299
Aluminum	µg/L	2900	<5
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	121
Boron	µg/L	5000	104
Cadmium	µg/L	7	<0.02
Calcium	mg/L		90.4
Chloride	mg/L		68.1
Chromium	µg/L	50	<1
Copper	µg/L	2000	<1
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		<2
Lead	µg/L	5	<1
Magnesium	mg/L		17.7
Manganese	µg/L	120	13
Mercury	µg/L	1	<0.02
Nitrate (as NO3)	mg/L	45	0.8
pH			8.03
Potassium	mg/L		4.0
Selenium	µg/L	50	<2
Sodium	mg/L		30.1
Sulphate	mg/L		62
Thallium	µg/L		<1
Turbidity	NTU		0.20
Uranium	µg/L	20	3.4
Zinc	µg/L		<2

**New Brunswick Clean Water Results
Carleton Community Centre (Zone 2)**

89 Market Place

Organic Parameters:	Units	Health Advisory	July 11 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		55.0
Bromodichloromethane	µg/L		6.0
Dibromochloromethane	µg/L		< 0.37
Bromoform	µg/L		< 0.34
Total Trihalomethanes	µg/L	100	61.0
Trichloroacetic acid	µg/L		22.0
Dichloroacetic acid	µg/L		19.9
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	41.8

Inorganic Parameters:	Units	Health Advisory	July 11 2022
Alkalinity (as CaCO3)	mg/L		25
Total Hardness (as CaCO3)	mg/L		30
Aluminum	µg/L	2900	<5
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	<10
Boron	µg/L	5000	<10
Cadmium	µg/L	7	<0.02
Calcium	mg/L		11.2
Chloride	mg/L		10.4
Chromium	µg/L	50	<1
Copper	µg/L	2000	<1
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		<2
Lead	µg/L	5	<1
Magnesium	mg/L		0.6
Manganese	µg/L	120	<2
Mercury	µg/L	1	<0.02
Nitrate (as NO3)	mg/L	45	<0.2
pH			7.53
Potassium	mg/L		0.3
Selenium	µg/L	50	<2
Sodium	mg/L		11.3
Sulphate	mg/L		2
Thallium	µg/L		<1
Turbidity	NTU		0.34
Uranium	µg/L	20	<0.5
Zinc	µg/L		40

**New Brunswick Clean Water Results
Ridgewood Lift Station (Zone 3)**

410 Bay Street

Organic Parameters:	Units	Health Advisory	July 11 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		0.71
Bromodichloromethane	µg/L		1.2
Dibromochloromethane	µg/L		2.9
Bromoform	µg/L		2.4
Total Trihalomethanes	µg/L	100	7.1
Trichloroacetic acid	µg/L		< 5.3
Dichloroacetic acid	µg/L		< 2.6
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	< 5.3

Inorganic Parameters:	Units	Health Advisory	July 11 2022
Alkalinity (as CaCO3)	mg/L		154
Total Hardness (as CaCO3)	mg/L		237
Aluminum	µg/L	2900	<5
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	76
Boron	µg/L	5000	38
Cadmium	µg/L	7	<0.02
Calcium	mg/L		74.1
Chloride	mg/L		77.2
Chromium	µg/L	50	<1
Copper	µg/L	2000	<1
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		<2
Lead	µg/L	5	<1
Magnesium	mg/L		12.5
Manganese	µg/L	120	<2
Mercury	µg/L	1	<0.02
Nitrate (as NO3)	mg/L	45	0.8
pH			8.08
Potassium	mg/L		3.0
Selenium	µg/L	50	<2
Sodium	mg/L		26.7
Sulphate	mg/L		43
Thallium	µg/L		<1
Turbidity	NTU		0.23
Uranium	µg/L	20	2.3
Zinc	µg/L		83

**New Brunswick Clean Water Results
Operations Complex (Zone 4)**

175 Rothesay Avenue

Organic Parameters:	Units	Health Advisory	July 11 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		33.0
Bromodichloromethane	µg/L		3.8
Dibromochloromethane	µg/L		< 0.37
Bromoform	µg/L		< 0.34
Total Trihalomethanes	µg/L	100	37.0
Trichloroacetic acid	µg/L		18.4
Dichloroacetic acid	µg/L		16.1
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	34.4

Inorganic Parameters:	Units	Health Advisory	July 11 2022
Alkalinity (as CaCO3)	mg/L		26
Total Hardness (as CaCO3)	mg/L		20
Aluminum	µg/L	2900	<5
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	<10
Boron	µg/L	5000	<10
Cadmium	µg/L	7	<0.02
Calcium	mg/L		6.9
Chloride	mg/L		9.6
Chromium	µg/L	50	<1
Copper	µg/L	2000	15
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		<2
Lead	µg/L	5	<1
Magnesium	mg/L		0.7
Manganese	µg/L	120	<2
Mercury	µg/L	1	<0.02
Nitrate (as NO3)	mg/L	45	<0.2
pH			7.51
Potassium	mg/L		0.4
Selenium	µg/L	50	<2
Sodium	mg/L		11.1
Sulphate	mg/L		2
Thallium	µg/L		<1
Turbidity	NTU		0.30
Uranium	µg/L	20	<0.5
Zinc	µg/L		57

**New Brunswick Clean Water Results
Fundy Linen (Zone 6)**

320 King William Road

Organic Parameters:	Units	Health Advisory	July 11 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		0.55
Bromodichloromethane	µg/L		0.42
Dibromochloromethane	µg/L		1.1
Bromoform	µg/L		0.84
Total Trihalomethanes	µg/L	100	2.9
Trichloroacetic acid	µg/L		< 5.3
Dichloroacetic acid	µg/L		< 2.6
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	< 5.3

Inorganic Parameters:	Units	Health Advisory	July 11 2022
Alkalinity (as CaCO3)	mg/L		155
Total Hardness (as CaCO3)	mg/L		242
Aluminum	µg/L	2900	<5
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	74
Boron	µg/L	5000	42
Cadmium	µg/L	7	<0.02
Calcium	mg/L		75.9
Chloride	mg/L		78.9
Chromium	µg/L	50	<1
Copper	µg/L	2000	<1
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		4
Lead	µg/L	5	<1
Magnesium	mg/L		12.8
Manganese	µg/L	120	<2
Mercury	µg/L	1	<0.02
Nitrate (as NO3)	mg/L	45	0.8
pH			8.24
Potassium	mg/L		2.9
Selenium	µg/L	50	<2
Sodium	mg/L		27.6
Sulphate	mg/L		43
Thallium	µg/L		<1
Turbidity	NTU		0.24
Uranium	µg/L	20	2.4
Zinc	µg/L		58

**New Brunswick Clean Water Results
Ryerson Metals (Zone 7)**

2 Whitebone Way

Organic Parameters:	Units	Health Advisory	July 11 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		65.0
Bromodichloromethane	µg/L		5.9
Dibromochloromethane	µg/L		< 0.37
Bromoform	µg/L		< 0.34
Total Trihalomethanes	µg/L	100	71.0
Trichloroacetic acid	µg/L		27.5
Dichloroacetic acid	µg/L		24.2
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	51.7

Inorganic Parameters:	Units	Health Advisory	July 11 2022
Alkalinity (as CaCO3)	mg/L		27
Total Hardness (as CaCO3)	mg/L		20
Aluminum	µg/L	2900	<5
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	<10
Boron	µg/L	5000	<10
Cadmium	µg/L	7	<0.02
Calcium	mg/L		6.9
Chloride	mg/L		10.7
Chromium	µg/L	50	<1
Copper	µg/L	2000	<1
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		<2
Lead	µg/L	5	<1
Magnesium	mg/L		0.7
Manganese	µg/L	120	<2
Mercury	µg/L	1	<0.02
Nitrate (as NO3)	mg/L	45	<0.2
pH			7.55
Potassium	mg/L		0.3
Selenium	µg/L	50	<2
Sodium	mg/L		11.7
Sulphate	mg/L		2
Thallium	µg/L		<1
Turbidity	NTU		0.27
Uranium	µg/L	20	<0.5
Zinc	µg/L		45

**New Brunswick Clean Water Results
Bridge Road Pump Station (Zone 8)**

435 Riverview Drive

Organic Parameters:	Units	Health Advisory	July 11 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		44.0
Bromodichloromethane	µg/L		4.8
Dibromochloromethane	µg/L		< 0.37
Bromoform	µg/L		< 0.34
Total Trihalomethanes	µg/L	100	49.0
Trichloroacetic acid	µg/L		23.9
Dichloroacetic acid	µg/L		19.0
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	43

Inorganic Parameters:	Units	Health Advisory	July 11 2022
Alkalinity (as CaCO3)	mg/L		26
Total Hardness (as CaCO3)	mg/L		20
Aluminum	µg/L	2900	<5
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	<10
Boron	µg/L	5000	<10
Cadmium	µg/L	7	<0.02
Calcium	mg/L		7.1
Chloride	mg/L		10.7
Chromium	µg/L	50	<1
Copper	µg/L	2000	<1
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		<2
Lead	µg/L	5	<1
Magnesium	mg/L		0.6
Manganese	µg/L	120	<2
Mercury	µg/L	1	<0.02
Nitrate (as NO3)	mg/L	45	<0.2
pH			7.58
Potassium	mg/L		0.4
Selenium	µg/L	50	<2
Sodium	mg/L		11.6
Sulphate	mg/L		2
Thallium	µg/L		<1
Turbidity	NTU		0.21
Uranium	µg/L	20	<0.5
Zinc	µg/L		47

New Brunswick Clean Water Results Doiron Sports (Zone 9)			
31 Greenhead Road			
Organic Parameters:	Units	Health Advisory	July 11 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		53.0
Bromodichloromethane	µg/L		6.0
Dibromochloromethane	µg/L		< 0.37
Bromoform	µg/L		< 0.34
Total Trihalomethanes	µg/L	100	59.0
Trichloroacetic acid	µg/L		20.3
Dichloroacetic acid	µg/L		15.5
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	35.9

Inorganic Parameters:	Units	Health Advisory	July 11 2022
Alkalinity (as CaCO3)	mg/L		26
Total Hardness (as CaCO3)	mg/L		31
Aluminum	µg/L	2900	8
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	<10
Boron	µg/L	5000	<10
Cadmium	µg/L	7	<0.02
Calcium	mg/L		11.3
Chloride	mg/L		10.4
Chromium	µg/L	50	<1
Copper	µg/L	2000	<1
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		38
Lead	µg/L	5	<1
Magnesium	mg/L		0.6
Manganese	µg/L	120	26
Mercury	µg/L	1	<0.02
Nitrate (as NO3)	mg/L	45	<0.2
pH			7.49
Potassium	mg/L		0.5
Selenium	µg/L	50	<2
Sodium	mg/L		11.4
Sulphate	mg/L		2
Thallium	µg/L		<1
Turbidity	NTU		0.77
Uranium	µg/L	20	<0.5
Zinc	µg/L		52

**New Brunswick Clean Water Results
Kennebecasis Drive PRV (Zone 10)**

1240 Kennebecasis Drive

Organic Parameters:	Units	Health Advisory	July 11 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		58.0
Bromodichloromethane	µg/L		6.2
Dibromochloromethane	µg/L		< 0.37
Bromoform	µg/L		< 0.34
Total Trihalomethanes	µg/L	100	65.0
Trichloroacetic acid	µg/L		31.4
Dichloroacetic acid	µg/L		20.2
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	51.5

Inorganic Parameters:	Units	Health Advisory	July 11 2022
Alkalinity (as CaCO3)	mg/L		26
Total Hardness (as CaCO3)	mg/L		20
Aluminum	µg/L	2900	<5
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	<10
Boron	µg/L	5000	<10
Cadmium	µg/L	7	<0.02
Calcium	mg/L		7.0
Chloride	mg/L		10.7
Chromium	µg/L	50	<1
Copper	µg/L	2000	<1
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		<2
Lead	µg/L	5	<1
Magnesium	mg/L		0.6
Manganese	µg/L	120	<2
Mercury	µg/L	1	<0.02
Nitrate (as NO3)	mg/L	45	<0.2
pH			7.20
Potassium	mg/L		0.5
Selenium	µg/L	50	<2
Sodium	mg/L		11.3
Sulphate	mg/L		2
Thallium	µg/L		<1
Turbidity	NTU		0.17
Uranium	µg/L	20	<0.5
Zinc	µg/L		46

**New Brunswick Clean Water Results
Champlain Heights Pump Station (Zone 13)**

784 Loch Lomond Road

Organic Parameters:	Units	Health Advisory	July 11 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		35.0
Bromodichloromethane	µg/L		4.5
Dibromochloromethane	µg/L		< 0.37
Bromoform	µg/L		< 0.34
Total Trihalomethanes	µg/L	100	40.0
Trichloroacetic acid	µg/L		16.7
Dichloroacetic acid	µg/L		13.9
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	30.5

Inorganic Parameters:	Units	Health Advisory	July 11 2022
Alkalinity (as CaCO3)	mg/L		26
Total Hardness (as CaCO3)	mg/L		18
Aluminum	µg/L	2900	<5
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	<10
Boron	µg/L	5000	<10
Cadmium	µg/L	7	<0.02
Calcium	mg/L		6.2
Chloride	mg/L		10.1
Chromium	µg/L	50	<1
Copper	µg/L	2000	<1
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		<2
Lead	µg/L	5	<1
Magnesium	mg/L		0.6
Manganese	µg/L	120	<2
Mercury	µg/L	1	<0.02
Nitrate (as NO3)	mg/L	45	<0.2
pH			7.48
Potassium	mg/L		0.3
Selenium	µg/L	50	<2
Sodium	mg/L		11.6
Sulphate	mg/L		2
Thallium	µg/L		<1
Turbidity	NTU		0.20
Uranium	µg/L	20	<0.5
Zinc	µg/L		63

**New Brunswick Clean Water Results
Fundy Heights Convenience (Zone 14)**

658 Dunn Avenue

Organic Parameters:	Units	Health Advisory	July 11 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		41.0
Bromodichloromethane	µg/L		5.2
Dibromochloromethane	µg/L		< 0.37
Bromoform	µg/L		< 0.34
Total Trihalomethanes	µg/L	100	46.0
Trichloroacetic acid	µg/L		18.7
Dichloroacetic acid	µg/L		17.3
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	36.0

Inorganic Parameters:	Units	Health Advisory	July 11 2022
Alkalinity (as CaCO3)	mg/L		26
Total Hardness (as CaCO3)	mg/L		30
Aluminum	µg/L	2900	<5
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	<10
Boron	µg/L	5000	<10
Cadmium	µg/L	7	<0.02
Calcium	mg/L		11.1
Chloride	mg/L		10.3
Chromium	µg/L	50	<1
Copper	µg/L	2000	30
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		<2
Lead	µg/L	5	<1
Magnesium	mg/L		0.6
Manganese	µg/L	120	<2
Mercury	µg/L	1	<0.02
Nitrate (as NO3)	mg/L	45	<0.2
pH			7.44
Potassium	mg/L		0.4
Selenium	µg/L	50	<2
Sodium	mg/L		11.1
Sulphate	mg/L		2
Thallium	µg/L		<1
Turbidity	NTU		0.26
Uranium	µg/L	20	<0.5
Zinc	µg/L		52

**New Brunswick Clean Water Results
University Avenue Pump Station (Zone 15)**

399 University Avenue

Organic Parameters:	Units	Health Advisory	July 11 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		46.0
Bromodichloromethane	µg/L		5.4
Dibromochloromethane	µg/L		< 0.37
Bromoform	µg/L		< 0.34
Total Trihalomethanes	µg/L	100	52.0
Trichloroacetic acid	µg/L		20.7
Dichloroacetic acid	µg/L		17.9
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	38.5

Inorganic Parameters:	Units	Health Advisory	July 11 2022
Alkalinity (as CaCO3)	mg/L		26
Total Hardness (as CaCO3)	mg/L		19
Aluminum	µg/L	2900	<5
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	<10
Boron	µg/L	5000	<10
Cadmium	µg/L	7	<0.02
Calcium	mg/L		6.5
Chloride	mg/L		10.4
Chromium	µg/L	50	<1
Copper	µg/L	2000	<1
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		<2
Lead	µg/L	5	<1
Magnesium	mg/L		0.6
Manganese	µg/L	120	<2
Mercury	µg/L	1	<0.02
Nitrate (as NO3)	mg/L	45	<0.2
pH			7.18
Potassium	mg/L		0.4
Selenium	µg/L	50	<2
Sodium	mg/L		11.1
Sulphate	mg/L		2
Thallium	µg/L		<1
Turbidity	NTU		0.20
Uranium	µg/L	20	<0.5
Zinc	µg/L		55

**New Brunswick Clean Water Results
Somerset Street Pump Station (Zone 16)**

510 Somerset Street

Organic Parameters:	Units	Health Advisory	July 11 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		46.0
Bromodichloromethane	µg/L		5.4
Dibromochloromethane	µg/L		< 0.37
Bromoform	µg/L		< 0.34
Total Trihalomethanes	µg/L	100	51.0
Trichloroacetic acid	µg/L		26.3
Dichloroacetic acid	µg/L		19.4
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	45.6

Inorganic Parameters:	Units	Health Advisory	July 11 2022
Alkalinity (as CaCO3)	mg/L		26
Total Hardness (as CaCO3)	mg/L		19
Aluminum	µg/L	2900	<5
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	<10
Boron	µg/L	5000	<10
Cadmium	µg/L	7	<0.02
Calcium	mg/L		6.6
Chloride	mg/L		10.7
Chromium	µg/L	50	<1
Copper	µg/L	2000	<1
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		<2
Lead	µg/L	5	<1
Magnesium	mg/L		0.6
Manganese	µg/L	120	<2
Mercury	µg/L	1	<0.02
Nitrate (as NO3)	mg/L	45	<0.2
pH			7.53
Potassium	mg/L		0.5
Selenium	µg/L	50	<2
Sodium	mg/L		11.7
Sulphate	mg/L		2
Thallium	µg/L		<1
Turbidity	NTU		0.18
Uranium	µg/L	20	<0.5
Zinc	µg/L		55

**New Brunswick Clean Water Results
Lakewood Pump Station, Line #2 (Zone 18)**

37 Fish Hatchery Road

Organic Parameters:	Units	Health Advisory	July 11 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		34.0
Bromodichloromethane	µg/L		4.0
Dibromochloromethane	µg/L		< 0.37
Bromoform	µg/L		< 0.34
Total Trihalomethanes	µg/L	100	38.0
Trichloroacetic acid	µg/L		16.5
Dichloroacetic acid	µg/L		13.5
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	30.0

Inorganic Parameters:	Units	Health Advisory	July 11 2022
Alkalinity (as CaCO3)	mg/L		26
Total Hardness (as CaCO3)	mg/L		21
Aluminum	µg/L	2900	<5
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	<10
Boron	µg/L	5000	<10
Cadmium	µg/L	7	<0.02
Calcium	mg/L		7.3
Chloride	mg/L		10.2
Chromium	µg/L	50	<1
Copper	µg/L	2000	<1
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		<2
Lead	µg/L	5	<1
Magnesium	mg/L		0.6
Manganese	µg/L	120	2
Mercury	µg/L	1	<0.02
Nitrate (as NO3)	mg/L	45	<0.2
pH			7.43
Potassium	mg/L		0.4
Selenium	µg/L	50	<2
Sodium	mg/L		11.2
Sulphate	mg/L		2
Thallium	µg/L		<1
Turbidity	NTU		0.19
Uranium	µg/L	20	<0.5
Zinc	µg/L		66

**New Brunswick Clean Water Results
Travelodge Suites (Zone 20)**

1011 Fairville Boulevard

Organic Parameters:	Units	Health Advisory	July 11 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		0.77
Bromodichloromethane	µg/L		1.2
Dibromochloromethane	µg/L		2.9
Bromoform	µg/L		2.2
Total Trihalomethanes	µg/L	100	7.1
Trichloroacetic acid	µg/L		< 5.3
Dichloroacetic acid	µg/L		< 2.6
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	< 5.3

Inorganic Parameters:	Units	Health Advisory	July 11 2022
Alkalinity (as CaCO3)	mg/L		153
Total Hardness (as CaCO3)	mg/L		237
Aluminum	µg/L	2900	<5
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	76
Boron	µg/L	5000	39
Cadmium	µg/L	7	<0.02
Calcium	mg/L		74.6
Chloride	mg/L		77.1
Chromium	µg/L	50	<1
Copper	µg/L	2000	<1
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		<2
Lead	µg/L	5	<1
Magnesium	mg/L		12.3
Manganese	µg/L	120	<2
Mercury	µg/L	1	<0.02
Nitrate (as NO3)	mg/L	45	0.8
pH			8.02
Potassium	mg/L		3.5
Selenium	µg/L	50	<2
Sodium	mg/L		27.9
Sulphate	mg/L		43
Thallium	µg/L		<1
Turbidity	NTU		0.17
Uranium	µg/L	20	2.3
Zinc	µg/L		75

**New Brunswick Clean Water Results
Churchill Heights Water Tank (Zone 21)**

45 Ocean Court

Organic Parameters:	Units	Health Advisory	July 11 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		0.63
Bromodichloromethane	µg/L		1.0
Dibromochloromethane	µg/L		2.4
Bromoform	µg/L		1.7
Total Trihalomethanes	µg/L	100	5.8
Trichloroacetic acid	µg/L		< 5.3
Dichloroacetic acid	µg/L		< 2.6
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	< 5.3

Inorganic Parameters:	Units	Health Advisory	July 11 2022
Alkalinity (as CaCO3)	mg/L		155
Total Hardness (as CaCO3)	mg/L		245
Aluminum	µg/L	2900	<5
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	77
Boron	µg/L	5000	43
Cadmium	µg/L	7	<0.02
Calcium	mg/L		76.8
Chloride	mg/L		76.1
Chromium	µg/L	50	<1
Copper	µg/L	2000	<1
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		<2
Lead	µg/L	5	<1
Magnesium	mg/L		12.9
Manganese	µg/L	120	<2
Mercury	µg/L	1	<0.02
Nitrate (as NO3)	mg/L	45	0.7
pH			8.10
Potassium	mg/L		3.0
Selenium	µg/L	50	<2
Sodium	mg/L		27.7
Sulphate	mg/L		44
Thallium	µg/L		<1
Turbidity	NTU		0.21
Uranium	µg/L	20	2.4
Zinc	µg/L		2

**New Brunswick Clean Water Results
Greybar (Zone 22)**

300 Charlotte Street

Organic Parameters:	Units	Health Advisory	July 11 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		55.0
Bromodichloromethane	µg/L		5.9
Dibromochloromethane	µg/L		< 0.37
Bromoform	µg/L		< 0.34
Total Trihalomethanes	µg/L	100	71.0
Trichloroacetic acid	µg/L		27.5
Dichloroacetic acid	µg/L		24.2
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	51.7

Inorganic Parameters:	Units	Health Advisory	July 11 2022
Alkalinity (as CaCO3)	mg/L		26
Total Hardness (as CaCO3)	mg/L		21
Aluminum	µg/L	2900	8
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	<10
Boron	µg/L	5000	<10
Cadmium	µg/L	7	<0.02
Calcium	mg/L		7.1
Chloride	mg/L		10.9
Chromium	µg/L	50	<1
Copper	µg/L	2000	<1
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		8
Lead	µg/L	5	<1
Magnesium	mg/L		0.7
Manganese	µg/L	120	9
Mercury	µg/L	1	<0.02
Nitrate (as NO3)	mg/L	45	<0.2
pH			7.55
Potassium	mg/L		0.6
Selenium	µg/L	50	<2
Sodium	mg/L		12.0
Sulphate	mg/L		2
Thallium	µg/L		<1
Turbidity	NTU		0.58
Uranium	µg/L	20	<0.5
Zinc	µg/L		43

**New Brunswick Clean Water Results
Park Drive Meter Station (Zone 24)**

36 Park Drive

Organic Parameters:	Units	Health Advisory	July 11 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		71.0
Bromodichloromethane	µg/L		6.4
Dibromochloromethane	µg/L		< 0.37
Bromoform	µg/L		< 0.34
Total Trihalomethanes	µg/L	100	77.0
Trichloroacetic acid	µg/L		24.9
Dichloroacetic acid	µg/L		21.9
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		2.1
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	46.7

Inorganic Parameters:	Units	Health Advisory	July 11 2022
Alkalinity (as CaCO ₃)	mg/L		28
Total Hardness (as CaCO ₃)	mg/L		21
Aluminum	µg/L	2900	<5
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	<10
Boron	µg/L	5000	<10
Cadmium	µg/L	7	<0.02
Calcium	mg/L		7.4
Chloride	mg/L		9.9
Chromium	µg/L	50	<1
Copper	µg/L	2000	<1
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		<2
Lead	µg/L	5	<1
Magnesium	mg/L		0.7
Manganese	µg/L	120	<2
Mercury	µg/L	1	<0.02
Nitrate (as NO ₃)	mg/L	45	<0.2
pH			7.58
Potassium	mg/L		0.4
Selenium	µg/L	50	<2
Sodium	mg/L		11.5
Sulphate	mg/L		2
Thallium	µg/L		<1
Turbidity	NTU		0.19
Uranium	µg/L	20	<0.5
Zinc	µg/L		45

**New Brunswick Clean Water Results
Millidgeville WWTP (Zone 25)**

700 Woodward Avenue

Organic Parameters:	Units	Health Advisory	July 11 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		63.0
Bromodichloromethane	µg/L		6.4
Dibromochloromethane	µg/L		< 0.37
Bromoform	µg/L		< 0.34
Total Trihalomethanes	µg/L	100	70.0
Trichloroacetic acid	µg/L		33.1
Dichloroacetic acid	µg/L		25.4
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	58.5

Inorganic Parameters:	Units	Health Advisory	July 11 2022
Alkalinity (as CaCO3)	mg/L		27
Total Hardness (as CaCO3)	mg/L		20
Aluminum	µg/L	2900	<5
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	<10
Boron	µg/L	5000	<10
Cadmium	µg/L	7	<0.02
Calcium	mg/L		7.1
Chloride	mg/L		10.1
Chromium	µg/L	50	<1
Copper	µg/L	2000	52
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		<2
Lead	µg/L	5	<1
Magnesium	mg/L		0.6
Manganese	µg/L	120	<2
Mercury	µg/L	1	<0.02
Nitrate (as NO3)	mg/L	45	<0.2
pH			7.18
Potassium	mg/L		0.4
Selenium	µg/L	50	<2
Sodium	mg/L		11.2
Sulphate	mg/L		2
Thallium	µg/L		<1
Turbidity	NTU		0.20
Uranium	µg/L	20	<0.5
Zinc	µg/L		48

New Brunswick Clean Water Results Eden Street Sampling Hydrant (Zone 28)			
79 Eden Street			
Organic Parameters:	Units	Health Advisory	July 11 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		0.41
Bromodichloromethane	µg/L		0.53
Dibromochloromethane	µg/L		0.59
Bromoform	µg/L		< 0.34
Total Trihalomethanes	µg/L	100	1.5
Trichloroacetic acid	µg/L		< 5.3
Dichloroacetic acid	µg/L		< 2.6
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	< 5.3

Inorganic Parameters:	Units	Health Advisory	July 11 2022
Alkalinity (as CaCO3)	mg/L		89
Total Hardness (as CaCO3)	mg/L		117
Aluminum	µg/L	2900	<5
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	166
Boron	µg/L	5000	<10
Cadmium	µg/L	7	<0.02
Calcium	mg/L		36.1
Chloride	mg/L		24.6
Chromium	µg/L	50	<1
Copper	µg/L	2000	<1
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		<2
Lead	µg/L	5	<1
Magnesium	mg/L		6.5
Manganese	µg/L	120	<2
Mercury	µg/L	1	<0.02
Nitrate (as NO3)	mg/L	45	1.2
pH			7.88
Potassium	mg/L		0.9
Selenium	µg/L	50	<2
Sodium	mg/L		15.6
Sulphate	mg/L		6
Thallium	µg/L		<1
Turbidity	NTU		0.28
Uranium	µg/L	20	<0.5
Zinc	µg/L		<2

**New Brunswick Clean Water Results
Aberdeen Street Sampling Hydrant (Zone 29)**

132 Aberdeen Avenue

Organic Parameters:	Units	Health Advisory	July 11 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		0.88
Bromodichloromethane	µg/L		1.2
Dibromochloromethane	µg/L		1.1
Bromoform	µg/L		0.43
Total Trihalomethanes	µg/L	100	3.6
Trichloroacetic acid	µg/L		< 5.3
Dichloroacetic acid	µg/L		< 2.6
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	< 5.3

Inorganic Parameters:	Units	Health Advisory	July 11 2022
Alkalinity (as CaCO3)	mg/L		91
Total Hardness (as CaCO3)	mg/L		114
Aluminum	µg/L	2900	<5
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	173
Boron	µg/L	5000	<10
Cadmium	µg/L	7	<0.02
Calcium	mg/L		34.6
Chloride	mg/L		12.9
Chromium	µg/L	50	<1
Copper	µg/L	2000	<1
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		<2
Lead	µg/L	5	<1
Magnesium	mg/L		6.7
Manganese	µg/L	120	<2
Mercury	µg/L	1	<0.02
Nitrate (as NO3)	mg/L	45	1.1
pH			8.05
Potassium	mg/L		2.3
Selenium	µg/L	50	<2
Sodium	mg/L		18.7
Sulphate	mg/L		6
Thallium	µg/L		<1
Turbidity	NTU		0.27
Uranium	µg/L	20	<0.5
Zinc	µg/L		<2

**New Brunswick Clean Water Results
Fairville Boulevard Subway (Zone 34)**

800 Fairville Boulevard

Organic Parameters:	Units	Health Advisory	July 11 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		58.0
Bromodichloromethane	µg/L		6.2
Dibromochloromethane	µg/L		< 0.37
Bromoform	µg/L		< 0.34
Total Trihalomethanes	µg/L	100	64.0
Trichloroacetic acid	µg/L		31.6
Dichloroacetic acid	µg/L		22.9
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	54.5

Inorganic Parameters:	Units	Health Advisory	July 11 2022
Alkalinity (as CaCO3)	mg/L		26
Total Hardness (as CaCO3)	mg/L		25
Aluminum	µg/L	2900	15
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	<10
Boron	µg/L	5000	<10
Cadmium	µg/L	7	<0.02
Calcium	mg/L		9.0
Chloride	mg/L		9.8
Chromium	µg/L	50	<1
Copper	µg/L	2000	<1
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		<2
Lead	µg/L	5	<1
Magnesium	mg/L		0.6
Manganese	µg/L	120	15
Mercury	µg/L	1	<0.02
Nitrate (as NO3)	mg/L	45	<0.2
pH			7.45
Potassium	mg/L		0.5
Selenium	µg/L	50	<2
Sodium	mg/L		11.7
Sulphate	mg/L		2
Thallium	µg/L		<1
Turbidity	NTU		0.48
Uranium	µg/L	20	<0.5
Zinc	µg/L		54

New Brunswick Clean Water Results Saint John Laboratory Services (Zone 35)			
1216 Sand Cove Road			
Organic Parameters:	Units	Health Advisory	July 11 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		67.0
Bromodichloromethane	µg/L		6.9
Dibromochloromethane	µg/L		< 0.37
Bromoform	µg/L		< 0.34
Total Trihalomethanes	µg/L	100	74.0
Trichloroacetic acid	µg/L		31.9
Dichloroacetic acid	µg/L		23.2
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	55.0

Inorganic Parameters:	Units	Health Advisory	July 11 2022
Alkalinity (as CaCO3)	mg/L		26
Total Hardness (as CaCO3)	mg/L		20
Aluminum	µg/L	2900	47
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	<10
Boron	µg/L	5000	<10
Cadmium	µg/L	7	<0.02
Calcium	mg/L		7.1
Chloride	mg/L		10.9
Chromium	µg/L	50	<1
Copper	µg/L	2000	14
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		6
Lead	µg/L	5	<1
Magnesium	mg/L		0.6
Manganese	µg/L	120	<2
Mercury	µg/L	1	<0.02
Nitrate (as NO3)	mg/L	45	<0.2
pH			7.49
Potassium	mg/L		0.4
Selenium	µg/L	50	<2
Sodium	mg/L		11.2
Sulphate	mg/L		2
Thallium	µg/L		<1
Turbidity	NTU		0.19
Uranium	µg/L	20	<0.5
Zinc	µg/L		33