



ADDENDUM

PROJECT TITLE: DOMINION PARK MASTER PLAN-PHASE 1	ADD. NO: 2
TENDER NO: 2022-081202T	DATE: November 16 th , 2022
PAGE 1 of 3 (Including Confirmation Sheet)	

Make the following modifications to the above project. Include in the amount of the Tender, any additions to or deductions from the cost of the work by reason of these instructions.

Sign and attach this Addendum to the Tender documents and submit with your Tender. Failure to do so may result in the rejection of your Tender.

Please find below questions and attached addendum responses.

Please note the following questions and answers.

- Q1. Please provide more detail regarding the rebar required for the concrete steps in the walkway/ Sidewalk
A1. Contractor to submit tender pricing based on the information provided on drawing L5 detail 1 Concrete Stairs. Detailed shop drawings will be required post tender.
- Q2. The drywall spec for this project is asking for 19mm gypsum board but the plans show 16mm gypsum board.
A2. Please use 19mm gypsum board as per specification.
- Q3. The door elevation descriptions on drawing A3 indicate a power door operator for openings #D6 & #D7. The actual door elevation as well as the hardware/Door Schedule do not indicate power door operators at these door locations. Please confirm if these 2 openings actually require power door operators.
A3. D6 + D7 door openings will both require power door operators.
- Q4. The doors that are to receive power door operators will require electric strikes to overcome the latch of the lockset to allow the operator to open the door. No electric strikes are specified for these openings.
A4. D6 + D7 door openings will both require power door operators.

SIGN AND RETURN THIS ADDENDUM WITH YOUR PROPOSAL

BY: Monic MacVicar
Monic MacVicar, CCLP, CPPB
Procurement Specialist, Supply Chain Management

Contractor's Signature



ADDENDUM

PROJECT TITLE: DOMINION PARK MASTER PLAN-PHASE 1	ADD. NO: 2
TENDER NO: 2022-081202T	DATE: November 16 th , 2022
PAGE 2 of 3 (Including Confirmation Sheet)	
<p>Q5. Opening D8 is shown with a window prep in the door elevations but not on the actual building elevations. Please confirm that the window is required at this opening. A5. <i>Opening D8 does include a window as shown on the door schedule.</i></p> <p>Q6. Would it be possible to price an alternate power door operator for this project? We would like to offer the Besam 200i power door operator in lieu of the Nabco GT-20 noted. A6. <i>Pricing for Besam 200i power door operator will be accepted as an alternative product.</i></p>	

SIGN AND RETURN THIS ADDENDUM WITH YOUR PROPOSAL

BY: Monic MacVicar
Monic MacVicar, CCLP, CPPB
Procurement Specialist, Supply Chain Management

Contractor's Signature



ADDENDUM

PROJECT TITLE: DOMINION PARK MASTER PLAN-PHASE 1	ADD. NO: 2
TENDER NO: 2022-081202T	DATE: November 16 th , 2022
PAGE 3 of 3 (Including Confirmation Sheet)	

CONFIRMATION - RECEIPT OF ADDENDUM

**Upon receipt of this document, fax this page to
(506) 658-4742 to confirm receipt of this addendum.**

CONTRACTOR'S NAME: _____

ADDRESS: _____

PHONE: _____ FAX: _____

RECEIVER NAME (PRINT) _____

RECEIVER SIGNATURE: _____