

<b>New Brunswick Clean Water Results</b>			
<b>Ocean Drive Well Raw Water (Source 2)</b>			
<i>Located at: 103 Ocean Drive</i>			
Organic Parameters:	Units	Health Advisory	October 24 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		< 0.29
Bromodichloromethane	µg/L		< 0.26
Dibromochloromethane	µg/L		< 0.37
Bromoform	µg/L		< 0.34
Total Trihalomethanes	µg/L	100	< 0.37
Trichloroacetic acid	µg/L		< 5.3
Dichloroacetic acid	µg/L		< 2.6
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	< 5.3

Inorganic Parameters:	Units	Health Advisory	October 24 2022
Alkalinity (as CaCO3)	mg/L		89
Total Hardness (as CaCO3)	mg/L		114
Aluminum	µg/L	2900	<5
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	185
Boron	µg/L	5000	<10
Cadmium	µg/L	7	<0.02
Calcium	mg/L		35.1
Chloride	mg/L		32.9
Chromium	µg/L	50	<1
Copper	µg/L	2000	<1
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		15
Lead	µg/L	5	<1
Magnesium	mg/L		6.4
Manganese	µg/L	120	<2
Mercury	µg/L	1	<0.02
Nitrate (as NO3)	mg/L	45	1.3
pH			8.06
Potassium	mg/L		0.3
Selenium	µg/L	50	<2
Sodium	mg/L		13.5
Sulphate	mg/L		6
Thallium	µg/L		<1
Turbidity	NTU		0.23
Uranium	µg/L	20	<0.5
Zinc	µg/L		<2

**New Brunswick Clean Water Results  
Seaward Crescent Well Raw Water (Source 3)**

*Located at: 14 Seaward Crescent*

Organic Parameters:	Units	Health Advisory	October 24 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		< 0.29
Bromodichloromethane	µg/L		< 0.26
Dibromochloromethane	µg/L		< 0.37
Bromoform	µg/L		< 0.34
Total Trihalomethanes	µg/L	100	< 0.37
Trichloroacetic acid	µg/L		< 5.3
Dichloroacetic acid	µg/L		< 2.6
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	< 5.3

Inorganic Parameters:	Units	Health Advisory	October 24 2022
Alkalinity (as CaCO3)	mg/L		92
Total Hardness (as CaCO3)	mg/L		103
Aluminum	µg/L	2900	<5
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	271
Boron	µg/L	5000	<10
Cadmium	µg/L	7	<0.02
Calcium	mg/L		34.2
Chloride	mg/L		14.0
Chromium	µg/L	50	<1
Copper	µg/L	2000	<1
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		11
Lead	µg/L	5	<1
Magnesium	mg/L		4.3
Manganese	µg/L	120	<2
Mercury	µg/L	1	<0.02
Nitrate (as NO3)	mg/L	45	1.2
pH			8.03
Potassium	mg/L		0.3
Selenium	µg/L	50	<2
Sodium	mg/L		6.9
Sulphate	mg/L		6
Thallium	µg/L		<1
Turbidity	NTU		0.28
Uranium	µg/L	20	<0.5
Zinc	µg/L		<2

**New Brunswick Clean Water Results  
Latimer Lake Raw Water (Source 4)**

*Located at: 1200 Pipeline Road*

Organic Parameters:	Units	Health Advisory	October 24 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		< 0.29
Bromodichloromethane	µg/L		< 0.26
Dibromochloromethane	µg/L		< 0.37
Bromoform	µg/L		< 0.34
Total Trihalomethanes	µg/L	100	< 0.37
Trichloroacetic acid	µg/L		< 5.3
Dichloroacetic acid	µg/L		< 2.6
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	< 5.3

Inorganic Parameters:	Units	Health Advisory	October 24 2022
Alkalinity (as CaCO3)	mg/L		9
Total Hardness (as CaCO3)	mg/L		12
Aluminum	µg/L	2900	<5
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	<10
Boron	µg/L	5000	< 10
Cadmium	µg/L	7	<0.02
Calcium	mg/L		3.9
Chloride	mg/L		6.8
Chromium	µg/L	50	<1
Copper	µg/L	2000	<1
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		213
Lead	µg/L	5	<1
Magnesium	mg/L		0.6
Manganese	µg/L	120	37
Mercury	µg/L	1	<0.02
Nitrate (as NO3)	mg/L	45	<0.2
pH			6.84
Potassium	mg/L		0.2
Selenium	µg/L	50	<2
Sodium	mg/L		3.8
Sulphate	mg/L		2
Thallium	µg/L		<1
Turbidity	NTU		0.50
Uranium	µg/L	20	<0.5
Zinc	µg/L		<2

New Brunswick Clean Water Results Southbay Well #1 Raw Water (Source 5)			
<i>Located at: 66 Gaelic Drive</i>			
Organic Parameters:	Units	Health Advisory	October 24 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		0.54
Bromodichloromethane	µg/L		< 0.26
Dibromochloromethane	µg/L		< 0.37
Bromoform	µg/L		< 0.34
Total Trihalomethanes	µg/L	100	0.54
Trichloroacetic acid	µg/L		< 5.3
Dichloroacetic acid	µg/L		< 2.6
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	< 5.3

Inorganic Parameters:	Units	Health Advisory	October 24 2022
Alkalinity (as CaCO3)	mg/L		140
Total Hardness (as CaCO3)	mg/L		215
Aluminum	µg/L	2900	<5
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	57
Boron	µg/L	5000	15
Cadmium	µg/L	7	<0.02
Calcium	mg/L		68.3
Chloride	mg/L		80.6
Chromium	µg/L	50	<1
Copper	µg/L	2000	<1
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		<2
Lead	µg/L	5	<1
Magnesium	mg/L		10.7
Manganese	µg/L	120	<2
Mercury	µg/L	1	<0.02
Nitrate (as NO3)	mg/L	45	0.9
pH			8.08
Potassium	mg/L		1.5
Selenium	µg/L	50	<2
Sodium	mg/L		22.4
Sulphate	mg/L		24
Thallium	µg/L		<1
Turbidity	NTU		0.45
Uranium	µg/L	20	2.1
Zinc	µg/L		<2

New Brunswick Clean Water Results Southbay Well #2 Raw Water (Source 6)			
<i>Located at: 66 Gaelic Drive</i>			
Organic Parameters:	Units	Health Advisory	October 24 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		1.1
Bromodichloromethane	µg/L		< 0.26
Dibromochloromethane	µg/L		< 0.37
Bromoform	µg/L		< 0.34
Total Trihalomethanes	µg/L	100	1.1
Trichloroacetic acid	µg/L		< 5.3
Dichloroacetic acid	µg/L		< 2.6
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	< 5.3

Inorganic Parameters:	Units	Health Advisory	October 24 2022
Alkalinity (as CaCO3)	mg/L		128
Total Hardness (as CaCO3)	mg/L		208
Aluminum	µg/L	2900	<5
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	60
Boron	µg/L	5000	16
Cadmium	µg/L	7	<0.02
Calcium	mg/L		67.1
Chloride	mg/L		73.3
Chromium	µg/L	50	<1
Copper	µg/L	2000	<1
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		<2
Lead	µg/L	5	<1
Magnesium	mg/L		9.5
Manganese	µg/L	120	<2
Mercury	µg/L	1	<0.02
Nitrate (as NO3)	mg/L	45	0.8
pH			8.04
Potassium	mg/L		2.6
Selenium	µg/L	50	<2
Sodium	mg/L		21.2
Sulphate	mg/L		23
Thallium	µg/L		<1
Turbidity	NTU		0.28
Uranium	µg/L	20	1.9
Zinc	µg/L		<2

<b>New Brunswick Clean Water Results</b>			
<b>Southbay Well #3 Raw Water (Source 7)</b>			
<i>Located at: 66 Gaelic Drive</i>			
Organic Parameters:	Units	Health Advisory	October 24 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		< 0.29
Bromodichloromethane	µg/L		< 0.26
Dibromochloromethane	µg/L		< 0.37
Bromoform	µg/L		< 0.34
Total Trihalomethanes	µg/L	100	< 0.37
Trichloroacetic acid	µg/L		< 5.3
Dichloroacetic acid	µg/L		< 2.6
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	< 5.3

Inorganic Parameters:	Units	Health Advisory	October 24 2022
Alkalinity (as CaCO3)	mg/L		182
Total Hardness (as CaCO3)	mg/L		273
Aluminum	µg/L	2900	<5
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	122
Boron	µg/L	5000	104
Cadmium	µg/L	7	<0.02
Calcium	mg/L		82.9
Chloride	mg/L		70.4
Chromium	µg/L	50	<1
Copper	µg/L	2000	<1
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		<2
Lead	µg/L	5	<1
Magnesium	mg/L		16.0
Manganese	µg/L	120	10
Mercury	µg/L	1	<0.02
Nitrate (as NO3)	mg/L	45	<0.2
pH			7.80
Potassium	mg/L		3.2
Selenium	µg/L	50	<2
Sodium	mg/L		26.8
Sulphate	mg/L		47
Thallium	µg/L		<1
Turbidity	NTU		0.67
Uranium	µg/L	20	3.4
Zinc	µg/L		<2

**New Brunswick Clean Water Results  
Carleton Community Centre (Zone 2)**

*Located at: 89 Market Place*

Organic Parameters:	Units	Health Advisory	October 24 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		46.0
Bromodichloromethane	µg/L		6.5
Dibromochloromethane	µg/L		0.42
Bromoform	µg/L		< 0.34
Total Trihalomethanes	µg/L	100	53.0
Trichloroacetic acid	µg/L		24.6
Dichloroacetic acid	µg/L		17.2
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	41.8

Inorganic Parameters:	Units	Health Advisory	October 24 2022
Alkalinity (as CaCO <sub>3</sub> )	mg/L		26
Total Hardness (as CaCO <sub>3</sub> )	mg/L		21
Aluminum	µg/L	2900	<5
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	<10
Boron	µg/L	5000	<10
Cadmium	µg/L	7	<0.02
Calcium	mg/L		7.3
Chloride	mg/L		10.4
Chromium	µg/L	50	<1
Copper	µg/L	2000	<1
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		19
Lead	µg/L	5	<1
Magnesium	mg/L		0.7
Manganese	µg/L	120	<2
Mercury	µg/L	1	<0.02
Nitrate (as NO <sub>3</sub> )	mg/L	45	<0.2
pH			7.34
Potassium	mg/L		0.2
Selenium	µg/L	50	<2
Sodium	mg/L		10.6
Sulphate	mg/L		2
Thallium	µg/L		<1
Turbidity	NTU		0.24
Uranium	µg/L	20	<0.5
Zinc	µg/L		91

**New Brunswick Clean Water Results  
Ridgewood Lift Station (Zone 3)**

*Located at: 410 Bay Street*

Organic Parameters:	Units	Health Advisory	October 24 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		1.1
Bromodichloromethane	µg/L		2.3
Dibromochloromethane	µg/L		5.6
Bromoform	µg/L		5.4
Total Trihalomethanes	µg/L	100	14.0
Trichloroacetic acid	µg/L		< 5.3
Dichloroacetic acid	µg/L		< 2.6
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		2.1
Haloacetic acids 6 / HAA6	µg/L	80	< 5.3

Inorganic Parameters:	Units	Health Advisory	October 24 2022
Alkalinity (as CaCO3)	mg/L		153
Total Hardness (as CaCO3)	mg/L		248
Aluminum	µg/L	2900	<5
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	75
Boron	µg/L	5000	44
Cadmium	µg/L	7	<0.02
Calcium	mg/L		81.1
Chloride	mg/L		72.2
Chromium	µg/L	50	<1
Copper	µg/L	2000	<1
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		14
Lead	µg/L	5	<1
Magnesium	mg/L		11.1
Manganese	µg/L	120	<2
Mercury	µg/L	1	<0.02
Nitrate (as NO3)	mg/L	45	0.5
pH			8.24
Potassium	mg/L		2.4
Selenium	µg/L	50	<2
Sodium	mg/L		26.0
Sulphate	mg/L		35
Thallium	µg/L		<1
Turbidity	NTU		0.17
Uranium	µg/L	20	3.0
Zinc	µg/L		66



**New Brunswick Clean Water Results  
Operations Complex (Zone 4)**

*Located at: 175 Rothesay Avenue*

Organic Parameters:	Units	Health Advisory	October 24 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		31.0
Bromodichloromethane	µg/L		5.5
Dibromochloromethane	µg/L		< 0.37
Bromoform	µg/L		< 0.34
Total Trihalomethanes	µg/L	100	37.0
Trichloroacetic acid	µg/L		22.9
Dichloroacetic acid	µg/L		16.5
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	39.4

Inorganic Parameters:	Units	Health Advisory	October 24 2022
Alkalinity (as CaCO3)	mg/L		26
Total Hardness (as CaCO3)	mg/L		18
Aluminum	µg/L	2900	15
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	<10
Boron	µg/L	5000	<10
Cadmium	µg/L	7	<0.02
Calcium	mg/L		6.2
Chloride	mg/L		10.4
Chromium	µg/L	50	<1
Copper	µg/L	2000	<1
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		49
Lead	µg/L	5	<1
Magnesium	mg/L		0.6
Manganese	µg/L	120	<2
Mercury	µg/L	1	<0.02
Nitrate (as NO3)	mg/L	45	<0.2
pH			7.54
Potassium	mg/L		0.1
Selenium	µg/L	50	<2
Sodium	mg/L		10.5
Sulphate	mg/L		2
Thallium	µg/L		<1
Turbidity	NTU		0.21
Uranium	µg/L	20	<0.5
Zinc	µg/L		91

**New Brunswick Clean Water Results  
Fundy Linen (Zone 6)**

*Located at: 320 King William Road*

Organic Parameters:	Units	Health Advisory	October 24 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		0.84
Bromodichloromethane	µg/L		0.70
Dibromochloromethane	µg/L		1.7
Bromoform	µg/L		1.4
Total Trihalomethanes	µg/L	100	4.6
Trichloroacetic acid	µg/L		< 5.3
Dichloroacetic acid	µg/L		< 2.6
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	< 5.3

Inorganic Parameters:	Units	Health Advisory	October 24 2022
Alkalinity (as CaCO3)	mg/L		145
Total Hardness (as CaCO3)	mg/L		242
Aluminum	µg/L	2900	<5
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	74
Boron	µg/L	5000	69
Cadmium	µg/L	7	<0.02
Calcium	mg/L		78.4
Chloride	mg/L		74.6
Chromium	µg/L	50	<1
Copper	µg/L	2000	<1
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		12
Lead	µg/L	5	<1
Magnesium	mg/L		11.2
Manganese	µg/L	120	<2
Mercury	µg/L	1	<0.02
Nitrate (as NO3)	mg/L	45	0.5
pH			7.96
Potassium	mg/L		2.3
Selenium	µg/L	50	<2
Sodium	mg/L		24.0
Sulphate	mg/L		32
Thallium	µg/L		<1
Turbidity	NTU		0.31
Uranium	µg/L	20	3.1
Zinc	µg/L		67

**New Brunswick Clean Water Results  
Ryerson Metals (Zone 7)**

*Located at: 2 Whitebone Way*

Organic Parameters:	Units	Health Advisory	October 24 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		48.0
Bromodichloromethane	µg/L		6.1
Dibromochloromethane	µg/L		0.38
Bromoform	µg/L		< 0.34
Total Trihalomethanes	µg/L	100	54.0
Trichloroacetic acid	µg/L		29.2
Dichloroacetic acid	µg/L		20.8
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	50.0

Inorganic Parameters:	Units	Health Advisory	October 24 2022
Alkalinity (as CaCO3)	mg/L		27
Total Hardness (as CaCO3)	mg/L		20
Aluminum	µg/L	2900	14
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	<10
Boron	µg/L	5000	<10
Cadmium	µg/L	7	<0.02
Calcium	mg/L		6.9
Chloride	mg/L		10.3
Chromium	µg/L	50	<1
Copper	µg/L	2000	<1
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		16
Lead	µg/L	5	<1
Magnesium	mg/L		0.6
Manganese	µg/L	120	<2
Mercury	µg/L	1	<0.02
Nitrate (as NO3)	mg/L	45	<0.2
pH			7.54
Potassium	mg/L		0.1
Selenium	µg/L	50	<2
Sodium	mg/L		11.1
Sulphate	mg/L		2
Thallium	µg/L		<1
Turbidity	NTU		0.16
Uranium	µg/L	20	<0.5
Zinc	µg/L		88

**New Brunswick Clean Water Results  
Bridge Road Pump Station (Zone 8)**

*Located at: 435 Riverview Drive*

Organic Parameters:	Units	Health Advisory	October 24 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		35.0
Bromodichloromethane	µg/L		5.5
Dibromochloromethane	µg/L		< 0.37
Bromoform	µg/L		< 0.34
Total Trihalomethanes	µg/L	100	40.0
Trichloroacetic acid	µg/L		26.3
Dichloroacetic acid	µg/L		17.1
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	43.5

Inorganic Parameters:	Units	Health Advisory	October 24 2022
Alkalinity (as CaCO3)	mg/L		27
Total Hardness (as CaCO3)	mg/L		21
Aluminum	µg/L	2900	<5
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	<10
Boron	µg/L	5000	<10
Cadmium	µg/L	7	<0.02
Calcium	mg/L		7.1
Chloride	mg/L		10.2
Chromium	µg/L	50	<1
Copper	µg/L	2000	<1
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		<2
Lead	µg/L	5	<1
Magnesium	mg/L		0.7
Manganese	µg/L	120	<2
Mercury	µg/L	1	<0.02
Nitrate (as NO3)	mg/L	45	<0.2
pH			7.38
Potassium	mg/L		0.3
Selenium	µg/L	50	<2
Sodium	mg/L		10.7
Sulphate	mg/L		2
Thallium	µg/L		<1
Turbidity	NTU		0.19
Uranium	µg/L	20	<0.5
Zinc	µg/L		66

**New Brunswick Clean Water Results  
Doiron Sports (Zone 9)**

*Located at: 31 Greenhead Road*

Organic Parameters:	Units	Health Advisory	October 24 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		40.0
Bromodichloromethane	µg/L		6.0
Dibromochloromethane	µg/L		0.41
Bromoform	µg/L		< 0.34
Total Trihalomethanes	µg/L	100	46.0
Trichloroacetic acid	µg/L		23.6
Dichloroacetic acid	µg/L		15.7
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	39.3

Inorganic Parameters:	Units	Health Advisory	October 24 2022
Alkalinity (as CaCO3)	mg/L		28
Total Hardness (as CaCO3)	mg/L		21
Aluminum	µg/L	2900	<5
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	<10
Boron	µg/L	5000	<10
Cadmium	µg/L	7	<0.02
Calcium	mg/L		7.5
Chloride	mg/L		9.3
Chromium	µg/L	50	<1
Copper	µg/L	2000	<1
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		29
Lead	µg/L	5	<1
Magnesium	mg/L		0.6
Manganese	µg/L	120	<2
Mercury	µg/L	1	<0.02
Nitrate (as NO3)	mg/L	45	<0.2
pH			7.52
Potassium	mg/L		0.1
Selenium	µg/L	50	<2
Sodium	mg/L		11.6
Sulphate	mg/L		2
Thallium	µg/L		<1
Turbidity	NTU		0.34
Uranium	µg/L	20	<0.5
Zinc	µg/L		89

**New Brunswick Clean Water Results  
Kennebecasis Drive PRV (Zone 10)**

*Located at: 1240 Kennebecasis Drive*

Organic Parameters:	Units	Health Advisory	October 24 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		46.0
Bromodichloromethane	µg/L		5.9
Dibromochloromethane	µg/L		< 0.37
Bromoform	µg/L		< 0.34
Total Trihalomethanes	µg/L	100	52.0
Trichloroacetic acid	µg/L		29.6
Dichloroacetic acid	µg/L		23.8
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	53.4

Inorganic Parameters:	Units	Health Advisory	October 24 2022
Alkalinity (as CaCO3)	mg/L		27
Total Hardness (as CaCO3)	mg/L		21
Aluminum	µg/L	2900	9
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	<10
Boron	µg/L	5000	<10
Cadmium	µg/L	7	<0.02
Calcium	mg/L		7.3
Chloride	mg/L		10.6
Chromium	µg/L	50	<1
Copper	µg/L	2000	<1
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		8
Lead	µg/L	5	<1
Magnesium	mg/L		0.6
Manganese	µg/L	120	<2
Mercury	µg/L	1	<0.02
Nitrate (as NO3)	mg/L	45	<0.2
pH			7.34
Potassium	mg/L		0.2
Selenium	µg/L	50	<2
Sodium	mg/L		10.6
Sulphate	mg/L		2
Thallium	µg/L		<1
Turbidity	NTU		0.17
Uranium	µg/L	20	<0.5
Zinc	µg/L		73

**New Brunswick Clean Water Results  
Champlain Heights Pump Station (Zone 13)**

*Located at: 784 Loch Lomond Road*

Organic Parameters:	Units	Health Advisory	October 24 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		25.0
Bromodichloromethane	µg/L		4.5
Dibromochloromethane	µg/L		< 0.37
Bromoform	µg/L		< 0.34
Total Trihalomethanes	µg/L	100	29.0
Trichloroacetic acid	µg/L		17.3
Dichloroacetic acid	µg/L		12.3
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	29.6

Inorganic Parameters:	Units	Health Advisory	October 24 2022
Alkalinity (as CaCO3)	mg/L		26
Total Hardness (as CaCO3)	mg/L		19
Aluminum	µg/L	2900	<5
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	<10
Boron	µg/L	5000	<10
Cadmium	µg/L	7	<0.02
Calcium	mg/L		6.6
Chloride	mg/L		10.2
Chromium	µg/L	50	<1
Copper	µg/L	2000	<1
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		<2
Lead	µg/L	5	<1
Magnesium	mg/L		0.6
Manganese	µg/L	120	<2
Mercury	µg/L	1	<0.02
Nitrate (as NO3)	mg/L	45	<0.2
pH			7.32
Potassium	mg/L		0.2
Selenium	µg/L	50	<2
Sodium	mg/L		11.3
Sulphate	mg/L		2
Thallium	µg/L		<1
Turbidity	NTU		0.20
Uranium	µg/L	20	<0.5
Zinc	µg/L		63

**New Brunswick Clean Water Results  
Fundy Heights Convenience (Zone 14)**

*Located at: 658 Dunn Avenue*

Organic Parameters:	Units	Health Advisory	October 24 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		32.0
Bromodichloromethane	µg/L		5.3
Dibromochloromethane	µg/L		< 0.37
Bromoform	µg/L		< 0.34
Total Trihalomethanes	µg/L	100	37.0
Trichloroacetic acid	µg/L		23.3
Dichloroacetic acid	µg/L		16.4
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	39.7

Inorganic Parameters:	Units	Health Advisory	October 24 2022
Alkalinity (as CaCO3)	mg/L		25
Total Hardness (as CaCO3)	mg/L		20
Aluminum	µg/L	2900	<5
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	<10
Boron	µg/L	5000	<10
Cadmium	µg/L	7	<0.02
Calcium	mg/L		7.1
Chloride	mg/L		10.3
Chromium	µg/L	50	<1
Copper	µg/L	2000	<1
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		13
Lead	µg/L	5	<1
Magnesium	mg/L		0.6
Manganese	µg/L	120	<2
Mercury	µg/L	1	<0.02
Nitrate (as NO3)	mg/L	45	<0.2
pH			6.98
Potassium	mg/L		0.1
Selenium	µg/L	50	<2
Sodium	mg/L		11.2
Sulphate	mg/L		2
Thallium	µg/L		<1
Turbidity	NTU		0.22
Uranium	µg/L	20	<0.5
Zinc	µg/L		79



**New Brunswick Clean Water Results  
University Avenue Pump Station (Zone 15)**

*Located at: 399 University Avenue*

Organic Parameters:	Units	Health Advisory	October 24 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		47.0
Bromodichloromethane	µg/L		6.6
Dibromochloromethane	µg/L		0.39
Bromoform	µg/L		< 0.34
Total Trihalomethanes	µg/L	100	54.0
Trichloroacetic acid	µg/L		28.1
Dichloroacetic acid	µg/L		19.9
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	48.0

Inorganic Parameters:	Units	Health Advisory	October 24 2022
Alkalinity (as CaCO <sub>3</sub> )	mg/L		26
Total Hardness (as CaCO <sub>3</sub> )	mg/L		20
Aluminum	µg/L	2900	12
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	<10
Boron	µg/L	5000	<10
Cadmium	µg/L	7	<0.02
Calcium	mg/L		7.2
Chloride	mg/L		10.8
Chromium	µg/L	50	<1
Copper	µg/L	2000	<1
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		6
Lead	µg/L	5	<1
Magnesium	mg/L		0.6
Manganese	µg/L	120	<2
Mercury	µg/L	1	<0.02
Nitrate (as NO <sub>3</sub> )	mg/L	45	<0.2
pH			7.37
Potassium	mg/L		0.1
Selenium	µg/L	50	<2
Sodium	mg/L		10.8
Sulphate	mg/L		2
Thallium	µg/L		<1
Turbidity	NTU		0.23
Uranium	µg/L	20	<0.5
Zinc	µg/L		69

**New Brunswick Clean Water Results  
Somerset Street Pump Station (Zone 16)**

*Located at: 510 Somerset Street*

Organic Parameters:	Units	Health Advisory	October 24 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		33.0
Bromodichloromethane	µg/L		5.4
Dibromochloromethane	µg/L		< 0.37
Bromoform	µg/L		< 0.34
Total Trihalomethanes	µg/L	100	39.0
Trichloroacetic acid	µg/L		22.9
Dichloroacetic acid	µg/L		15.2
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	38.1

Inorganic Parameters:	Units	Health Advisory	October 24 2022
Alkalinity (as CaCO3)	mg/L		28
Total Hardness (as CaCO3)	mg/L		20
Aluminum	µg/L	2900	<5
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	<10
Boron	µg/L	5000	<10
Cadmium	µg/L	7	<0.02
Calcium	mg/L		6.9
Chloride	mg/L		10.8
Chromium	µg/L	50	<1
Copper	µg/L	2000	<1
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		<2
Lead	µg/L	5	<1
Magnesium	mg/L		0.6
Manganese	µg/L	120	<2
Mercury	µg/L	1	<0.02
Nitrate (as NO3)	mg/L	45	<0.2
pH			7.42
Potassium	mg/L		0.1
Selenium	µg/L	50	<2
Sodium	mg/L		10.7
Sulphate	mg/L		4
Thallium	µg/L		<1
Turbidity	NTU		0.18
Uranium	µg/L	20	<0.5
Zinc	µg/L		65

**New Brunswick Clean Water Results  
Lakewood Pump Station, Line #2 (Zone 18)**

*Located at: 37 Fish Hatchery Road*

Organic Parameters:	Units	Health Advisory	October 24 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		24.0
Bromodichloromethane	µg/L		4.2
Dibromochloromethane	µg/L		< 0.37
Bromoform	µg/L		< 0.34
Total Trihalomethanes	µg/L	100	28.0
Trichloroacetic acid	µg/L		16.2
Dichloroacetic acid	µg/L		12.1
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	28.4

Inorganic Parameters:	Units	Health Advisory	October 24 2022
Alkalinity (as CaCO3)	mg/L		27
Total Hardness (as CaCO3)	mg/L		18
Aluminum	µg/L	2900	14
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	<10
Boron	µg/L	5000	<10
Cadmium	µg/L	7	<0.02
Calcium	mg/L		6.3
Chloride	mg/L		10.0
Chromium	µg/L	50	<1
Copper	µg/L	2000	<1
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		20
Lead	µg/L	5	<1
Magnesium	mg/L		0.6
Manganese	µg/L	120	2
Mercury	µg/L	1	<0.02
Nitrate (as NO3)	mg/L	45	<0.2
pH			7.56
Potassium	mg/L		0.2
Selenium	µg/L	50	<2
Sodium	mg/L		10.9
Sulphate	mg/L		2
Thallium	µg/L		<1
Turbidity	NTU		0.16
Uranium	µg/L	20	<0.5
Zinc	µg/L		95

**New Brunswick Clean Water Results  
Travelodge Suites (Zone 20)**

*Located at: 1011 Fairville Boulevard*

Organic Parameters:	Units	Health Advisory	October 24 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		0.87
Bromodichloromethane	µg/L		1.4
Dibromochloromethane	µg/L		3.2
Bromoform	µg/L		2.8
Total Trihalomethanes	µg/L	100	8.4
Trichloroacetic acid	µg/L		< 5.3
Dichloroacetic acid	µg/L		< 2.6
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	< 5.3

Inorganic Parameters:	Units	Health Advisory	October 24 2022
Alkalinity (as CaCO3)	mg/L		152
Total Hardness (as CaCO3)	mg/L		243
Aluminum	µg/L	2900	<5
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	77
Boron	µg/L	5000	59
Cadmium	µg/L	7	<0.02
Calcium	mg/L		76.0
Chloride	mg/L		74.5
Chromium	µg/L	50	<1
Copper	µg/L	2000	<1
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		<2
Lead	µg/L	5	<1
Magnesium	mg/L		12.8
Manganese	µg/L	120	<2
Mercury	µg/L	1	<0.02
Nitrate (as NO3)	mg/L	45	<0.2
pH			8.18
Potassium	mg/L		2.9
Selenium	µg/L	50	<2
Sodium	mg/L		26.9
Sulphate	mg/L		31
Thallium	µg/L		<1
Turbidity	NTU		0.33
Uranium	µg/L	20	2.7
Zinc	µg/L		74

New Brunswick Clean Water Results Churchill Heights Water Tank (Zone 21)			
<i>Located at: 45 Ocean Court</i>			
Organic Parameters:	Units	Health Advisory	October 24 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		0.77
Bromodichloromethane	µg/L		1.3
Dibromochloromethane	µg/L		3.1
Bromoform	µg/L		2.6
Total Trihalomethanes	µg/L	100	7.8
Trichloroacetic acid	µg/L		< 5.3
Dichloroacetic acid	µg/L		< 2.6
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	< 5.3

Inorganic Parameters:	Units	Health Advisory	October 24 2022
Alkalinity (as CaCO3)	mg/L		153
Total Hardness (as CaCO3)	mg/L		244
Aluminum	µg/L	2900	<5
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	76
Boron	µg/L	5000	51
Cadmium	µg/L	7	<0.02
Calcium	mg/L		78.6
Chloride	mg/L		72.4
Chromium	µg/L	50	<1
Copper	µg/L	2000	<1
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		6
Lead	µg/L	5	<1
Magnesium	mg/L		11.6
Manganese	µg/L	120	<2
Mercury	µg/L	1	<0.02
Nitrate (as NO3)	mg/L	45	0.5
pH			8.08
Potassium	mg/L		2.3
Selenium	µg/L	50	<2
Sodium	mg/L		25.0
Sulphate	mg/L		33
Thallium	µg/L		<1
Turbidity	NTU		0.17
Uranium	µg/L	20	2.9
Zinc	µg/L		71

**New Brunswick Clean Water Results  
Greybar (Zone 22)**

*Located at: 300 Charlotte Street*

Organic Parameters:	Units	Health Advisory	October 24 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		40.0
Bromodichloromethane	µg/L		6.0
Dibromochloromethane	µg/L		0.39
Bromoform	µg/L		< 0.34
Total Trihalomethanes	µg/L	100	46.0
Trichloroacetic acid	µg/L		24.3
Dichloroacetic acid	µg/L		16.6
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	40.9

Inorganic Parameters:	Units	Health Advisory	October 24 2022
Alkalinity (as CaCO3)	mg/L		26
Total Hardness (as CaCO3)	mg/L		20
Aluminum	µg/L	2900	8
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	<10
Boron	µg/L	5000	<10
Cadmium	µg/L	7	<0.02
Calcium	mg/L		6.8
Chloride	mg/L		10.3
Chromium	µg/L	50	<1
Copper	µg/L	2000	<1
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		<2
Lead	µg/L	5	<1
Magnesium	mg/L		0.7
Manganese	µg/L	120	5
Mercury	µg/L	1	<0.02
Nitrate (as NO3)	mg/L	45	<0.2
pH			7.36
Potassium	mg/L		0.3
Selenium	µg/L	50	<2
Sodium	mg/L		10.7
Sulphate	mg/L		2
Thallium	µg/L		<1
Turbidity	NTU		0.33
Uranium	µg/L	20	<0.5
Zinc	µg/L		78

**New Brunswick Clean Water Results  
Park Drive Meter Station (Zone 24)**

*Located at: 36 Park Drive*

Organic Parameters:	Units	Health Advisory	October 24 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		77.0
Bromodichloromethane	µg/L		8.5
Dibromochloromethane	µg/L		0.51
Bromoform	µg/L		< 0.34
Total Trihalomethanes	µg/L	100	86.0
Trichloroacetic acid	µg/L		33.0
Dichloroacetic acid	µg/L		13.8
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	46.8

Inorganic Parameters:	Units	Health Advisory	October 24 2022
Alkalinity (as CaCO3)	mg/L		26
Total Hardness (as CaCO3)	mg/L		18
Aluminum	µg/L	2900	11
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	<10
Boron	µg/L	5000	<10
Cadmium	µg/L	7	<0.02
Calcium	mg/L		6.1
Chloride	mg/L		10.3
Chromium	µg/L	50	<1
Copper	µg/L	2000	<1
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		12
Lead	µg/L	5	<1
Magnesium	mg/L		0.6
Manganese	µg/L	120	<2
Mercury	µg/L	1	<0.02
Nitrate (as NO3)	mg/L	45	<0.2
pH			7.51
Potassium	mg/L		0.1
Selenium	µg/L	50	<2
Sodium	mg/L		11.3
Sulphate	mg/L		2
Thallium	µg/L		<1
Turbidity	NTU		0.27
Uranium	µg/L	20	<0.5
Zinc	µg/L		87

**New Brunswick Clean Water Results  
Millidgeville WWTP (Zone 25)**

*Located at: 700 Woodward Avenue*

Organic Parameters:	Units	Health Advisory	October 24 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		44.0
Bromodichloromethane	µg/L		5.8
Dibromochloromethane	µg/L		< 0.37
Bromoform	µg/L		< 0.34
Total Trihalomethanes	µg/L	100	49.0
Trichloroacetic acid	µg/L		30.9
Dichloroacetic acid	µg/L		21.0
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	51.9

Inorganic Parameters:	Units	Health Advisory	October 24 2022
Alkalinity (as CaCO3)	mg/L		27
Total Hardness (as CaCO3)	mg/L		21
Aluminum	µg/L	2900	6
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	<10
Boron	µg/L	5000	<10
Cadmium	µg/L	7	<0.02
Calcium	mg/L		7.4
Chloride	mg/L		10.4
Chromium	µg/L	50	<1
Copper	µg/L	2000	<1
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		8
Lead	µg/L	5	<1
Magnesium	mg/L		0.6
Manganese	µg/L	120	<2
Mercury	µg/L	1	<0.02
Nitrate (as NO3)	mg/L	45	<0.2
pH			7.38
Potassium	mg/L		0.1
Selenium	µg/L	50	<2
Sodium	mg/L		10.2
Sulphate	mg/L		2
Thallium	µg/L		<1
Turbidity	NTU		0.18
Uranium	µg/L	20	<0.5
Zinc	µg/L		77



**New Brunswick Clean Water Results  
Eden Street Sampling Hydrant (Zone 28)**

*Located at: 79 Eden Street*

Organic Parameters:	Units	Health Advisory	October 24 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		0.61
Bromodichloromethane	µg/L		1.0
Dibromochloromethane	µg/L		1.2
Bromoform	µg/L		0.63
Total Trihalomethanes	µg/L	100	3.4
Trichloroacetic acid	µg/L		< 5.3
Dichloroacetic acid	µg/L		< 2.6
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	< 5.3

Inorganic Parameters:	Units	Health Advisory	October 24 2022
Alkalinity (as CaCO3)	mg/L		89
Total Hardness (as CaCO3)	mg/L		111
Aluminum	µg/L	2900	<5
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	183
Boron	µg/L	5000	<10
Cadmium	µg/L	7	<0.02
Calcium	mg/L		34.4
Chloride	mg/L		23.4
Chromium	µg/L	50	<1
Copper	µg/L	2000	<1
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		13
Lead	µg/L	5	<1
Magnesium	mg/L		6.1
Manganese	µg/L	120	<2
Mercury	µg/L	1	<0.02
Nitrate (as NO3)	mg/L	45	1.2
pH			8.00
Potassium	mg/L		0.7
Selenium	µg/L	50	<2
Sodium	mg/L		13.7
Sulphate	mg/L		6
Thallium	µg/L		<1
Turbidity	NTU		0.19
Uranium	µg/L	20	<0.5
Zinc	µg/L		<2

**New Brunswick Clean Water Results  
Aberdeen Street Sampling Hydrant (Zone 29)**

*Located at: 132 Aberdeen Avenue*

Organic Parameters:	Units	Health Advisory	October 24 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		0.84
Bromodichloromethane	µg/L		1.2
Dibromochloromethane	µg/L		1.2
Bromoform	µg/L		0.63
Total Trihalomethanes	µg/L	100	3.9
Trichloroacetic acid	µg/L		< 5.3
Dichloroacetic acid	µg/L		< 2.6
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	< 5.3

Inorganic Parameters:	Units	Health Advisory	October 24 2022
Alkalinity (as CaCO3)	mg/L		87
Total Hardness (as CaCO3)	mg/L		107
Aluminum	µg/L	2900	<5
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	186
Boron	µg/L	5000	<10
Cadmium	µg/L	7	<0.02
Calcium	mg/L		33.3
Chloride	mg/L		30.8
Chromium	µg/L	50	<1
Copper	µg/L	2000	<1
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		12
Lead	µg/L	5	<1
Magnesium	mg/L		5.9
Manganese	µg/L	120	<2
Mercury	µg/L	1	<0.02
Nitrate (as NO3)	mg/L	45	1.4
pH			7.85
Potassium	mg/L		0.2
Selenium	µg/L	50	<2
Sodium	mg/L		12.4
Sulphate	mg/L		6
Thallium	µg/L		<1
Turbidity	NTU		0.21
Uranium	µg/L	20	<0.5
Zinc	µg/L		<2

**New Brunswick Clean Water Results  
Fairville Boulevard Subway (Zone 34)**

*Located at: 800 Fairville Boulevard*

Organic Parameters:	Units	Health Advisory	October 24 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		42.0
Bromodichloromethane	µg/L		6.3
Dibromochloromethane	µg/L		0.46
Bromoform	µg/L		< 0.34
Total Trihalomethanes	µg/L	100	49.0
Trichloroacetic acid	µg/L		22.2
Dichloroacetic acid	µg/L		16.9
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	39.1

Inorganic Parameters:	Units	Health Advisory	October 24 2022
Alkalinity (as CaCO3)	mg/L		27
Total Hardness (as CaCO3)	mg/L		19
Aluminum	µg/L	2900	25
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	<10
Boron	µg/L	5000	<10
Cadmium	µg/L	7	<0.02
Calcium	mg/L		6.8
Chloride	mg/L		9.5
Chromium	µg/L	50	<1
Copper	µg/L	2000	<1
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		7
Lead	µg/L	5	<1
Magnesium	mg/L		0.6
Manganese	µg/L	120	<2
Mercury	µg/L	1	<0.02
Nitrate (as NO3)	mg/L	45	<0.2
pH			7.31
Potassium	mg/L		0.2
Selenium	µg/L	50	<2
Sodium	mg/L		10.6
Sulphate	mg/L		2
Thallium	µg/L		<1
Turbidity	NTU		0.34
Uranium	µg/L	20	<0.5
Zinc	µg/L		63

**New Brunswick Clean Water Results  
Saint John Laboratory Services (Zone 35)**

*Located at: 1216 Sand Cove Road*

Organic Parameters:	Units	Health Advisory	October 24 2022
1,2-Dichlorobenzene	µg/L	200	< 0.41
1,2-Dichloroethane	µg/L	5	< 0.35
1,4-Dichlorobenzene	µg/L	5	< 0.36
Benzene	µg/L	5	< 0.32
Benzo[a]pyrene	µg/L	0.04	< 0.01
Carbon tetrachloride	µg/L	2	< 0.17
Dichloromethane	µg/L	50	< 0.35
Ethylbenzene	µg/L	140	< 0.33
Total Xylenes	µg/L	90	< 0.43
Pentachlorophenol	µg/L	60	< 5
Tetrachloroethylene	µg/L	10	< 0.35
Toluene	µg/L	60	< 0.36
Trichloroethylene	µg/L	5	< 0.44
Vinyl chloride	µg/L	2	< 0.17
Chloroform	µg/L		56.0
Bromodichloromethane	µg/L		7.4
Dibromochloromethane	µg/L		0.50
Bromoform	µg/L		< 0.34
Total Trihalomethanes	µg/L	100	64.0
Trichloroacetic acid	µg/L		26.0
Dichloroacetic acid	µg/L		16.0
Monochloroacetic acid	µg/L		< 4.7
Bromochloroacetic acid	µg/L		< 2.0
Monobromoacetic acid	µg/L		< 2.9
Dibromoacetic acid	µg/L		< 2.0
Haloacetic acids 6 / HAA6	µg/L	80	42.0

Inorganic Parameters:	Units	Health Advisory	October 24 2022
Alkalinity (as CaCO3)	mg/L		27
Total Hardness (as CaCO3)	mg/L		18
Aluminum	µg/L	2900	<5
Antimony	µg/L	6	<2
Arsenic	µg/L	10	<1
Barium	µg/L	2000	<10
Boron	µg/L	5000	<10
Cadmium	µg/L	7	<0.02
Calcium	mg/L		6.4
Chloride	mg/L		9.3
Chromium	µg/L	50	<1
Copper	µg/L	2000	10
Fluoride	mg/L	1.5	<0.2
Iron	µg/L		<2
Lead	µg/L	5	<1
Magnesium	mg/L		0.6
Manganese	µg/L	120	<2
Mercury	µg/L	1	<0.02
Nitrate (as NO3)	mg/L	45	<0.2
pH			7.36
Potassium	mg/L		0.3
Selenium	µg/L	50	<2
Sodium	mg/L		10.9
Sulphate	mg/L		2
Thallium	µg/L		<1
Turbidity	NTU		0.20
Uranium	µg/L	20	<0.5
Zinc	µg/L		76