

## ADDENDUM

PROJECT TITLE: SAINT JOHN SIGN LIGHTING	ADD. NO: 2
TENDER NO: 2024-082301T	DATE: April 2 <sup>nd</sup> , 2024
PAGE 1 of 2 (Including Confirmation Sheet)	

Make the following modifications to the above project. Include in the amount of the Tender, any additions to or deductions from the cost of the work by reason of these instructions.

Sign and attach this Addendum to the Tender documents and submit with your Tender. Failure to do so may result in the rejection of your Tender.

Please add the following	note to Drawing E	-1.
--------------------------	-------------------	-----

- 1.0 Reference Drawing E-1:
- .1 Reference Detail 3: Notes
  - .1 Delete Specific Note 8:
  - .2 Add Specific Note 8 as follows:

Reuse existing 120V Teck cables. Verify condition of existing cabling and replace all damaged portion as required and replace all existing fasteners.

## SIGN AND RETURN THIS ADDENDUM WITH YOUR PROPOSAL

BY: Monic Maelluar		
Monic MacVicar, CCLP, CPPB	Contractor's Signature	
Procurement Specialist, Supply Chain Management		



## ADDENDUM

PROJECT TITLE: SAINT JOHN SIGN LIGHTING	ADD. NO: 2
TENDER NO: 2024-082301T	DATE: April 2 <sup>nd</sup> , 2024
PAGE 2 of 2 (Including Confirmation Sheet)	

## **CONFIRMATION - RECEIPT OF ADDENDUM**

Upon receipt of this document, fax this page to (506) 658-4742 to confirm receipt of this addendum.

CONTRACTOR'S NAME:		
ADDRESS:		
PHONE:	FAX:	
RECEIVER NAME (PRINT)		
RECEIVER SIGNATURE:		