



## ADDENDUM

PROJECT TITLE: Thermal Interconnect – Market Square and Aquatic Centre	ADD. NO: 1
TENDER NO: 2023-085104T	DATE: August 30, 2023
PAGE 1 of 2 (Including Confirmation Sheet)	

Make the following modifications to the above project. Include in the amount of the Tender, any additions to or deductions from the cost of the work by reason of these instructions.

**Sign and attach this Addendum to the Tender documents and submit with your Tender. Failure to do so may result in the rejection of your Tender.**

### Questions and Answers

Q1. Can you confirm that the 300 mm PVC DR35 pipe is just a standard pipe that is what we would consider the “regular” 4 meter in length pipe and not a special product?

*A1. The 300mm PVC DR35 pipe is a standard pipe.*

Q2. We are also wondering if it is possible to have the sidewalk excavated and the holes drilled in the buildings through the week in order to expediate the weekend work unless there is a possibility of performing this work through the normal day with traffic control. It should be noted that the southbound traffic lane is already reduced and there seems to be a minimal effect on traffic. And as that project comes to a conclusion there may be an opportunity to work reduce and divert in some cases the traffic on St Patrick Street. It should be noted that traffic will have to be reduced during the rehabilitation phase when reinstating the curb and sidewalk regardless.

*A2. The City does not have any issues with drilling the holes in the buildings through the week (as long there is no impact on the road traffic) however, these holes should be drilled after the pipe is installed across the road in case the elevation has to be adjusted to get around the existing gas line and underground electrical ducts. As for the additional comments on working throughout the week, the City would want the work to be completed on the weekend.*

### Notes

1. In Division 4, there is a page numbering error. Page 4-13 should read “4-12”.
2. Disregard any references to the “Schedule of Quantities”. The schedule is not applicable to this tender.



Chris Roberts, SCMP, CPPB  
Procurement Manager  
Supply Chain Management

\_\_\_\_\_  
Contractor’s Signature

**SIGN AND RETURN THIS ADDENDUM WITH YOUR PROPOSAL**



## ADDENDUM

PROJECT TITLE: Thermal Interconnect – Market Square and Aquatic Centre	ADD. NO: 1
TENDER NO: 2023-085104T	DATE: August 30, 2023
PAGE 2 of 2 (Including Confirmation Sheet)	

## CONFIRMATION - RECEIPT OF ADDENDUM

**Upon receipt of this document, fax this page to (506) 658-4742 to confirm receipt of this addendum.**

CONTRACTOR'S NAME: \_\_\_\_\_

ADDRESS: \_\_\_\_\_

\_\_\_\_\_

PHONE: \_\_\_\_\_ FAX: \_\_\_\_\_

RECEIVER NAME (PRINT) \_\_\_\_\_

RECEIVER SIGNATURE: \_\_\_\_\_