TRANSMITTAL SHEET

TO: All Bidders

DATE: November 16, 2023

TOTAL NUMBER OF PAGES (INCLUDING COVER PAGE):

FROM: Gerry Mattsson, P. Eng. Utilities & Infrastructure Services 6 TEL. #: (506) 649-7998

IF YOU DID NOT RECEIVE ALL PAGES, OR FURTHER INFORMATION IS REQUIRED, PLEASE CONTACT THE SENDER

MESSAGE:

TENDER NO: 2022-19

One Mile Lift Station and Egbert Street Force Main

Please find attached a copy of <u>Addendum #4</u> for the above tender.

As of March 2021, please be advised that an *Acknowledgement Form* (historically sent as part of the City's addendum packages) confirming receipt of an Addendum is **no longer** included in the addendum package.

However, in accordance with Section 2.5.03 of the City's General Specifications, it remains a requirement that each <u>Addendum</u> will contain a signature page(s) which each Tenderer is <u>required to sign and include with its Tender submission</u>.



ADDENDUM

PROJECT TITLE:	ADDENDUM N	iO:		4
One Mile Lift Station	DATE:	November 16, 2023		
And Egbert Street Force Main	PAGE:	1	OF	5
	TENDER NO:		202	2-19

MAKE THE FOLLOWING MODIFICATIONS TO THE ABOVE PROJECT. INCLUDE IN THE AMOUNT OF THE TENDER ANY ADDITIONS TO OR DEDUCTIONS FROM THE COST OF THE WORK BY REASON OF THESE INSTRUCTIONS. THE DATE FOR RECEIVING TENDERS **REMAINS THE SAME:** <u>2:30PM, TUESDAY, NOVEMBER 21, 2023</u>.

ADJUSTMENTS TO THE DRAWINGS

Item 1:

Delete Drawing C04 New Sanitary Sewer Piping Plan And Profile Revision 0 – Issued for Tender.

Add Drawing C04 New Sanitary Sewer Piping Plan And Profile Revision 1 – Issued for Addendum #4.

Item 2:

Delete Drawing C07 Egbert Street Plan & Profile Sta. 1+000 to 1+160 Revision 0 – Issued for Tender.

Add Drawing C07 Egbert Street Plan & Profile Sta. 1+000 to 1+160 Revision 1 – Issued for Addendum #4.

ADJUSTMENTS TO THE SPECIFICATIONS

Item 3: Division 3 – Particular Specifications

Add the following paragraph at the end of Section 3.1.14 Construction Sequence Plan:

Based on available model data, where required as a part of the Contractors Construction Sequence Plan (3.1.14) the Contractor is responsible to provide a methodology to convey a minimum of 3.0 L/s from WWN-COM-MH154731 and 35.0 L/s from WWN-SAN-MH001070 into the City system at an approved downstream location. The Contractor can consider pumping wastewater from existing manholes into the existing One Mile SLS grinder chamber during connection of the new sanitary manholes SMH #6 and SMH#10. Connecting the new 400mm dia. force main into the existing 400mm diameter force main can be completed by use of a live tap using a Mueller H-615 tapping sleeve or equivalent, provided that proper experience can be demonstrated.

ADJUSTMENTS IN GENERAL

Item 4: Response to Queries:

Q1. SJE indicates that the customer contribution towards the install of the new electrical service will be approximately \$13,000 – can you confirm that the Owner will be responsible for coordinating with SJE and paying these costs, and not the contractor?

A1. Section 3.1.32.25 "Measurement for Payment (Electrical) of Division 3.1 (page 3-39) says that the electrical service entrance and equipment is to be included in this pay item, so the contractor is responsible for the required cost.

Q2. Regarding Q/A #2 from Addendum #2; Can you confirm that there is only one SCADA/PLC/RTU panel, and that it is Owner supplied & contractor installed?
A2. Only one SCADA/PLC/RTU panel is required. Panel is not owner supplied.

Q3. Regarding Q/A #2 from Addendum #2; Can you advise on the manufacturer of the Owner supplied SCADA/PLC/RTU panel?

A3. The City is only supplying the radio (GE Orbit) and associated programming of the radio. The contractor is responsible for providing the antenna, cabling, (refer to Section 3.1.32.21 SCADA panel & Section 3.1.32.23 Radio System), and the PLC and HMI programming software and SCADA programming.

Q4. Regarding Q/A #2 from Addendum #2; Does the panel manufacturer need to be engaged and paid by the contractor to provide the programming, software, integration, etc., or is their involvement covered under the PO the City has placed to produce the panel?

A4. See A3 above.

Q5. Regarding Q/A #2 from Addendum #2; Will any part of the programming, software, integration, etc. be performed by City staff?

A5. Programming and software for the SCADA/PLC/RTU is by the panel manufacturer and integration into the City's SCADA system is coordinated with the City.

Q6. Regarding Section 3.1.31; Item 9 Sewage Pumps - Can you confirm that these are supplied with a pre-terminated length of cable, long enough to reach the above ground junction boxes? They do come with pre-terminated length of cable.

A6. Assume the proper length of pump cabling will be selected as part of the shop drawing review process.

Q7. Regarding Section 3.1.31; Item 16 Electronic Pressure Gauge – Can you confirm that these are supplied by mechanical, but installed by electrical (as per drawing E04 detail 12)? Do these require any cabling?

1Laz		
CHIEF CITY ENGIN	EER	CONTRAC
TO BE SIGNED ANI	DATTACHED TO	O TENDER DOCUM
TO BE SIGNED ANI	D ATTACHED T	O TENDER DOCUMI
TO BE SIGNED ANI	D ATTACHED T	O TENDER DOCUMI

BY

	1/2
<i>(</i> :	1602
	CHIEF CITY ENGINEER

and their respective subtrades.

CONTRACTOR'S SIGNATURE

Note: Signed copy of the addendum must be enclosed in the tender documents, according to the Instructions to Tenderers and Tendering Procedures in Division 2 of the Contract Specifications.

towards the creek? A10. SJ Energy could be engaged by the contractor to cover the lines if need be. SJ energy advises that the clearance from an uncovered line would need to be 12 feet. If the lines were covered, the minimum clearance reduces to 1m.

contractor and their respective subtrades. Q10. We met with our sheet piling subcontractor today and they have concerns about the proximity of the power lines to where the sheet piling would need to be installed in order to install wet well #2 and the CSO Chambers. Is there any possibility of moving the wet wells closer together or shifting the wet wells and the CSO chambers back

Q9. Regarding Section 3.1.31; Item 18 Level and Float Sensors – Can you confirm that these are supplied with factory terminated cabling, sufficient in length to reach the above ground junction boxes? Can you confirm that these are supplied and installed by mechanical (wired only by electrical)?

A9. Assume the proper length of cabling will be selected as part of the shop drawing review process. Determination of subtrade scopes of work to be arranged between the general

Q8. Regarding Section 3.1.31; Item 17 Flow Meter and Transmitter – Can you confirm these are supplied and installed by mechanical? Can you confirm the display is also installed by mechanical?

A8. Determination of subtrade scopes of work to be arranged between the general contractor

A7. All devices will require cabling. Instrumentation cabling listed on drawings. Determination of subtrade scopes of work to be arranged between the general contractor and their respective subtrades.

Tender 2022-19

Addendum #4



