

TRANSMITTAL SHEET

TO: All Bidders
DATE: February 20, 2025
TOTAL NUMBER OF PAGES (INCLUDING COVER PAGE): 3
FROM: John Campbell, P. Eng. **TEL. #:** (506) 654-1354
Utilities & Infrastructure Services

IF YOU DID NOT RECEIVE ALL PAGES, OR FURTHER INFORMATION IS REQUIRED,
PLEASE CONTACT THE SENDER

MESSAGE:

TENDER NO: 2023-06

Millidge Avenue – Sanitary Lift Station Modifications

Please find attached a copy of **Addendum #1** for the above tender.

As of March 2021, please be advised that an ***Acknowledgement Form*** (historically sent as part of the City’s addendum packages) confirming receipt of an Addendum is **no longer** included in the addendum package.

However, in accordance with Section 2.5.03 of the City’s General Specifications, it remains a requirement that **each Addendum** will contain a signature page(s) which each Tenderer is **required to sign and include with its Tender submission.**



UTILITIES & INFRASTRUCTURE SERVICES
Engineering Services
175 Rothesay Avenue
Saint John, NB, E2J 2B4

ADDENDUM

PROJECT TITLE:

Millidge Avenue – Sanitary Lift Station Modifications

ADDENDUM NO:

1

DATE:

February 20, 2025

PAGE:

1 OF 2

TENDER NO:

2023-06

MAKE THE FOLLOWING MODIFICATIONS TO THE ABOVE PROJECT. INCLUDE IN THE AMOUNT OF THE TENDER ANY ADDITIONS TO OR DEDUCTIONS FROM THE COST OF THE WORK BY REASON OF THESE INSTRUCTIONS. THE DATE FOR RECEIVING TENDERS REMAINS AS: **2:30PM, TUESDAY, FEBRUARY 25, 2025.**

CHANGES TO THE SPECIFICATIONS

Division 2 – Submission of Tender

The City of Saint John is implementing adjustments to the tender submission procedure as follows:

Section 2.6.01 Location of Tender Box for the Submission of Tender

175 Rothesay Avenue, Saint John, New Brunswick

The tender box will be available at the main building entrance for submission of tenders by the Tenderer between the hours of 9:30 am and 2:30 pm only on the above tender closing date.

There will not be a public tender opening. Registered Bidders will receive an email invitation to view the Tender Opening using Microsoft Teams software. Email invitations will be sent to the address provided on the Official Bidder's List. The Tender Opening Committee will conduct the evaluation of the tenders and Compliant tenders will be included in the summary of bids on the City's Tenders & Proposals website within 1 business day following the tender closing.

Division 3 – Particular Specifications

Section 3.1.01 – Work Description

Revise section to add the following bullet:

- The Contractor is responsible to modify and provide all material for extending cables between the elevated equipment cabinet and equipment in the wet well.

Section 3.1.31.15 – Level and Float Sensors

Remove the sentence, "Two (2) float type level switches shall provide the signals for a high-water level (alarm) indication and for low water alarm and pump shutdown redundancy." and replace with, "Two (2) new float-type level switches shall be provided to signal high-water level alarm, low-water alarm and pump shutdown redundancy."

Following 3.1.02.19 – Electrical Supply, the heading “Execution” is to be numbered as section 3.1.02.20.

Section 3.1.02.20 – Execution

Replace section 5 with the following:” The pumps to be controlled by a submersible pressure transducer which sends a wet well level input signal to the PLC. Provide a new controller with the required cable length to reach the new panel height. The PLC sends start/stop and alarm signals to the pumps. The pumps shall be operated in a lead/standby manner and will not operate in parallel. If the lead pump fails to start or stops due to a fault condition, the standby pump is to be started. The circuits to the transducer and float switches to be intrinsically safe circuits using IS barrier. Refer to Drawings for wet well setpoints.

Add section 3.1.02.20.15 New pump cables are to be provided to extend to the elevated enclosure. Contractor to provide new Meltric connections to two aux contacts to allow disconnection of the pump cables in the wet well.

Note: Signed copy of the addendum must be enclosed in the tender documents, according to the Instructions to Tenderers and Tendering Procedures in Division 2 of the Contract Specifications.

BY:



CHIEF CITY ENGINEER

CONTRACTOR'S SIGNATURE

TO BE SIGNED AND ATTACHED TO TENDER DOCUMENTS