

TRANSMITTAL SHEET

TO: All Bidders

DATE: March 13, 2024

TOTAL NUMBER OF PAGES (INCLUDING COVER PAGE): 4

FROM: Kevin O'Brien, P. Eng. TEL. #: (506) 658-4455
Utilities & Infrastructure Services

IF YOU DID NOT RECEIVE ALL PAGES, OR FURTHER INFORMATION IS REQUIRED,
PLEASE CONTACT THE SENDER

MESSAGE:

TENDER NO: 2023-12

Sydney Street (St. James Street to Queen Square North) – Street Reconstruction

Please find attached a copy of Addendum #1 for the above tender.

As of March 2021, please be advised that an ***Acknowledgement Form*** (historically sent as part of the City's addendum packages) confirming receipt of an Addendum is **no longer** included in the addendum package.

However, in accordance with Section 2.5.03 of the City's General Specifications, it remains a requirement that **each Addendum** will contain a signature page(s) which each Tenderer is **required to sign and include with its Tender submission.**



UTILITIES & INFRASTRUCTURE SERVICES
Engineering Services
175 Rothesay Avenue
Saint John, NB, E2J 2B4

ADDENDUM

PROJECT TITLE:

**SYDNEY STREET (ST. JAMES STREET TO QUEEN
SQUARE NORTH) – STREET RECONSTRUCTION**

ADDENDUM NO: 1

DATE: MARCH 13, 2024

PAGE: 1 **OF** 3

TENDER NO: 2023-12

MAKE THE FOLLOWING MODIFICATIONS TO THE ABOVE PROJECT. INCLUDE IN THE AMOUNT OF THE TENDER ANY ADDITIONS TO OR DEDUCTIONS FROM THE COST OF THE WORK BY REASON OF THESE INSTRUCTIONS. THE DATE FOR RECEIVING TENDERS REMAINS AT: **2:30:00 PM, TUESDAY, MARCH 19, 2024.**

ADJUSTMENTS TO THE SPECIFICATIONS

Division 2 – Submission of Tender

The City of Saint John is implementing adjustments to the tender submission procedure as follows:

Section 2.6.01 Location of Tender Box for the Submission of Tender

175 Rothesay Avenue, Saint John, New Brunswick

The tender box will be available at the main building entrance for submission of tenders by the Tenderer between the hours of 9:30 am and 2:30:00 pm only on the above tender closing date.

There will not be a public tender opening. Registered Bidders will receive an email invitation to view the Tender Opening using Microsoft Teams software. Email invitations will be sent to the address provided on the Official Bidder's List. The Tender Opening Committee will conduct the evaluation of the tenders and Compliant tenders will be included in the summary of bids on the City's Tenders & Proposals website within 1 business day following the tender closing.

ADJUSTMENTS TO DIVISION 4 - FORM OF TENDER

In the Contract Specifications, Division 4 – Form of Tender, Section 4.5 (Schedule of Quantities and Unit Prices) replace Sheet 12 of 20 with the attached Sheet 12 of 20.

TO THE DRAWINGS:

Sheet 01: Change Structure diameters of STMH#1A and STMH#1B from 1500mmØ to 1800mmØ.

Please see the following responses to questions received:

REGARDING SOLAR POWERED LED-EMBEDDED STOP SIGN (SPEC SECTION 3.1.34):

Q1: Is a site-specific solar assessment required?

A1: Yes, a site-specific solar assessment is required.

Q2: What is the Minimum Array-to-load ratio?

A2: The minimum array-to-load ratio shall be 1.25 (i.e.: Photovoltaic production shall be greater than the load by 25%).

Q3: Is Remote communication with status notifications required?

A3: The model specified in Division 3.1.34 should include the remote communication functionality as a standard capability; however, the City does not wish to subscribe to the remote communication service as part of this tender.

Note: Signed copy of the addendum **must** be enclosed in the tender documents, according to the Instructions to Tenderers and Tendering Procedures in Division 2 of the Contract Specifications.

BY:


CHIEF CITY ENGINEER

CONTRACTOR'S SIGNATURE

TO BE SIGNED AND ATTACHED TO TENDER DOCUMENTS

DIVISION 4

SCHEDULE OF QUANTITIES AND UNIT PRICES

UNIT PRICE TO BE EITHER
TYPEWRITTEN OR
PRINTED IN INK IN WORDS
AND PRINTED
NUMERICALLY

CONTRACT NUMBER 2023-12

TITLE: SYDNEY STREET (QUEEN SQUARE NORTH TO ST JAMES ST)

WATER, SANITARY SEWER, AND STORM SEWER RENEWAL AND STREET RECONSTRUCTION

ITEM NO.	DESCRIPTION	DIV. NO.	UNIT	EST. QTY.	UNIT BID PRICE		TOTAL (\$)
					WRITTEN	NUMERICAL	
c	1200mm Ø precast MH complete with City adjustable frame and cover and incl. all labour & materials necessary to connect to new and existing mains & laterals, etc.		Each	4			
d	1500mm Ø precast MH complete with City adjustable frame and cover and incl. all labour & materials necessary to connect to new and existing mains & laterals, etc.		Each	1			
e	1800mm Ø precast MH complete with City adjustable frame and cover and incl. all labour & materials necessary to connect to new and existing mains & laterals, etc.		Each	2			
f	750mm Ø precast catch basin, complete with City standard frame and cover, incl. all connections		Each	11			
5	<u>Calcium Chloride - Supply & Place</u>	24	Per 40 kg	10			
6	<u>CCTV Video</u>	11	m	308			
7	<u>Contingency</u>	2.6.03	LS	1	Thirty Five Thousand Dollars and Zero Cents	35,000.00	35,000.00
	AMOUNT "C" (STORM SEWER)						