

TRANSMITTAL SHEET

TO: All Bidders
DATE: August 7, 2024
TOTAL NUMBER OF PAGES (INCLUDING COVER PAGE): 5
FROM: Holly Young, P. Eng. **TEL. #:** (506) 658-4455
Utilities & Infrastructure Services

IF YOU DID NOT RECEIVE ALL PAGES, OR FURTHER INFORMATION IS REQUIRED,
PLEASE CONTACT THE SENDER

MESSAGE:

TENDER NO: 2024-05

**Sussex Drive (Technology Drive to Millidge Avenue) and Shamrock Park
Storm Sewer Installation**

Please find attached a copy of Addendum #1 for the above tender.

As of March 2021, please be advised that an *Acknowledgement Form* (historically sent as part of the City's addendum packages) confirming receipt of an Addendum is **no longer** included in the addendum package.

However, in accordance with Section 2.5.03 of the City's General Specifications, it remains a requirement that **each Addendum** will contain a signature page(s) which each Tenderer is **required to sign and include with its Tender submission.**



UTILITIES & INFRASTRUCTURE SERVICES
Engineering Services
175 Rothesay Avenue
Saint John, NB, E2J 2B4

ADDENDUM

PROJECT TITLE:

SUSSEX DRIVE (TECHNOLOGY DRIVE TO MILLIDGE AVENUE) AND SHAMROCK PARK

STORM SEWER INSTALLATION

ADDENDUM NO:

1

DATE:

AUGUST 7, 2024

PAGE:

1 OF 4

TENDER NO:

2024-05

MAKE THE FOLLOWING MODIFICATIONS TO THE ABOVE PROJECT. INCLUDE IN THE AMOUNT OF THE TENDER ANY ADDITIONS TO OR DEDUCTIONS FROM THE COST OF THE WORK BY REASON OF THESE INSTRUCTIONS. THE DATE FOR RECEIVING TENDERS REMAINS AT: **2:30:00 PM, TUESDAY, AUGUST 13, 2024.**

ADJUSTMENTS TO THE SPECIFICATIONS

Division 2 – Submission of Tender

The City of Saint John is implementing adjustments to the tender submission procedure as follows:

Section 2.6.01 Location of Tender Box for the Submission of Tender

175 Rothesay Avenue, Saint John, New Brunswick

The tender box will be available at the main building entrance for submission of tenders by the Tenderer between the hours of 9:30 am and 2:30:00 pm only on the above tender closing date.

There will not be a public tender opening. Registered Bidders will receive an email invitation to view the Tender Opening using Microsoft Teams software. Email invitations will be sent to the address provided on the Official Bidder's List. The Tender Opening Committee will conduct the evaluation of the tenders and Compliant tenders will be included in the summary of bids on the City's Tenders & Proposals website within 1 business day following the tender closing.

ADJUSTMENTS TO DIVISION 4 - FORM OF TENDER

In the Contract Specifications, Division 4 – Form of Tender, Section 4.5 (Schedule of Quantities and Unit Prices) replace Sheet 1 of 16 AND Sheet 2 of 16 with the attached Sheet 1 of 16 AND Sheet 2 of 16.

CLARIFICATION


Please see the following clarification on the Drawings:

- Drawing S039-002 (Sheet 2 of 3 and Sheet 3 of 3), the water main on Sussex Drive,

from approximately Station 0+333 to the intersection with Millidge Avenue intersection is 200 mm diameter PVC. All other water main on Sussex Drive is 200 mm diameter ductile iron as indicated.

Note: Signed copy of the addendum **must** be enclosed in the tender documents, according to the Instructions to Tenderers and Tendering Procedures in Division 2 of the Contract Specifications.

BY:



CHIEF CITY ENGINEER

CONTRACTOR'S SIGNATURE

TO BE SIGNED AND ATTACHED TO TENDER DOCUMENTS

DIVISION 4

SCHEDULE OF QUANTITIES AND UNIT PRICES

CONTRACT NUMBER 2024-05

TITLE: SUSSEX DRIVE (TECHNOLOGY DRIVE TO MILLIDGE AVENUE) AND SHAMROCK PARK
STORM SEWER INSTALLATION

UNIT PRICE TO BE EITHER
TYPEWRITTEN OR PRINTED
IN INK IN WORDS AND
PRINTED NUMERICALLY

ITEM NO.	DESCRIPTION	DIV. NO.	UNIT	EST. QTY.	UNIT BID PRICE		TOTAL (\$)
					WRITTEN	NUMERICAL	
A	WATER - SUSSEX DRIVE						
1	<u>Excavation</u>	13					
a)	Rock		m ³	100			
1	<u>Backfill</u>	13					
a)	Unshrinkable Fill (max 28 day compressive strength < 0.4MPa, Slump 150-200mm, max 25kg of Type 10 Portland cement per m ³ , Air entrainment between 4-6%)		m ³	50			
2	<u>Pipelaying & Jointing: Watermain - Supply & Install</u>	7, 10					
b)	150mm Ø PVC, DR18, Class 150 or approved equal including tracer wire and connections		m	7			
c)	200mm Ø PVC, DR18, Class 150 or approved equal including tracer wire and connections		m	5			
d)	250mm Ø PVC, DR18, Class 150 or approved equal including tracer wire and connections		m	25			
e)	200mm Ø Coupling for connection to existing watermain		Each	2			
f)	250mm Ø Coupling for connection to existing watermain		Each	4			

DIVISION 4
SCHEDULE OF QUANTITIES AND UNIT PRICES

CONTRACT NUMBER 2024-05

**TITLE: SUSSEX DRIVE (TECHNOLOGY DRIVE TO MILLIDGE AVENUE) AND SHAMROCK PARK
 STORM SEWER INSTALLATION**

**UNIT PRICE TO BE EITHER
 TYPEWRITTEN OR PRINTED
 IN INK IN WORDS AND
 PRINTED NUMERICALLY**

ITEM NO.	DESCRIPTION	DIV. NO.	UNIT	EST. QTY.	UNIT BID PRICE		TOTAL (\$)
					WRITTEN	NUMERICAL	
g)	250mm x 45 ° Bend		Each	4			
h)	250mm x 250mm x 200mm Tee		Each	1			
i)	200mm Gate Valve		Each	1			
j)	250mm Gate Valve		Each	2			
k)	130mm Service Box & tracer wire		Each	3			
l)	5.5kg (12 lb.) Anodes on valves and mechanical fittings 200mm Ø and smaller		Each	3			
m)	11kg (24 lb.) Anodes on water service connections, valves and mechanical fittings		Each	12			
3	<u>Fire Hydrants - Supply & Install</u>	10					
a)	Fire hydrant complete, including anchor tee, 150mm GV, 130mm VB, restraints, concrete thrust blocks, vertical piping, polyethylene encasement, tracer wire and Storz pumper nozzle.		Each	1			
4	<u>Insulation - Supply & Install</u>	10					
a)	Supply and install 50mm thick insulation		m ²	10			
5	<u>Contingency</u>	2.6.03	LS	1	Ten Thousand Dollars and Zero Cents	10,000.00	10,000.00
	AMOUNT "A" (WATER - SUSSEX DRIVE)						