

TRANSMITTAL SHEET

TO: All Bidders

DATE: 17 April, 2025

TOTAL NUMBER OF PAGES (INCLUDING COVER PAGE): 3

FROM: John Campbell, P. Eng. **TEL. #:** (506) 632-6890
Utilities & Infrastructure Services

IF YOU DID NOT RECEIVE ALL PAGES, OR FURTHER INFORMATION IS REQUIRED,
PLEASE CONTACT THE SENDER

MESSAGE:

TENDER NO: 2024-07

Kennedy Street - Sanitary Lift Station Modifications

Please find attached a copy of **Addendum #1** for the above tender.

As of March 2021, please be advised that an ***Acknowledgement Form*** (historically sent as part of the City's addendum packages) confirming receipt of an Addendum is **no longer** included in the addendum package.

However, in accordance with Section 2.5.03 of the City's General Specifications, it remains a requirement that **each Addendum** will contain a signature page(s) which each Tenderer is **required to sign and include with its Tender submission.**



UTILITIES & INFRASTRUCTURE SERVICES
Engineering Services
175 Rothesay Avenue
Saint John, NB, E2J 2B4

ADDENDUM

PROJECT TITLE:

Kennedy Street Sanitary Lift Station Modifications

ADDENDUM NO: 1

DATE: April 17, 2025

PAGE: 1 **OF** 2

TENDER NO: 2024-07

MAKE THE FOLLOWING MODIFICATIONS TO THE ABOVE PROJECT. INCLUDE IN THE AMOUNT OF THE TENDER ANY ADDITIONS TO OR DEDUCTIONS FROM THE COST OF THE WORK BY REASON OF THESE INSTRUCTIONS. THE DATE FOR RECEIVING TENDERS REMAINS AT: **2:30:00PM, April 22, 2025.**

ADJUSTMENTS TO THE SPECIFICATIONS

Division 2 – Instructions to Tenderers and Tendering Procedures

The City of Saint John is implementing adjustments to the tender submission procedure as follows:

Section 2.6.01 Location of Tender Box for the Submission of Tender

175 Rothesay Avenue, Saint John, New Brunswick

The tender box will be available at the main building entrance for submission of tenders by the Tenderer between the hours of 9:30 am and 2:30:00 pm only on the above tender closing date.

There will not be a public tender opening. Registered Bidders will receive an email invitation to view the Tender Opening using Microsoft Teams software. Email invitations will be sent to the address provided on the Official Bidder's List. The Tender Opening Committee will conduct the evaluation of the tenders and Compliant tenders will be included in the summary of bids on the City's Tenders & Proposals website within 1 business day following the tender closing.

Timetable for Completion of the Work

Replace Section 2.2.10 with the following: "The Substantial Completion of the Work is **ten(10) weeks from start of construction, but no later than October 15th, 2025**".

Replace Section 4.2, Paragraph 4, with: "In the event that the City accepts its Tender, the undersigned Tenderer hereby agrees to Substantially Complete the Work **ten(10) weeks from start of construction, but no later than October 15th, 2025.**"

Replace Section 5.1, paragraph 2(c) with: "The Contractor shall Substantially Complete the Work **ten(10) weeks from start of construction, but no later than October 15th, 2025.**"

Division 3 – Particular Specifications

Section 3.1.32.9.9 – Plug Valves, Acceptable Products, Add “DeZurik PEC Eccentric Plug Valve.”

Section 3.1.32.10.2 – Check Valves, Add “DeZurik APCO Swing Check Valve” as approved equal.

Section 3.1.32.11 – Combination Air Valve, Add “DeZurik APCO ASC Single Body Combination Valve” as approved equal.


Replace Section 3.1.32.15 – Level and Float Sensors, paragraph 6, with “Two (2) new float type level switches shall provide the signals for a high-water level (alarm) indication and for low water alarm and pump shutdown redundancy. The float switches shall provide backup pump control in the event of a pressure transducer level controller failure.”

Replace Section 3.1.02.18.10.2 – Electrical Heater, with “Stelpro WF1508W or approved equal.”

Following 3.1.02.19 – Electrical Supply, the heading “Execution” is to be numbered as section 3.1.02.20.

Note: Signed copy of the addendum **must** be enclosed in the tender documents, according to the Instructions to Tenderers and Tendering Procedures in Division 2 of the Contract Specifications.

BY:


for CHIEF CITY ENGINEER

CONTRACTOR'S SIGNATURE

TO BE SIGNED AND ATTACHED TO TENDER DOCUMENTS