

TRANSMITTAL SHEET

TO: All Bidders

DATE: June 12, 2025

TOTAL NUMBER OF PAGES (INCLUDING COVER PAGE): 4

FROM: Jill DeMerchant, P.Eng. **TEL. #:** (506) 647-9382
Utilities & Infrastructure Services

IF YOU DID NOT RECEIVE ALL PAGES, OR FURTHER INFORMATION IS REQUIRED,
PLEASE CONTACT THE SENDER

MESSAGE:

TENDER NO: 2024-16

Sandy Point Road and Foster Thurston Drive Roundabout

Please find attached a copy of **Addendum #1** for the above tender.

As of March 2021, please be advised that an ***Acknowledgement Form*** (historically sent as part of the City's addendum packages) confirming receipt of an Addendum is **no longer** included in the addendum package.

However, in accordance with Section 2.5.03 of the City's General Specifications, it remains a requirement that **each Addendum** will contain a signature page(s) which each Tenderer is **required to sign and include with its Tender submission.**



UTILITIES & INFRASTRUCTURE SERVICES
Engineering Services
175 Rothesay Avenue
Saint John, NB, E2J 2B4

ADDENDUM

PROJECT TITLE:

**SANDY POINT ROAD AND FOSTER THURSTON DRIVE
ROUNDAABOUT**

ADDENDUM NO: 1

DATE: June 12, 2025

PAGE: 1 **OF** 3

TENDER NO: 2024-16

MAKE THE FOLLOWING MODIFICATIONS TO THE ABOVE PROJECT. INCLUDE IN THE AMOUNT OF THE TENDER ANY ADDITIONS TO OR DEDUCTIONS FROM THE COST OF THE WORK BY REASON OF THESE INSTRUCTIONS. THE DATE FOR RECEIVING TENDERS REMAINS AT: **2:30:00 PM, TUESDAY, JUNE 17, 2025.**

ADJUSTMENTS TO THE SPECIFICATIONS

Division 2 – Submission of Tender

The City of Saint John is implementing adjustments to the tender submission procedure as follows:

Section 2.6.01 Location of Tender Box for the Submission of Tender

175 Rothesay Avenue, Saint John, New Brunswick

The tender box will be available at the main building entrance for submission of tenders by the Tenderer between the hours of 9:30 am and 2:30:00 pm only on the above tender closing date.

There will not be a public tender opening. Registered Bidders will receive an email invitation to view the Tender Opening using Microsoft Teams software. Email invitations will be sent to the address provided on the Official Bidder's List. The Tender Opening Committee will conduct the evaluation of the tenders and Compliant tenders will be included in the summary of bids on the City's Tenders & Proposals website within 1 business day following the tender closing.

Division 4 – Form of Tender

Section 4.5 Schedule of Quantities and Unit Prices

Replace Sheet 7 of 14 of Section 4.5 with the attached.

ENQUIRIES

Please see the following responses to questions received:

Q1: No specification was provided for the distribution panel. Are push on breakers acceptable? Can we use a load center c/w MB or does it have to be commercial grade c/w bolt on breakers.

A1: *A load center with push on breakers is acceptable.*

Q2: No specification was provided for the required lighting contactor. Need to know # of poles, amperage, voltage

A2: *The contactor is to be six pole, 30 amps and 120 volt.*

Q3: For the Central Island Grass Stone, does this item include the supply of topsoil or will the topsoil be paid under the topsoil item?

A3: *The topsoil for the Grass Stone is to be included in the grass stone item.*

Q4: Do the Oversized one-way signs and the WA-38 Roundabout directional sign need to be High Intensity Reflective or Diamond grade?

A4: *Sign sheeting should be diamond grade.*

Q5: CB4 and CBMH2 are not standard catch basins used in Saint John. Would you accept a 42" and a 30" round catch basin in place of these structures?

A5: *Round catch basins are acceptable. Inlet grate should be square, angled to the slope as shown on the drawings.*

Note: Signed copy of the addendum **must** be enclosed in the tender documents, according to the Instructions to Tenderers and Tendering Procedures in Division 2 of the Contract Specifications.

BY:


CHIEF CITY ENGINEER

CONTRACTOR'S SIGNATURE

TO BE SIGNED AND ATTACHED TO TENDER DOCUMENTS

DIVISION 4.5

SCHEDULE OF QUANTITIES AND UNIT PRICES

UNIT PRICE TO BE EITHER
TYPEWRITTEN OR PRINTED
IN INK IN WORDS AND
PRINTED NUMERICALLY

CONTRACT NUMBER 2024-16

TITLE: SANDY POINT ROAD AND FOSTER THURSTON ROUNDABOUT

ITEM NO.	DESCRIPTION	DIV. NO.	UNIT	EST. QTY.	UNIT BID PRICE		TOTAL (\$)
					WRITTEN	NUMERICAL	
D	ROAD WORK	13, 24					
1	<u>Excavation (Roads or Other Surfaces)</u>						
	a) Common excavation - includes all road, driveways, sidewalks, culverts and areas for regrading purposes		m ³	3390			
	b) Rock excavation		m ³	860			
	c) Grubbing		m ²	4600			
2	<u>Granular Backfill & Compaction (Roads or Other Surfaces) - Supply & Place</u>	13, 24					
	a) Imported Pit Run Gravel Subbase		m ³	5195			
	b) Imported Crushed Gravel Base Material		m ³	930			
3	<u>Bituminous Tack</u>	27					
	a) Supply & place bituminous tack		m ²	3965			