



ADDENDUM

PROJECT TITLE: Air-To-Air Energy Recovery Ventilator	ADD. NO: 2
RFP NO: 2023-414001P	DATE: May 23 rd , 2023
PAGE 1 of 2 (Including Confirmation Sheet)	

Make the following modifications to the above project. Include in the amount of the Proposal, any additions to or deductions from the cost of the work by reason of these instructions.

Sign and attach this Addendum to the Proposal documents and submit with your Proposal. Failure to do so may result in the rejection of your Proposal.

Please find below clarification question for Addendum #1.

Q1. In the addenda there is indication of a Heating Coil

HEATING COIL SCHEDULE							
TAG	MANUFACTURER AND MODEL NUMBER	AIR FLOW	CAPACITY	VOLTAGE	PHASE	FREQUENCY	ACCESSORY
HC-1	RENEWAIRE	6000 CFM	90kW	600	3	60	OUTDOOR COIL

But in the specification 237200 there doesn't appear to be any heating coil specified, can you confirm that it is the intent to not have heating coil as part of the unit.

A1. The heating coil is installed on the ductwork not in the unit and intended for outdoors installation.

SIGN AND RETURN THIS ADDENDUM WITH YOUR PROPOSAL

Monic MacVicar

BY: _____
 Monic MacVicar, CCLP, CPPB
 Procurement Specialist, Supply Chain Management

 Contractor's Signature



ADDENDUM

PROJECT TITLE: Air-To-Air Energy Recovery Ventilator	ADD. NO: 2
RFP NO: 2023-414001P	DATE: May 23 rd , 2023
PAGE 2 of 2 (Including Confirmation Sheet)	

CONFIRMATION - RECEIPT OF ADDENDUM

**Upon receipt of this document, fax this page to
(506) 658-4742 to confirm receipt of this addendum.**

CONSULTANT'S NAME: _____

ADDRESS: _____

PHONE: _____ FAX: _____

RECEIVER NAME (PRINT) _____

RECEIVER SIGNATURE: _____