



ADDENDUM

PROJECT TITLE: Air-To-Air Energy Recovery Ventilator	ADD. NO: 1
RFP NO: 2023-414001P	DATE: May 23 rd , 2023
PAGE 1 of 2 (Including Confirmation Sheet)	

Make the following modifications to the above project. Include in the amount of the Proposal, any additions to or deductions from the cost of the work by reason of these instructions.

Sign and attach this Addendum to the Proposal documents and submit with your Proposal. Failure to do so may result in the rejection of your Proposal.

Please find attached the drawing.

SIGN AND RETURN THIS ADDENDUM WITH YOUR PROPOSAL

Monic MacVicar

BY: _____
Monic MacVicar, CCLP, CPPB
Procurement Specialist, Supply Chain Management

Contractor's Signature



ADDENDUM

PROJECT TITLE: Air-To-Air Energy Recovery Ventilator	ADD. NO: 1
RFP NO: 2023-414001P	DATE: May 23 rd , 2023
PAGE 2 of 2 (Including Confirmation Sheet)	

CONFIRMATION - RECEIPT OF ADDENDUM

**Upon receipt of this document, fax this page to
(506) 658-4742 to confirm receipt of this addendum.**


CONSULTANT'S NAME: _____

ADDRESS: _____


PHONE: _____ FAX: _____

RECEIVER NAME (PRINT) _____


RECEIVER SIGNATURE: _____



1 MECHANICAL UNIT LOCATION PLAN VIEW
M4.5 NTS



5 MECHANICAL UNIT SECTION VIEW
M4.5 NTS



2 ERV UNIT - 3D VIEW
M4.5

HEATING COIL SCHEDULE							
TAG	MANUFACTURER AND MODEL NUMBER	AIR FLOW	CAPACITY	VOLTAGE	PHASE	FREQUENCY	ACCESSORY
HC-1	RENEWAIRE	6000 CFM	90KW	600	3	60	OUTDOOR COIL

ERV UNIT SCHEDULE									
TAG	MANUFACTURER AND MODEL NUMBER	AIR FLOW	VOLTAGE	PHASE	FREQUENCY	MCA	MOP	ESTATIC PRESSURE	
HRV-1	RenewAire LE-8X	6000 CFM	577	3	60	18.8	20	1.25 IWC	

REVISIONS

No.	DESCRIPTION	DATE
0	ISSUE FOR ADDENDUM #2	2022-07-06
1	ISSUE FOR REVIEW	2022-12-23
2	ISSUE FOR PRICING	2023-03-01

LEGEND

DETAIL REFERENCE NODE

1 L6
DETAIL NUMBER
SHEET NUMBER

NOTES

- GENERAL CONTRACTOR SHALL CHECK ALL DIMENSIONS ON DRAWINGS AND REPORT IN WRITING TO GLENN GROUP LTD. ANY AND ALL DISCREPANCIES TO MEASUREMENTS OR COORDINATE POINTS BEFORE PROCEEDING WITH THE WORK.
- THE HORIZONTAL AND VERTICAL DATUM UTILIZED: NAD83 (CSRS) NEW BRUNSWICK DOUBLE STEREOGRAPHIC PROJECTION AND THE CANADIAN GEODETIC VERTICAL DATUM OF 1928 (GVD28)
- SURVEY INFORMATION PROVIDED BY HUGHES SURVEYS AND CONSULTANTS ON JULY 24, 2015, AND FUNDY ENGINEERING ON FEBRUARY 24, 2022. CONTRACTOR RESPONSIBLE TO CONDUCT AS-BUILT SURVEY OF SITE AFTER COMPLETION WITH GEODETIC X,Y,Z COORDINATES TO BE SUBMITTED TO CONSULTANT. PAPER AND ELECTRONIC COPIES OF DOCUMENTS TO BE SUBMITTED.
- DRAWING NOT TO BE USED FOR LEGAL PROPERTY DEFINITION.
- ADDITIONAL LAYOUT INFORMATION TO BE PROVIDED TO CONTRACTOR UPON CONTRACT AWARD. DIGITAL FILES WILL BE MADE AVAILABLE AFTER CONTRACT AWARDED.

STAMP

PRIME CONSULTANT
GLENN GROUP
LANDSCAPE ARCHITECTS & PARK PLANNERS

SUB-CONSULTANT
CBCL

SUB-CONSULTANT
FUNDY Engineering
27 Wellington Row Tel: (506) 635-1566
P.O. Box 6626 Fax: (506) 635-0206
Saint John, NB fundy@fundyeng.com
E2L 4S1 www.fundyeng.com
Serving Our Clients' Needs First

SUB-CONSULTANT
ESTABROOKS ENGINEERING INC.
STRUCTURAL CONSULTANTS
107 Germain Street, Suite 200
Saint John, New Brunswick
Tel: (506) 674-1810
Fax: (506) 674-1812
Email: info@estabrooks.com

PROJECT TITLE
PUBLIC SPACE AT MARKET SLIP & HARBOUR PASSAGE EXTENSION

DRAWING NAME
PATIO VENTILATION SYSTEM - PHASE 2 HRV LOCATION AND CONNECTIONS

DATE PRINTED: 10.06.2022
DESIGNED BY: HL

DRAWN BY: BS
CHECKED BY: HL

CLIENT PROJECT No.: 2022-081201T
GG PROJECT NO.: 2107

SCALE: NTS
DATE: 10.06.2022

SHEET NUMBER
M4.5